

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110 001

No. F.6/DFS/MS/EH/2016/ 52/1495

Dated: 10/10/16

FIRE SAFETY CERTIFICATE

Certified that the **The Flying Saucer café (A unit of Priyank Sukhija Café Concept Private Limited)**, located at **Property Development Area, Lower Ground Floor, TDI Mall, Nehru Palace Metro Station, New Delhi-110019** comprised of Basement, Lower Ground floor & Upper Ground Floor, but the Restaurant is running on Lower Ground Floor only was granted FSC by this department vide letter No.F6/DFS/MS/2013/EH/SZ/612 dated 24/07/2013. The premises was re- inspected by the officer concerned of this department on 19/09/16 in the presence of Mr. M. C. Pathani and found that the restaurant have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class **Group- D Assembly Building** with effect from ~~10/10/16~~ 10/10/16-2016 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule-38 of the Delhi Fire Service Rules, 2010.

Issued on.....10/10/16.....at New Delhi by.


(Vipin Kental)
Chief Fire Officer
Tel: 011-23412225

Copy to:-

1. The Dy. Health Officer,
Central Zone, MCD, Lajpat Nagar Road,
New Delhi
2. The Flying Saucer café (A unit of Priyank Sukhija Café Concept Private Limited),
Property Development Area, Lower Ground Floor,
TDI Mall, Nehru Palace Metro Station, New Delhi

Conditions for the validity of fire safety certificate:

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. The owner/ occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
5. This fire safety certificate may not in any way be treated as regularization of unauthorized construction, if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry."

INSPECTION REPORT

1. Name & address of the building: The Flying Saucer cafe, located at Property Development Area, Lower Ground Floor, TDI Mall, Nehru Palace Metro Station, New Delhi
2. Type of Occupancy : Group D Assembly Building (Eating House)[**Building is B+LG+ UG**]
3. Type of Case : Renewal[**Restaurant is running at Lower Ground Floor only**]
4. Details of Previous NOC : F6/DFS/MS/2013/EH/SZ/612 dated 24/07/2013
5. Fire Safety directives letter No : Nil
6. Date of inspection : 19/9/2016
7. Name of Inspecting Officer : A.K. Malik
8. Name and designation of officers
From the building side : Mr. M. C. Pathani
9. Year of Construction : 2009
10. Applicant's letter No. : Nil dated 05/07/2016[Outdoor diary no.8881 dated 05/09/2016]

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC/BBL Requirement	Provided at site	Remarks MR/NMR
1.	Access to building [TDI Mall FSC No. of F6/MS/DFS/SZ/2016/743 dated 10/05/16]			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	Restaurant within Mall	As Above	MR
2.	Number, Width, Type & Arrangement of Exits [Provided & Maintained by Mall management]			
	a. Number of staircases			
	<ul style="list-style-type: none"> • Upper Floors • Basements 	Restaurant within Mall	As Above	MR
		Restaurant within Mall	As Above	NA
	b. Width of staircases			
	<ul style="list-style-type: none"> • Upper Floor • Basement 	Restaurant within Mall	As Above	MR
		Restaurant within Mall	As Above	NA
	c. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	Restaurant within Mall	As Above	NA
		Restaurant within Mall	As Above	NA
	d. No. of continuous staircases to terrace	Restaurant within Mall	As Above	NA
	e. Width of Corridor	Restaurant within Mall	As Above	NA
	f. Door Size	Restaurant within Mall	As Above	NA
		2m	2m & 2m	MR
3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	Restaurant within Mall	As Above	NA
		Restaurant within Mall	As Above	NA
		Restaurant within Mall	As Above	NA
		Restaurant within Mall	As Above	NA
		Restaurant within Mall	As Above	NA
4.	Smoke Management System [Provided & Maintained by Mall management]			
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 ACPH	As Above	NA
		12 ACPH	As Above	MR
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	6 No's ISI marked	8 Nos	MR
			ABC-6No's	MR
			CO ₂ -2 No's	MR
6.	First-Aid Hose Reels [Provided & Maintained by Mall management]			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	One (Near to Restaurant)	As Above	MR
		30 m	As Above	MR
		5 mm	As Above	MR
7.	Automatic fire detection and alarming system [Provided & Maintained by Mall management]			
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel 	NA	As Above	NA
		NA	As Above	NA

6. Date of inspection :
 7. Name of Inspecting Officer : A.K. Malik
 8. Name and designation of officers
 From the building side : Mr. M. C. Pathani
 9. Year of Construction : 2009
 10. Applicant's letter No. : Nil dated 05/07/2016 [Outdoor diary no.8881 dated 05/09/2016]

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC/BBL Requirement	Provided at site	Remarks MR/NMR
1.	Access to building [TDI Mall FSC No. of F6/MS/DFS/SZ/2016/743 dated 10/05/16]			
	<ul style="list-style-type: none"> Road width Gate width Width of internal road 	Restaurant within Mall	As Above	MR
2.	Number, Width, Type & Arrangement of Exits [Provided & Maintained by Mall management]			
	a. Number of staircases	Restaurant within Mall	As Above	MR
	<ul style="list-style-type: none"> Upper Floors Basements 	Restaurant within Mall	As Above	NA
	b. Width of staircases	Restaurant within Mall	As Above	MR
	<ul style="list-style-type: none"> Upper Floor Basement 	Restaurant within Mall	As Above	NA
	c. Protection of exits	Restaurant within Mall	As Above	NA
	<ul style="list-style-type: none"> Fire check door Pressurization 	Restaurant within Mall	As Above	NA
	d. No. of continuous staircases to terrace	Restaurant within Mall	As Above	NA
	e. Width of Corridor	Restaurant within Mall	As Above	NA
	f. Door Size	2m	2m & 2m	MR
3.	Compartmentation			
	<ul style="list-style-type: none"> Fire check door Sealing of electrical shafts Fire Rating of shaft door Water Curtain Fire Dampers 	Restaurant within Mall	As Above	NA
		Restaurant within Mall	As Above	NA
		Restaurant within Mall	As Above	NA
		Restaurant within Mall	As Above	NA
		Restaurant within Mall	As Above	NA
4.	Smoke Management System [Provided & Maintained by Mall management]			
	<ul style="list-style-type: none"> Basements Upper floors 	30 ACPH	As Above	NA
		12 ACPH	As Above	MR
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	6 No's ISI marked	8 Nos	MR
			ABC-6No's	MR
			CO ₂ -2 No's	MR
6.	First-Aid Hose Reels [Provided & Maintained by Mall management]			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	One (Near to Restaurant) 30 m 5 mm	As Above	MR
			As Above	MR
			As Above	MR
7.	Automatic fire detection and alarming system [Provided & Maintained by Mall management]			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	NA NA NA NA NA	As Above	NA
			As Above	NA
			As Above	NA
			As Above	NA
			As Above	NA
8.	MOEFA	Required	Provided	MR
9.	Public Address System	NA	As Above	NA
10.	Automatic Sprinkler System [Provided & Maintained by Mall management]			
	<ul style="list-style-type: none"> Basement 	NA	As Above	NA

	<ul style="list-style-type: none"> • Ground Floor 	NA	As Above	NA
	<ul style="list-style-type: none"> • Sprinkler above false ceiling 	NA	As Above	NA
11.	Internal Hydrants [Provided & Maintained by Mall management]			
	<ul style="list-style-type: none"> • Size of riser/down-comer 	100mm	As Above	MR
	<ul style="list-style-type: none"> • Number of hydrants per floor 	One (near to Restaurant)	As Above	MR
	<ul style="list-style-type: none"> • Hose Box 	One (near to Restaurant)	As Above	MR
12.	Yard Hydrants [Provided & Maintained by Mall management]			
	<ul style="list-style-type: none"> • Total number of hydrants 	NA	NA	NA
	<ul style="list-style-type: none"> • Hose Box 	NA	NA	NA
13.	Pumping Arrangements [Provided & Maintained by Mall management]			
	<ul style="list-style-type: none"> • Ground Level <ul style="list-style-type: none"> ➤ Discharge of main Pump ➤ Head of Main pump ➤ Number of main pumps ➤ Jockey Pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/Manual Stopping ➤ Pump House Access • Terrace level <ul style="list-style-type: none"> ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		[Provided & Maintained by Mall management]		
		450 LPM	As Above	MR
		40 M	As Above	MR
		Required	As Above	MR
		Required	As Above	MR
14.	Captive Water Storage for firefighting [Provided & Maintained by Mall management]			
	<ul style="list-style-type: none"> • Underground tank capacity <ul style="list-style-type: none"> ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	NA	As Above	NA
		NA	As Above	NA
		NA	As Above	NA
		NA	As Above	NA
		10,000 Lts	As Above	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts. [Provided & Maintained by Mall management]			
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area. [Provided & Maintained by Mall management]			
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 	NA	NA	NA
		NA	NA	NA
19.	Fire Control Room [Provided & Maintained by Mall management]			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
20.	Special Fire Protection System for Protection of special Risks, if any:	NA	NA	NA

	• Hose Box	NA	NA	
13.	Pumping Arrangements [Provided & Maintained by Mall management]			
	• Ground Level			
	➤ Discharge of main Pump	NA	NA	NA
	➤ Head of Main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey Pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Starting/Manual Stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level	[Provided & Maintained by Mall management]		
	➤ Discharge of pump	450 LPM	As Above	MR
	➤ Head of the pump	40 M	As Above	MR
	➤ Power Supply	Required	As Above	MR
	➤ Auto Starting of pump	Required	As Above	MR
14.	Captive Water Storage for firefighting [Provided & Maintained by Mall management]			
	• Underground tank capacity	NA	As Above	NA
	➤ Draw-off connection	NA	As Above	NA
	➤ Fire service inlet	NA	As Above	NA
	➤ Access to tank	NA	As Above	NA
	• Overhead Tank capacity	10,000 Lts	As Above	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts. [Provided & Maintained by Mall management]			
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift lobby	NA	NA	NA
	• Communication In lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area. [Provided & Maintained by Mall management]			
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire Control Room [Provided & Maintained by Mall management]			
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Batter backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20.	Special Fire Protection System for Protection of special Risks, if any:	NA	NA	NA

The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules , It is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010.

N-5

The Flying Saucer cafe, located at Property Development Area, Lower Ground Floor, TDI Mall, Nehru Palace Metro Station, New Delhi

Accordingly FSC in shape of DFA is put up for approval.


Signature of Inspecting Officer

Name:- A.K. Malik

Designation:- DO (SZ)