

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI- 110001

NO. *F6/DFS/MS/School/2016/NDZ/1501* DATED: *13/10/16*

FIRE SAFETY CERTIFICATE

Certified that the M/s **Pushpanjali Modern Public School** at Main Road Tukmirpur Extn., Near Delhi Police Camp, Delhi-110094, comprised of ground plus two upper floors owned/occupied by Pushpanjali Modern Public School was granted NOC vide letter No.-F6/DFS/MS/School/2013/NDZ/894 dated-10/09/2013. The school building was re-inspected by the officer concerned of this department on 21/09/2016 in the presence of Mr. G.P. Sharma (Chairman) of the school and found that the school building have deemed complied with the fire prevention and fire safety requirements in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and that the building GF+FF+SF is fit for occupancy class B "Educational Building" with effect from ... *13/10/16* ... for a period of **three** years, subject to conditions printed overleaf.

Issued on ... *13/10/16* ... at New Delhi by

W
10/10
(Vipin Kertal)
Chief Fire Officer
Delhi Fire Service

o/c
W

To,
The Chairman
Pushpanjali Modern Public School,
Main Road Tukmirpur Extn.,
Near Delhi Police Camp,
Delhi-110094,

Copy to:-
The Dy. Director of Education,
North-East, B-Block,
Yamuna Vihar, Delhi-110053

- Conditions -

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.
7. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, six months prior to its expiry.

INSPECTION REPORT

1. Name & address of the building : M/s Pushpanjali Modern Public School,
Main Road Tukmirpur Extn., Near Delhi
Police Camp, Delhi -110094
2. Building is comprised of : Ground plus two upper floors.
3. Type of Occupancy : Educational
4. Type of Case : Renewal
5. Details of Previous NOC letter : F6//DFS/MS/School/2013/NDZ/894
Dated-10/9/13
6. Fire Safety direction letter No : NBC Part IV
7. Date of Inspection : 21/09/2016
8. Name of the Inspecting officers : ADO Vijay Bahadur Yadav
9. Name and designation of Officer:
from the building side : Mr. G.P. Sharma (Chairman)
10. Year of Construction : Ground floor in 2004, 1st floor & 2nd floor in
2012
11. Applicant's letter No : Letter No.- Nil, Dated-09/09/16

S.NO.	Minimum Standards on fire prevention and fire safety U/R33	Circular Requirement	Provided at Site	Remarks MR/NMR
1	Access to building			
	• Road width	06 mtr.	06 mtr.	✓ MR
	• Gate width	4.50 mtr.	06 mtr.	✓ MR
	• Width of internal road	N/A	N/A	N/A
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases	01 Nos.	01 Nos.	✓ MR
	• Upper Floor	01 Nos.	01 Nos.	✓ MR
	• Basement	N/A	N/A	N/A
	B. Width of Staircases	1.50 mtr.	1.50 mtr.	✓ MR
	• Upper Floor	1.50 mtr.	1.50 mtr.	✓ MR
	• Basement	N/A	N/A	N/A
	c. Protection of exits	N/A	N/A	N/A
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No. of continuous staircases to terrace	01 Nos.	01 Nos.	✓ MR
	e. Width of Corridor	1.60 mtr.	1.62 mtr.	✓ MR
	f. Door Size	1.0 Mtr.	1.10 mtr.	✓ MR
	i. No. of Doors in class room	02 Nos.	01 Nos.	✓ Acceptable as no of students less than 40
3	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A

4	Smoke Management System.	N/A	N/A	
	• Basement	N/A	N/A	
	• Upper floor	N/A	N/A	
5.	Fire Extinguishers	06 nos.	15 nos.	MR
	• Total numbers	ABC /CO ₂	ABC /CO ₂	MR
	• types	ISI marked	ISI marked	MR
	• IS marking			
6	First-aid-Hose Reels.	1 Nos.	1 Nos.	MR
	Total numbers on each floor	30 mtrs.	30 mtrs.	MR
	• Length of hose reel hose	5 mm	5mm	MR
	• Nozzle diameter			
7	Automatic fire detection and alarming system.			
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's location	N/A	N/A	N/A
8	MOEFA	N/A	N/A	N/A
9	Public address System.			
10	Automatic Sprinkler System.			
	• Basement	N/A	N/A	N/A
	• upper floor	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	Pumping Arrangements.			
	• Ground Level			
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main Pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby pump out put	N/A	N/A	N/A
	➤ Standby pump Head	N/A	N/A	N/A
	➤ Auto Starting /Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace Level			
	➤ Discharge of pump	450 LPM	450 LPM	MR
	➤ Head of the Pump	40 M	40 M	MR
	➤ Power supply	Required	Electricity	MR
	➤ Auto Starting of pump	Required	Provided	MR

14	Captive Water Storage for Fire Fighting.	Required	Provided	MR
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	Required	Provided	MR
	• Overhead Tank capacity	10,000 ltrs	10,000 ltrs	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A

	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested checked and found functional at the time of inspection.

Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rule 2010.

[Signature]
23/9/16

Signature of the Inspecting Officer

Name Vijay Bahadur

Designation ADD

~~DO (BD)~~

[Signature]
23/9

DCFO (NDZ)

[Signature]
26/9

C.F.P

Miscell

FT No.

[Signature]
27/9

FT FSC is put up for signature please.

CFO (NDZ)

Miscell

[Signature]
10/10/16

[Signature]
7/10/16

49/cfo/NDZ
27/9/16/10/X.