

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE  
NEW DELHI- 110001

NO.F6/DFS/MS/School/2016/SZ/ 1502

Dated: 13/10/16

FIRE SAFETY CERTIFICATE

Certified that the Bhartiya Public School, located at Ground floor & First floor of RZG-641, Raj Nagar-II, Palam Colony, New Delhi-110045, in a building comprised of ground plus three upper floors was granted NOC by this office vide letter no. F6/DFS/MS/School/2013/SZ/357 dated 24.5.2013 for **Ground & First floor**. The building was re-inspected by the officer concerned of this department on 07.9.2016 in presence Sh. Kapil Sharma(Manager) & found that the school building have deemed complied with the fire prevention and fire safety requirements in accordance with Circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by Directorate of Education, Govt. of NCT of Delhi, and that the building is fit for occupancy class B "Educational building" for **ground & first floor** with effect from 13/10/16... for a period of **three** years, in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010, printed overleaf.

Issued on .....13/10/16..... at New Delhi by

076  
6/10  
(Vipin Kental)  
Chief Fire Officer  
Su

Copy to:

1. Director (Education), Govt. of N C T of Delhi, Old Secretariat, New Delhi-110054.
2. Manager, Bhartiya Public School, RZG-641-642, Raj Nagar, Palam Colony, New Delhi-110045.

## CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
8. The owner / occupier shall apply for renewal of this **Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37)** along with copy of the certificate, six months prior to its expiry.


1	Name & address of the building	Bhartiyam Public School, RZG-641-642, Raj Nagar-II, Palam Colony, New Delhi-110045.		
2	Type of Occupancy	Educational Building "B"		
3	Type of case	Renewal		
4	Details of previous NOC	F6/DFS/MS/School/2013/357 dated 24.5.2013 ( For Ground & Fitst floor)		
5	Fire safety directives letter No	DOE Cir. No. 3298-3398 daed 1.03.2011		
6	Date of inspection	7.9.2016		
7	Name of the inspecting Officers :	ADO S.P. Bhardwaj		
8	Name and designation of officers from the building side	Sh. Kapil Sharma (Principal)		
9	Year of construction	2004-2005		
10	Applicant's letter No.	Nil Dated 19.8.2016	Building comprised of Ground plus three upper floor(School is running at ground & first floor)	
<b>S. NO.</b>	<b>Minimum Standards on fire prevention and fire safety U/R 33</b>	<b>NBC Requirement</b> <i>DOE circ No 17-105</i>	<b>Provided at site</b>	<b>Remarks</b> <b>MR / NMR</b>
<b>1</b>	<b>Access to building</b>			
	1) Road width	6 Mtrs.	6 Mtrs.	MR
	2) Gate width	4.5 Mtrs.	2.05 Mtrs. (Direct accessible from road)	MR
	3) Width of internal road	N/A	N/A	N/A
<b>2</b>	<b>Number, width Type &amp; arrangement of exits</b>			
	<b>a. Number of staircases</b>			
	1. Upper floors	Two	Two	MR
	2. basements	N/A	N/A	N/A
	<b>b. Width of staircase</b>			
	1. Upper floors	Old case	106, 107 Cms.	MR being old case
	2. basements	N/A	N/A	N/A
	<b>c. Protection of exits</b>			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	<b>d. No. of continuous staircase to terrace</b>	One	Two	MR
	<b>e. Width of corridor</b>	1.50 Mtrs.	153, 78 Cms.	MR being old case
	<b>f. Door size</b>	1 Mtr.	94x195 Cms.	MR being old case
<b>3</b>	<b>Compartmentation.</b>			
	1. Fire check door	N/A	N/A	N/A
	2. Sealing of electrical shafts	N/A	N/A	N/A
	3. Fire Rating of shaft door	N/A	N/A	N/A
	4. water curtain	N/A	N/A	N/A
	5. Fire dampers	N/A	N/A	N/A
<b>4</b>	<b>Smoke Management system.</b>			
	basement	N/A	N/A	N/A
	upper floors		N/A	N/A

11/11

5	<b>Fire Extinguishers</b>		
	total numbers	2 Nos. Each Floor	5 Nos
	Types	(Co2 OR ABC)	ABC
	ISI marking	ISI	ISI Marked
6	<b>First-Aid Hose Reels.</b>		
	total numbers on each floor	N/A	One
	Length of Hose reel hose	N/A	30 m
	Nozzle Diameter	N/A	5 mm
7	<b>Automatic fire detection and alarming system</b>		
	Type of detectors	N/A	N/A
	location of Main Panel	N/A	N/A
	location of Repeater panel	N/A	N/A
	Alternate source of power	N/A	N/A
	hooter's location	N/A	Near Office
8	<b>MOEFA</b>		
9	<b>Public Address System.</b>		
10	<b>Automatic Sprinkler System.</b>		
	basement	N/A	N/A
	upper floors	N/A	N/A
	sprinkler above false ceiling	N/A	N/A
11	<b>Internal Hydrants</b>		
	Size of riser/down-corner	N/A	N/A
	Number of Hydrants per floor	N/A	N/A
	hose Box	N/A	N/A
12	<b>Yard Hydrants.</b>		
	total number of hydrants	N/A	N/A
	hose box	N/A	N/A
13	<b>Pumping arrangements</b>		
	<b>1. Ground level</b>		
	a. Discharge of main Pump	N/A	N/A
	b. Head of main pump	N/A	N/A
	c. Number of main pumps	N/A	N/A
	d. jockey pump out put	N/A	N/A
	e. jockey pump head	N/A	N/A
	f. Standby Pump output	N/A	N/A
	g. Stanby Pump head	N/A	N/A
	h. Auto Starting/Manual stopping	N/A	N/A
	pump house access	N/A	N/A
	<b>2. Terrace level</b>		
	a. Discharge of pump	N/A	280 LPM
	b. head of the pump	30 Meter	30 Meter
	c. Power supply	Required	Provided
	d. Auto starting of pump	N/A	N/A
14	<b>Captive water storage for fire fighting</b>		
	1. Underground tank capacity	N/A	N/A
	a. Draw-off connection	N/A	N/A
	b. fire service inlet	N/A	N/A
	c. Access to tank	N/A	N/A
	Over head tank Capacity	N/A	5000 Ltrs.
15	<b>Exit Signage.</b>		
	Required	Provided	MR

16	<b>Provision of lifts.</b>			
	a. Pressurization of lift shaft	N/A	N/A	N/A
	b. pressurization of lift lobby	N/A	N/A	N/A
	c. communication in lift car	N/A	N/A	N/A
	d. Fireman's grounding switch	N/A	N/A	N/A
	e. Lift signage	N/A	N/A	N/A
17	<b>Standby power supply</b>	N/A	N/A	N/A
18	<b>Refuge Area.</b>	Not Required		
	total area			
	location			
19	<b>Fire control room</b>			
	a. detector system Panel	N/A	N/A	N/A
	b. Flow switch Panel	N/A	N/A	N/A
	c. PA system Panel	N/A	N/A	N/A
	d. Batter backup	N/A	N/A	N/A
	e. Building floor plans	N/A	N/A	N/A
20	<b>Special Fire Protection systems for protection of special risks, if any: ABC fire extinguisher near electric Meter.</b>			MR

Keeping In view deemed compliance of the minimum standards of fire prevention & fire safety requirements under the rules, renewal of Fire safety certificate issued vide letter no. F6/DFS/MS/School/2013/357 dated 24.5.2013 for **ground & first floor**, is recommended under rule 37 of the Delhi Fire Service Rules, 2010.

  
**Signature of the Inspecting Officer**  
 Name                      S.P. Bhardwaj  
 Designation              ADO (Dwarka)

~~DO/SW~~

What about 2nd & 3rd floor. Are they running my business/school?

~~ADO (Dwarka)~~

~~Key~~  
15/9/16

Sir, 2nd & 3rd floor are lying vacant.