

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F.6/DFS/MS/2016/School/1512

Dated: 14/10/2016

FIRE SAFETY CERTIFICATE

Certified that **M C D Primary Boys/Girls School, Naya Bans, Delhi-110082** comprised of **Ground floor only** owned/occupied by that **M C D Primary Boys/Girls School** was issued fire safety certificate **vide letter no. F.6/DFS/MS/2013/School/86 dated 18/03/2013.** The premises was re-inspected by the officer from this department on dated **21/09/2016** in the presence of **Sh. Chamra Kullu (Principal)** and observed that all the fire prevention & fire safety arrangements as provided in the premises found in good working condition. The premises have therefore deem complied with the requirements of **Circular No F.16/Estate/CC/Fire Safety/2011/3298-3398 dated 01/03/2011** issued by Director of Education and the building / premise is fit for occupancy of **Group Class B (Educational)** with effect from **14/10/2016** for a period of **three years**, subject to compliance of the conditions mentioned below:

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on **WWW.dfs.Delhigovt.nic.in**

Issued on 14/10/16 at New Delhi by


(Atul Garg)
Chief Fire Officer
Ph: 011-26189168
90.2

Copy to:

1. The Principal, M C D Primary Boys/Girls School, Naya Bans, Delhi-110082
2. The Addl. Director of Education, North MCD, Civic Centre New Delhi

INSPECTION REPORT

Single block
Ground floor only

1. Name & address of the building : M C D Primary Boys/Girls School, Naya Bans, Delhi-82
2. Type of Occupancy : Educational
3. Type of Case : Renewal
4. Details of previous NOC : Letter No F.6/DFS/MS/2013/School/86 dated 18/03/2013
Fire Safety directives letter No : Dir of Edu. Cir 01/03/2011
5. Date of inspection : 21/09/2016
6. Name of the Inspecting Officers : ADO (BW)
7. Name and designation of officers
from the building side : Sh. Chamra Kullu (Principal)
9. Year of Construction : 1960
10. Applicant's letter No. : Nil dated 22/08/2016

Plot Area: 23408 m2 Covered Area: 500 m2 No. of Students: NO. of Class Rooms: 05

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Dir. Of Edu. Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	6 mtr	6 mtr	MR
	• Gate width	4.50 mtr	3.60 mtr	MR being old case
	• Width of internal road	—	—	—
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	—	—	—
	• Upper Floors	—	—	—
	• Basements	—	—	—
	b. Width of staircases	—	—	—
	• Upper Floors	—	—	—
	• Basements	—	—	—
	c. Protection of exits	—	—	—
	• Fire check door	—	—	—
	• Pressurization	—	—	—
	e. No. of continuous staircases to terrace	—	—	—
	g. Width of Corridor	—	—	—
	h. Door Size	1.00 mtr	1.08 mtr	MR

Sh. Chamra Kullu

N-9

3	Compartmentation.	—	—	—
	• Fire check door	—	—	—
	• Sealing of electrical shafts	—	—	—
	• Fire Rating of shaft door	—	—	—
	• Water Curtain	—	—	—
	• Fire Dampers	—	—	—
4	Smoke Management System.			
	• Basements	30 a/c per hour	—	—
	• Upper floors	12 a/c per hour	—	—
5	Fire Extinguishers			
	• Total numbers	02 ABC	03	MR
	• Types	ISI marked	ABC	MR
	• IS marking		Yes	MR
6	First-Aid Hose Reels.			
	• Total numbers on each floor		—	—
	• Length of hose reel hose	30 m	—	—
	• Nozzle diameter	5 mm	—	—
7	Automatic fire detection and alarming system.			
	• Type of detectors	—	—	—
	• Location of Main Panel	—	—	—
	• Location of Repeater Panel	—	—	—
	• Alternate source of power	—	—	—
	• Hooters' Location	—	—	—
8	MOEFA	—	—	—
9	Public Address System.	—	—	—
10	Automatic Sprinkler System.			
	• Basement	—	—	—
	• Upper Floor	—	—	—
	• Sprinkler above false ceiling	—	—	—
11	Internal Hydrants			
	• Size of riser/down-comer	—	—	—
	• Number of hydrants per floor	—	—	—
	• Hose Box	—	—	—

Alshay

12	Yard Hydrants.		
	• Total number of hydrants	—	—
	• Hose Box	—	—
13	Pumping Arrangements.		
	• Ground Level	—	—
	➤ Discharge of main Pump	—	—
	➤ Head of Main pump	—	—
	➤ Number of main pumps	—	—
	➤ Jockey Pump out put	—	—
	➤ Jockey pump head	—	—
	➤ Standby Pump out put	—	—
	➤ Standby Pump Head	—	—
	➤ Auto Starting/ Manual stopping	—	—
	➤ Pump House Access	—	—
	• Terrace level	—	—
	➤ Discharge of pump	—	—
	➤ Head of the pump	—	—
	➤ Power Supply	—	—
	➤ Auto Starting of pump	—	—
14	Captive Water Storage for fire fighting.		
	• Underground tank capacity	—	—
	➤ Draw-off connection	—	—
	➤ Fire service inlet	—	—
	➤ Access to tank	—	—
	• Overhead Tank capacity	—	—
15	Exit Signage.		
	—	—	—
16	Provision of Lifts.		
	• Pressurization of Lift Shaft	—	—
	• Pressurization of Lift lobby	—	—
	• Communication In lift Car	—	—
	• Fireman's Grounding Switch	—	—
	• Lift Signage	—	—
17	Standby power supply		
	—	—	—

Signature

18	Refuge Area.			
	➤ Total Area	—	—	—
	➤ Location	—	—	—
19	Fire Control Room			
	• Detector System Panel	—	—	—
	• Flow Switch Panel	—	—	—
	• PA System Panel	—	—	—
	• Batter backup	—	—	—
	• Building Floor Plans	—	—	—
20	Special Fire Protection Systems for Protection of special Risks, if any:	—	—	—

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. F.6/DFS/MS/2013/School/86 dated 18/03/2016. Renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

Signature of the Inspecting Officer

Signature of the Inspecting Officer

Name

Name

Designation

Designation

(Signature)
S Singh
22.9.16

(Signature)
21/9/16
400(BW)

Dy CRO (WZ) out of station

~~CF- (WZ)~~
21/9/16 FT B