

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI- 110001

No. F6/DFS/MS/2016/M02/1509

Dated: 14/10/16

FIRE SAFETY CERTIFICATE

Certified that the Zaika Bazaar,6, Parmesh Complex-II, Karkardooma Community Centre, Delhi-92. owned/occupied by Narson Foods Pvt.Ltd, comprised of ground plus two upper floors was granted fire safety certificate vide letter no. F6/MS/DFS/EH/2013/NDZ/515 dt-05/07/13. The Premises was inspected by the officer concerned of this department on 02/08/16 & 14/09/16 in the presence of Mr.Raj Nath Bhat (Manager) and found that the assembly building have deemed complied with the fire prevention and fire safety requirements in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of condition under rule 38 and that the GF+FF of building is fit for occupancy Group D "Assembly Building" with effect from 14/10/16..... for a period of three years, subject to conditions printed overleaf.

Issued on 14/10/16..... at New Delhi by


(Vipin Kental)
Chief Fire Officer
Delhi Fire Service

To,

Mr.Raj Nath Bhat (Manager),
Zaika Bazaar,6, Parmesh Complex-II, Karkardooma,
Community Centre, Delhi-92

Copy to:-

The Deputy Health Officer,
Shahdara (South) Zone, EDMC,
Health Department, Shahdara South Zone, Karkardooma, Delhi

CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in good working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
5. This Fire Safety certificate can not be treated in any case for regularizations of unauthorized construction if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
7. "The owner /occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form'J'[sub rule(1) of rule 37] along with a copy of this certificate,six months prior to its expiry"

2. Building is comprised of : Ground + Two upper floor
 3. Type of Occupancy : Assembly
 4. Type of Case : Renewal
 5. Details of Previous FSC : F6/MS/DFS/EH/2013/NDZ/515 dt-05/07/13
 6. Fire Safety direction letter No : Old requirements Letter dt-24.12.04
 7. Date of Inspection : 02.08.2016 & 14/09/16
 8. Name of the Inspecting Officers: : DO S.K.Dua & ADO R.K. Yadav
 9. Name of the designation of Officer
 from the building side : Mr.Raj Nath Bhat (Manager)
 10. Year of Construction : 2002
 11. Applicant's letter No. : dated 20/07/2016

S. No	Minimum Standards on fire safety requirements as per	Requirement as per letter dt-24.12.04	Provided at Site	Remarks MR/NMR
1.	Access to building			
	Road width	N.A	30 m	Old accepted
	Gate width			
	Width of internal road	N.A	N.A	N.A
		N.A	N.A	N.A
2.	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	• Upper Floor	2 No.	3 No.	Old accepted
	• Basement	N.A	N.A	N.A
	b. Width of Staircases			
	• Upper Floor	N.A	1.1 m & .90 m, .70m	Old accepted
	• Basement	N.A	N.A	N.A
	c. Protection of exits			
	• Fire check door	N.A	N.A	N.A
	• Pressurization	N.A	N.A	N.A
	d. No. of continuous staircases to terrace	N.A	N.A	N.A
	e. Width of Corridor	N.A	N.A	N.A
	f. Door Size	N.A	G.F=1 M,.80 M 1 ST F =3 Nos .80 m each	Old accepted
3.	Compartmentation.			
	Fire check door	N.A	N.A	N.A
	Sealing of electrical shafts	N.A	N.A	N.A
	Fire rating of shaft door	N.A	N.A	N.A
	Water curtain	N.A	N.A	N.A
	Fire Dampers	N.A	N.A	N.A
4.	Smoke Management System.			
	Basement	N.A	N.A	N.A
	Upper floor	N.A	N.A	N.A
5.	Fire Extinguisher			
	Total numbers	4 Nos	4 Nos.	Old accepted
	Types	Co ₂ & ABC	Co ₂ & ABC	Old accepted
	ISI marking	ISI Marked	ISI Marked	Old accepted

6	First-aid-Hose Reels.			
	Total numbers of each floor	01 No.	01 No.at each floor no hosereel at 1 st floor	MR
	Length of hose reel hose	30 m	30 m	MR
	Nozzle diameter	5 mm	5 mm	MR
7	Automatic fire detection and alarming system.			
	Type of detectors	N.A	N.A	N.A
	Location of main panel	N.A	N.A	N.A
	Location of repeater panel	N.A	N.A	N.A
	Alternate source of power	N.A	N.A	N.A
	Hooters	N.A	N.A.	N.A.
8	MOEFA	Required	Provided	Old accepted
9	Public address System.	N.A	N.A	N.A
10	Automatic Sprinkler System.			
	basement	N.A	N.A	N.A
	upper floor	N.A	N.A	N.A
	sprinkler above false ceiling	N.A	N.A	N.A
11	Internal Hydrants			
	size of riser/down-comer	N.A	100MM	Old accepted
	Number of hydrants per floor	N.A	1 No.	Old accepted
	Hose Box	N.A	1 No.	Old accepted
12	Yard Hydrants.			
	Total number of hydrants	N.A	N.A	N.A
	Hose Box	N.A	N.A	N.A
13	Pumping Arrangements.			
	• Ground Level	N.A	N.A	N.A
	➤ Discharge of main Pump	N.A	N.A	N.A
	➤ Head of Main Pump	N.A	N.A	N.A
	➤ Number of main pumps	N.A	N.A	N.A
	➤ Jockey pump out put	N.A	N.A	N.A
	➤ Jockey pump head	N.A	N.A	N.A
	➤ Standby pump out put	N.A	N.A	N.A
	➤ Standby pump Head	N.A	N.A	N.A
	➤ Auto Starting /Manual stopping	N.A	N.A	N.A
	➤ Pump House Access	N.A	N.A	N.A
	• Terrace Level			
	➤ Discharge of pump	450 LPM	Provided but not functional	MR
	➤ Head of the Pump	N.A	40 m	Old accepted
	➤ Power supply	N.A	N.A	N.A
	➤ Auto Starting of pump	N.A	N.A	N.A
14	Captive Water Storage for Fire Fighting.			
	Underground tank capacity	N.A	N.A	N.A
	Draw-off connection	N.A	N.A	N.A
	Fire service inlet	N.A	N.A	N.A
	Access to tank	N.A	N.A	N.A
	Overhead Tank capacity	5000Ltrs	5000Ltrs	MR
15	Exit Signage.	N.A	provided	Old accepted

N/17

16	Provision of Lifts.			
	Pressurization of Lift Shaft	N.A	N.A	N.A
	Pressurization of Lift lobby	N.A	N.A	N.A
	Communication in lift car	N.A	N.A	N.A
	Firemen's grounding switch	N.A	N.A	N.A
	Lift Signage	N.A	N.A	N.A
17	Standby power supply	N.A	N.A	N.A
18	Refuge Area.			
	Total area	N.A	N.A	N.A
	Location	N.A	N.A	N.A
19	Fire Control Room			
	Detector system panel	N.A	N.A	N.A
	Flow switch panel	N.A	N.A	N.A
	PA system panel	N.A	N.A	N.A
	Batter backup	N.A	N.A	N.A
	Building Floor Plans	N.A	N.A	N.A
20	Special Fire Protection systems for protection of special Risks, if any:	N.A	N.A	N.A

The fire protection systems provided in the building were tested checked and found functional at the time of inspection.

Keeping in view the compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to renew Fire Safety Certificate under rule 35 of the Delhi Fire Service Rule 2010.

R. K. Yadav
27/9/2016

Signature of the Inspecting Officer
Name:- R. K. Yadav
Designation:- ADO (LN)

Submitted pl
DO (ED)

ling
27/9

DFO (ND2)
3/10

54/cfo/ND2
6/16/19/x

FT/10.

C.F.O. m.scell *U*
5/10.

Say FT letter is put up for signature pl.

R. K. Yadav
10/10/2016

CFO (ND2) m.scell *U*
10/10.