

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI- 110001

NO. F6/DFS/MS/EH/2016/SZ/ 1517

Dated: 17/10/16

FIRE SAFETY CERTIFICATE

Certified that the Hi Mircheee Restaurant at Plot No. 1, Manish Plaza, 3rd floor, Sector-12, Ashirwad Chowk, Dwarka, New Delhi-110075 is running at 3rd floor of the building comprised of ground plus three upper floors was granted NOC by this department vide letter no. F6/DFS/MS/EH/2013/SZ/932 Dated 19.09.2013. The premises was re-inspected by the officer concerned of this department on 05.10.2016 in the presence of Sh. Bijay Parkash Tiwari (Manager) of the restaurant and found that the building is fit for occupancy class D "Assembly building ( Restaurant)" with effect from 17/10/16... for a period of **three** years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010, printed overleaf.

Issued on 17/10/16..... at New Delhi by

17/10/16  
(Vipin Kental)  
Chief Fire Officer  
OC

Copy To:-

1. DHO/West Zone, Deputy Health Officer, Municipal Corporation of Delhi, Najafgarh Zone New Delhi.
2. The Authorized Signatory, Hi Mircheee Restaurant at Plot No. 1, Manish Plaza, 3rd floor, Sector-12, Ashirwad Chowk, Dwarka, New Delhi-110075.

## CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
8. The owner / occupier shall apply for renewal of this **Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37)** along with copy of the certificate, six months prior to its expiry.

## INSPECTION REPORT


1	Name & address of the building	M/S Hi Mircheee Restaurant at Plot No. 1, Manish Plaza, 3rd floor, Sector-12, Ashirwad Chowk, Dwarka, New Delhi-110075		
2	Type of Occupancy	Assembly "D" Restaurant		
3	Type of case	Renewal		
4	Details of previous NOC	No. F-6/DFS/MS/EH/2013/SZ/932 dated 19.09.2013		
5	Fire safety directives letter No	Old Case		
6	Date of inspection	5.10.2016		
7	Name of the inspecting Officers :	ADO S.P Bhardwaj (Dwarka)		
8	Name and designation of officers from the building side	Sh. Bijay Parkash Tiwari (Manager)		
9	Year of construction	before 2005	<b>Restaurant Runinig at 3rd Floor</b>	
10	Applicant's letter No.	Nil Dated 17.08.2016	<b>Building: Ground + 3 upper Floors</b>	
<b>S. NO.</b>	<b>Minimum Standards on fire prevention and fire safety U/R 33</b>	<b>Old Case /NBC Requirement</b>	<b>Provided at site</b>	<b>Remarks MR / NMR</b>
<b>1</b>	<b>Access to building</b>			
	1) Road width	10mtrs	20 Mtrs.	MR
	2) Gate width	N/A	N/A	N/A
	3) Width of internal road	N/A	N/A	N/A
<b>2</b>	<b>Number, width Type &amp; arrangement of exits</b>			
	<b>a. Number of staircases</b>			
	1. Upper floors	Old case	One	MR
	2. basements	N/A	N/A	N/A
	<b>b. Width of staircase</b>			
	1. Upper floors	Old Case	1.20 Mtrs.	MR
	2. basements	N/A	N/A	N/A
	<b>c. Protection of exits</b>			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	<b>d. No. of continuous staircase to terrace</b>	Requied	One	MR
	<b>e. Width of corridor</b>	N/A	N/A	N/A
	<b>f. Door size</b>	Old case ( Two )	1.50 , 1.40 Mtrs.	MR
<b>3</b>	<b>Compartmentation.</b>			
	1. Fire check door	N/A	N/A	N/A
	2. Sealing of electrical shafts	N/A	N/A	N/A
	3. Fire Rating of shaft door	N/A	N/A	N/A
	4. water curtain	N/A	N/A	N/A
	5. Fire dampers	N/A	N/A	N/A
<b>4</b>	<b>Smoke Management system.</b>			
	basement	30 a/c per hour 12 a/c per hour	N/A	N/A
			Exhaust Fans provided	MR



	<b>Fire Extinguishers</b>	3	6 Nos	MR
	total numbers			
	Types			
	ISI marking	ISI	ABC, Co2, Yes	MR MR
6	<b>First-Aid Hose Reels.</b>			MR
	total numbers on each floor	1 No.	One	MR
	Length of Hose reel hose	30 m	30 m	MR
	Nozzle Diameter	5 mm	5 mm	MR
7	<b>Automatic fire detection and alarming system</b>			MR
	Type of detectors	N/A	N/A	N/A
	location of Main Panel	N/A	N/A	N/A
	location of Repeater panel	N/A	N/A	N/A
	Alternate source of power	N/A	N/A	N/A
	hooter's location	N/A	N/A	MR
8	<b>MOEFA</b>	Required	N/A	MR
9	<b>Public Address System.</b>	N/A	Provided	MR
10	<b>Automatic Sprinkler System.</b>		N/A	N/A
	basement	N/A	N/A	N/A
	upper floors	Required	Provided in Restaurant	MR
	sprinkler above false ceiling	N/A	N/A	N/A
11	<b>Internal Hydrants</b>			N/A
	Size of riser/down-corner	100 MM	100 MM	MR
	Number of Hydrants per floor	One	One	MR
	hose Box	Required	Provided	MR
12	<b>Yard Hydrants.</b>			MR
	total number of hydrants	N/A	N/A	N/A
	hose box	N/A	N/A	N/A
13	<b>Pumping arrangements</b>			N/A
	<b>1. Ground level/</b>			
	a. Discharge of main Pump	N/A	N/A	N/A
	b. Head of main pump	N/A	N/A	N/A
	c. Number of main pumps	N/A	N/A	N/A
	d. jockey pump out put	N/A	N/A	N/A
	e. jockey pump head	N/A	N/A	N/A
	f. Standby Pump output	N/A	N/A	N/A
	g. Stanby Pump head	N/A	N/A	N/A
	h. Auto Starting/Manual stopping	N/A	N/A	N/A
	pump house access	N/A	N/A	N/A
	<b>2. Terrace level</b>			
	a. Discharge of pump	450,180 LPM	450 LPM,180 LPM	MR
	b. head of the pump	35 Mtrs.	35 Mtrs.	MR
	c. Power supply	Required	Provided	MR
	d. Auto starting of pump	Required	Provided	MR
14	<b>Captive water storage for fire fighting</b>			
	1. Underground tank capacity	N/A	N/A	N/A
	a. Draw-off connection	N/A	N/A	N/A
	b. fire service inlet	N/A	N/A	N/A
	c. Access to tank	N/A	N/A	N/A
	Over head tank Capacity	Old Case	16,000 Ltrs.	MR
15	<b>Exit Signage.</b>	Required	Provided	MR
16	<b>Provision of lifts.</b>			
	a. Pressurization of lift shaft	N/A	N/A	N/A
	b. pressurization of lift lobby	N/A	N/A	N/A
	c. communication in lift car	N/A	N/A	N/A
	d. Fireman's grounding switch	N/A	N/A	N/A
	e. Lift signage	N/A	N/A	N/A

20115

17	Standby power supply	Required	Provided	MR
18	Refuge Area.	Not Required		
	total area			
	location			
19	Fire control room			
	a. detector system Panel	N/A	N/A	N/A
	b. Flow switch Panel	N/A	N/A	N/A
	c. PA system Panel	N/A	N/A	N/A
	d. Batter backup	N/A	N/A	N/A
	e. Building floor plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special risks, if any: N/A			


The fire protection systems provided in the building were checked and found functional at the time of inspection. Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety required under the rule, renewal of Fire Safety Certificate issued vide letter no.F6/ DFS/MS/EH/2013/SZ/932 dated 19.9.2013 is recommended under rules 37 of the Delhi Fire Service Rules 2010. Accordingly DFA is put up for approval and signature please.

  
 Signature of the Inspecting Officer  
 Name S.P Bhardwaj  
 Designation ADO (DWARKA)

  
 5/10/2016


DCFP (SZ)



  
 bhp

 cfo  


322/cfo s2  
 10/21/6/17/x.

Mr. S. Chauhan  
 FTM  
 7/10