

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001**

No F 6/DFS/MS/School/2016/ W2/1526

Dated 18/10/16

**FIRE SAFETY CERTIFICATE**

Certified that the Govt. Sarvodaya Bal Vidyalaya (School code-1617254) at Peeragarhi, Village, Delhi – 110087, comprised of 3 blocks of Ground + One upper floor only owned/occupied by Govt. Sarvodaya Bal Vidyalaya, have complied with the fire prevention and fire safety requirements in accordance with Director of Education Circular No. F6/Estate/CC/Fire/Safety/2011/3298-3398 dated 01/03/2011 and verified by the officer concerned of Fire Service on 28/09/2016 in presence of Sh. Prem Dutt Sharma (Vice- Principal) and that the building/premises is fit for occupancy class education (Group-B) with effect from 18/10/16..... for a period of 3 (Three) years subject to conditions printed below.

Issued on 18/10/16 at New Delhi by.

  
(Atul Garg)

Chief Fire Officer

Ph:- 011-23414250

Copy to:-

1. Vice-Principal, Govt. Sarvodaya Bal Vidyalaya (School code-1617254), Peeragarhi, Village, delhi-1110087.

**Conditions for the Validity of Fire Safety Certificate:-**

1. All fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc. shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
7. The owner/occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.Delhigovt.nic.in](http://www.dfs.Delhigovt.nic.in).

2. Type of Occupancy : Educational
3. Type of Case : New (3 Blocks of G+1)
4. Details of previous NOC : Nil
5. Fire Safety directives Letter No. : DOE Circular dated 01.03.2011
6. Date of inspection : 28/09/2016
7. Name of the Inspecting Officer : A. K. Jaiswal
8. Name and designation of Officer from the building side : Mr. Prem Dutt Sharma (Vice Principal)
9. Year of Construction : --- 2014
10. Applicant's letter No. : SBV/PGV/2016/134 Dated 09/09/2016

S No	Minimum standards on fire prevention and fire safety U/R 33	NBC Part-IV Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	Accessible	Provided	MR
	• Gate width	Accessible	Provided	MR
	• Width of internal road	N/A	N/A	N/A
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	1	4	MR
	• Basements	No basement	N/A	N/A
	b. Width of staircases			
	• Upper floors	1.50 Mtr.	A) Main Block -2x1.30, B) Lab. Block -1x 1.50, C) Junior Block- 1x1.50	MR (These blocks are separate and not interconnected)
	• Basements	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No of continuous staircase to terrace	1	1	MR
	e. Width Of Corridor	1.50 Mtr.	1.50 Mtr.	MR
	f. Door Size	1.00 Mtr.	1.00 Mtr.	MR
3.	Compartmentation			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers			
4.	Smoke managements System			
	• Basements	N/A	N/A	N/A
	• Upper floors	N/A	N/A	N/A
5.	Fire Extinguishers			
	• Total numbers	10	13	M/R
	• Types	ISI marked ABC/CO-	Provided	M/R

	each floor			
	• Length of hose reel hose	N/A	N/A	N/A
	• Nozzle diameter	N/A	N/A	N/A

7. Automatic fire detection and alarming system

	• Type of detector	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooters' Location	N/A	N/A	N/A

8. MOEFA

		N/A	N/A	N/A
--	--	-----	-----	-----

9. Public Address System

		N/A	N/A	N/A
--	--	-----	-----	-----

10. Automatic Sprinkler System

	• Basements	N/A	N/A	N/A
	• Upper Floor	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A

11. Internal Hydrants

	• Size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A

12. Yard Hydrants

	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A

13. Pumping Arrangements

	• Ground Level	N/A		
	• Discharge of main pump	N/A	N/A	
	➤ Head of main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Starting/Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace level			
	➤ Discharge of pump	N/A	N/A	N/A
	➤ Head of the pump	N/A	N/A	N/A
	➤ Power supply	N/A	N/A	N/A
	➤ Auto starting of pump	N/A	N/A	N/A

14. Captive water Storage for fire fighting

	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw of connection	N/A	N/A	N/A

15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	N/A	N/A	N/A
	➤ Pressurization of lift lobby	N/A	N/A	N/A
	➤ Communication in lift Car	N/A	N/A	N/A
	➤ Fireman's Grounding Switch	N/A	N/A	N/A
	➤ Lift Signage	N/A	N/A	N/A
17.	Standby power supply	N/A	N/A	N/A
18.	Refuge Area	N/A	N/A	
	➤ Total area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19.	Fire control room			
	➤ Detector system panel	N/A	N/A	N/A
	➤ Flow Switch Panel	N/A	N/A	N/A
	➤ PA System Panel	N/A	N/A	N/A
	➤ Battery backup	N/A	N/A	N/A
	➤ Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection Systems for Protection of special Risks, if any;	N/A	N/A	N/A

Note:-General requirements for schools as per Director of Education circular dated 01/03/2011.

1. Escape route .....:- **Clear**
2. LPG cylinders in laboratories :- **Nil**
3. Electric wiring .....:- **Conduit Wiring** MCB and ELCB.....  
Electric circuit .....:- **MCB Provided**
4. Electric meter board .....:- **Not under staircase**
5. Basement use as per BBL 1983 :- **N/A**
6. Emergency telephone no. board :- **Displayed**
7. Generator set ..... :- **NA**

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Keeping in view of the substantial compliance of the minimum standards of fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

*Ashok Kumar Jaiswal*  
28/9/16

Signature of the Inspecting Officer

Name : Ashok Kumar Jaiswal

Designation : A.D.O. (Jwala Puri)

*S/O (W)*  
*4/11/16*  
*17/11/16*