

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

No. F6/DFS/MS/2016/SZ/ 1542

Dated: 19/10/16

FIRE SAFETY CERTIFICATE

Certified that the **Anand Niketan Club and Multipurpose Hall** located at Anand Niketan, New Delhi-110021, comprised of Basement, Ground plus One upper floor was granted FSC by this department vide letter No. F6/DFS/MS/2013/SZ/116 dated 01.11.2013. the premises was re-inspected by the officer concerned of this department on 16.09.2016 in the presence of Mr. Satender Kumar Sharma and found that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class **Group-D Assembly Building** with effect from 19/10/16 for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 19/10/16 at New Delhi by

VK
10/10
Vipin Kental
Chief Fire Officer
Ph.: 011-23412225
ki

Copy to: -

1. Anand Niketan Club and Multipurpose Hall,
Anand Niketan, New Delhi-110021

Conditions for the validity of Fire Safety Certificate

1. All the fire safety and means of escape facilities shall be maintained in good working condition at all time. Any lapse rendering the fire safety or means of evacuation facilities non-functional shall be the responsibility of the management.
2. Building Sanctioning authority may verify any deviation with regard to construction/occupancy in the building. In case of any deviation, the fire safety certificate stands null & void.
3. The staff shall be trained for operating fire fighting system and mock evacuation drill be conducted at regular interval and record be maintained.
4. The basement shall be used strictly as per the provisions of Building Bye Laws.
5. The Owner/Occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules, 2010. The form is available on www.dfs.delhigovt.nic.in.
6. The water capacity of 50,000 Ltr shall always remain available in the swimming pool for firefighting purpose all the time.
7. The Owner/Occupier shall apply for renewal of this Fire Safety Certificate to the Director in the form 'J' [sub rule (1) of rule 37] along with copy of this certificate, six months prior to its expiry. The form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1	Name & Address of the Building	Anand Niketan Club and Multipurpose Hall located at Anand Niketan, New Delhi-110021		
2	Type of Occupancy	Assembly Building "Group-D"		
3	Building Comprised of	Basements, Ground plus one upper floor.		
4	Type of Case	Renewal		
5	Details of Previous NOC	F6/DFS/MS/2013/SZ/1166 dated 01/11/2013		
6	Fire Safety Directives Letter No	F.6/DFS/MS/BP/2001/272 dated 14/02/2001		
7	Date of Inspection	16.09.2016		
8	Name of the Inspecting Officers	ADO R.N. Singh		
9	Name & Designation of Officers from the building side	Mr. Satender Kumar Sharma.		
10	Year of construction	2004		
11	Applicant letter No.	ANC/182 dated 22/08/2016		
S. No	Minimum standards on Fire Prevention and Fire Safety U/R 33	NBC / BBL Requirements	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	1. Road width	9 Mts.	9 Mts.	MR
	2. Gate width	5 Mts.	5 Mts.	MR
	3. Width of internal road	NA	NA	NA
2	Number, width, type and arrangements of exits.			
	a. Number of Staircase			
	1. Upper floors	3 Nos.	3 Nos.	MR
	2. Basement floor	2 Nos.	2 Nos.	MR
	b. Width of Staircase			
	1. Upper floors	1.50 Mts.	1.5 m, 1.20 m & 1.20 m	MR (old case)
	2. Basement floor	1.50 Mts.	1.50 m & 1.20 m	MR (old case)
	c. Protection of exits			
	1. Fire check door	Required	Provided	MR
	2. Pressurization	NA	NA	NA
	d. No. of continuous staircase to terrace	1 Nos.	1 Nos.	MR
	e. Width of corridor	NA	NA	NA
	f. Door size	1 m	2.15 m Final exit	MR
3	Compartmentation.			
	1. Fire check door.	Required	Provided	MR
	2. Sealing of electrical shafts.	NA	NA	NA
	3. Fire rating of shaft door.	NA	NA	NA
	4. Water curtain	NA	NA	NA
	5. Fire dampers.	Yes	Provided	MR
4.	Smoke Management system.			
	1. Basement	30 a/c per hour	Exhaust fan provided	MR
	2. Upper floors	12 a/c per hour	Exhaust fan provided	MR
5.	Fire Extinguishers.			
	1. Total numbers		31 Nos.	MR
	2. Types	ISI Marked	Co2-14, ABC- 10, WC-3, DCP-2, Foam-2	MR
	3. ISI Marking		Provided	MR
6.	First Aid Hose Reels.			
	1. Total numbers on each floor.	2 Nos.	Provided	MR
	2. Length of hose-reel hose.	30 Mts.	Provided	MR
	3. Nozzle Diameter	5 mm	Provided	MR

7	Automatic Fire Detection and Alarming system.			
	1. Type of detectors	Smoke & Heat	Smoke.	MR
	2. Location of Main Panel	Required	Ground floor	MR
	3. Location of Repeater Panel	NA	NA	NA
	4. Alternate source of power	Required	Provided.	MR
	5. Hooter's location	Required	Each floor	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	1. Basement	Required	Provided	MR
	2. Upper floors	NA	NA	NA
	3. Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants.			
	1. Size of Riser / Down-comer	100 mm	100 mm	MR
	2. Number of Hydrant per floor	2 Nos.	2 Nos.	MR
	3. Hose box.	2 Nos.	2 Nos.	MR
12.	Yard Hydrants.			
	1. Total number of hydrants.	3 Nos.	3 Nos.	MR
	2. Hose box.	3 Nos.	3 Nos.	MR
13.	Pumping arrangements.			
	1. Ground Level			
	a) Discharge of main pump.	1620 LPM	1620 LPM	NMR
	b) Head of main pump.	56 Mtr.	56 Mtr.	MR
	c) Number of main pumps.	1 No	1 No	MR
	d) Jockey Pump output.	180 LPM	180 LPM	MR
	e) Jockey Pump head.	56 Mtr	56 Mtr	MR
	f) Standby Pump output.	1620 LPM	1620 LPM	MR
	g) Standby Pump head.	56 Mtr.	56 Mtr.	MR
	h) Auto Starting / Manual Stopping.	Required	Provided	MR
	2. Terrace Level			
	a) Discharge of pump.	NA	NA	NA
	b) Head of pump.	NA	NA	NA
	c) Power supply.	NA	NA	NA
	d) Auto starting of pump.	NA	NA	NA
14.	Captive water storage for Fire Fighting.			
	1. Underground tank capacity.	50000 Ltr.	50000 Ltr. (Swimming Pool)	MR
	2. Draw-off connection.	NA	NA	NA
	3. Fire Service Inlet.	Required	Provided	MR
	4. Access to tank.	Required	Provided	MR
	5. Overhead tank capacity.	20000 Ltr.	20000 Ltr.	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	1. Pressurization of lift shaft.	NA	NA	NA
	2. Pressurization of lift lobby.	NA	NA	NA
	3. Communication in lift car.	NA	NA	NA
	4. Fireman's switch.	Required	Provided	MR
	5. Lift signage.	Required	Provided	MR
17	Standby Power Supply	Required	Provided	MR
18.	Refuge Area			
	1. Total area	NA	NA	NA
	2. Location	NA	NA	NA

N/18

19.	Fire Control Room.			
	1. Detector System Panel.	NA	NA	NA
	2. Flow Switch Panel.	NA	NA	NA
	3. PA system Panel.	NA	NA	NA
	4. Battery backup	NA	NA	NA
	5. Building floor plan	NA	NA	NA
20.	Special Fire Protection System for the Protection of special Risk, if any :	NA	NA	NA

The fire protection system provided in the building were checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter No. F6/DFS/MS/2013/SZ/1166 dated 01.11.2013, renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended

Accordingly, DFA is put up for approval and signature please.

R.N. Singh
19/9/16

Signature of the Inspecting Officer
Name : R.N. Singh
Designation: ADO

Case: Renewal

Page-3

Anand Niketan Club & Multipurpose Hall

Div. Officer (SD)

R. N. Singh
26/9/16

dy. (PO/S2)

Kant
27/9



RTI.

CFO/S2

M. S. Chauhan

28/9

288/cfo 32
29/9/16/10/x