

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/2016/ *School/w2/1553*

Dated: *21/10/16*

FIRE SAFETY CERTIFICATE

Certified that the **Maharaja Agarsain Public School** Located at **Ashok Vihar Phase-IV, Delhi – 110052** comprised of Basement + Ground + 3 Upper Floor, was issued FSC vide Letter No. F6/DFS/MS/2012/2282 Dated 26-06-2012. The premises was re inspected by the officer concerned of this department on 23-09-2016 in the presence of Sh. Poonam Gupta (Principal) and observed that premises now comprises of Ground+ three upper floors. All the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deem complied with the fire prevention and fire safety requirements in accordance NBC/BBL1983 and that the premises is fit for occupancy class "Educational" Group B with effect from *21/10/16* for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on *21/10/16*..... at New Delhi by,

[Signature]
21/10/16

(Atul Garg)
Chief Fire Officer
Delhi Fire Service

Copy to:

OK
[Signature]

1) The Principal, **Maharaja Agarsain Public School ,Ashok Vihar Phase-IV, Delhi – 110052.**

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. All the exits including staircases shall be maintained free from any obstruction.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1. Name & address of the building: **Maharaja Agarsain Public School** Located at **Ashok Vihar Phase-IV, Delhi – 110052.**
2. Type of Occupancy : Educational (Basement + Ground + 3 Upper Floor)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/SCHOOL/2012/2282 Dated- 26/06/2012.
5. Fire Safety directives Letter No. : F6/DFS/MS/BP/2004/431 Dated 23/02/2004
6. Date of inspection : 23/09/2016
7. Name of the Inspecting Officer : ADO (WP)
8. Name and designation of Officer
from the building side : Ms. Punam Gupta (Principal)
9. Year of Construction : 1978
10. Applicant's letter No. : Letter no.Nil Dated- 29-08-2016

No. of Students=3500
 No. of class rooms=94
 Plot area=16187sq.mt.
 Covered area= 8094 sq mt.

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL Requirement	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	06 mtrs	09 mtr	MR
	• Gate width	4.5 mtrs	410 mtr	MR
	• Width of internal road	Required	03 mtrs	MR
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	04	04 Provided	MR
	• Basements	03	04 Provided	MR
	b. Width of staircases			
	• Upper floors	1.5mtr	2x1.5m & 2x1.6m	MR
	• Basements	Three 1.5 mtr	2x1.5 m 2x1.3 1m	MR(Being old case)
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	02	Provided	MR
	e. Width Of Corridor	2 mtrs.	2.10 m	MR
	f. Door Size	1mtr	1 mtr	MR

3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door 	NA	NA	NA
	<ul style="list-style-type: none"> • Sealing of electrical shafts 	NA	NA	NA
	<ul style="list-style-type: none"> • Fire Rating of shaft door 	NA	NA	NA
	<ul style="list-style-type: none"> • Water Curtain 	NA	NA	NA
	<ul style="list-style-type: none"> • Fire Dampers 	NA	NA	NA
4.	Smoke managements System			
	<ul style="list-style-type: none"> • Basements 	Exhaust Fans	Provided	MR
	<ul style="list-style-type: none"> • Upper floors 	NA	NA	NA
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers 	27 nos.	35 Provided	MR
	<ul style="list-style-type: none"> • Types 	ABC & CO ₂	Provided	MR
	<ul style="list-style-type: none"> • IS marking 	ISI marked	Provided	MR
6.	First – Aid Hose Reels			
	<ul style="list-style-type: none"> • Total numbers on each floor 	05	Provided	MR
	<ul style="list-style-type: none"> • Length of hose reel hose 	30m	Provided	MR
	<ul style="list-style-type: none"> • Nozzle diameter 	5mm	Provided	MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> • Type of detectors 	NA	NA	NA
	<ul style="list-style-type: none"> • Location of Main Panel 	NA	NA	NA
	<ul style="list-style-type: none"> • Location of Repeater Panel 	NA	NA	NA
	<ul style="list-style-type: none"> • Alternate source of power 	NA	NA	NA
	<ul style="list-style-type: none"> • Hooters' Location 	NA	NA	NA
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> • Basements 	Required	Provided	MR
	<ul style="list-style-type: none"> • Upper Floor 	NA	NA	NA
	<ul style="list-style-type: none"> • Sprinkler above false ceiling 	NA	NA	NA
11.	Internal Hydrants:			
	<ul style="list-style-type: none"> • Size of riser/down-comer 	NA	NA	NA
	<ul style="list-style-type: none"> • Number of hydrants per floor 	NA	NA	NA
	<ul style="list-style-type: none"> • Hose Box 	NA	NA	NA

12.	Yard Hydrants			
	<ul style="list-style-type: none"> • Total number of hydrants 	NA	Provided	MR
	<ul style="list-style-type: none"> • Hose Box 	NA	Provided	MR
13.	Pumping Arrangements:			
	<ul style="list-style-type: none"> • Ground Level 			
	<ul style="list-style-type: none"> • Discharge of main pump 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Head of main pump 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Number of main pumps 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Jockey pump out put 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Jockey pump head 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Standby Pump out put 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Standby Pump Head 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Auto Starting/Manual stopping 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Pump House Access 	NA	NA	NA
	<ul style="list-style-type: none"> • Terrace level 			
	<ul style="list-style-type: none"> ➤ Discharge of pump 	900 LPM	Provided	MR
	<ul style="list-style-type: none"> ➤ Head of the pump 	40Mtr	Provided	MR
	<ul style="list-style-type: none"> ➤ Power supply 	Required	NA	MR
	<ul style="list-style-type: none"> ➤ Auto starting of pump 	NA	Provided	MR
14.	Captive water Storage for fire fighting:			
	<ul style="list-style-type: none"> • Under ground tank capacity 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Draw off connection 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Fire service inlet 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Access to tank 	NA	NA	NA
	<ul style="list-style-type: none"> • Overhead Tank capacity 	15,000Ltr	Provided	MR
15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	<ul style="list-style-type: none"> ➤ Pressurization of Lift Shaft 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Pressurization of lift lobby 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Communication in lift Car 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Fireman's Grounding Switch 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Lift Signage 	NA	NA	NA
17.	Standby power supply			
18.	Refuge Area			
	<ul style="list-style-type: none"> ➤ Total area 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Location 	NA	NA	NA

19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

Note:-General requirements for schools as per Director of Education circular dated 01/03/2011.

1. Escape routeClear.....
2. LPG cylinders in laboratories ; NA
3. Electric wiring ...canceled Wiring..... MCB and ELCB
.....
Electric circuit
4. Electric meter boardNot under the staircase.....
5. Basement use as per BBL 1983 ... Under taking submitted by school authority
6. Emergency telephone no. boardDisplayed...
7. Generator set Provided out side the building

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no. F6/DFS/MS/2009/2282 Dated 26-06-2012 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Signature of the Inspecting Officer

Signature of the Inspecting Officer

Name

Uday Vir Singh

Name

Designation

ASel WP

Designation

(Handwritten signatures and dates)
 17/11/16
 17/11/16