

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**



No. F6/DFS/MS/EH/2016/SZ/ 1550

Dated: 21/10/16

**FIRE SAFETY CERTIFICATE**

Certified that the **Evergreen Sweet House, S-29-30, Green Park Market, New Delhi**, comprised of Basement, Ground + 02 upper floors (The Restaurant is running at first & second floor with seating capacity of 120 persons, ground floor used for in-out stores, basement floor used for storage) was granted FSC by this department vide letter No. F<sup>^</sup>/DFS/MS/EH/2013/SZ/1125 dated 23/10/2013. The premises was re-inspected by the officer concerned of this department on 28.09.2016 in the presence of Mr. Parmod Sharma, (Manager) and found that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fir for occupancy class **Group-D Assembly Building** (Restaurant) with effect from 21/10/16 for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 21/10/16 at New Delhi by

  
Vipin Kental  
Chief Fire Officer  
Ph.: 011-23412225  


Copy to: -

1. Mr. Manish Chopra, Evergreen Sweet House, Green Park Market, ND-110016
2. Dy. Health Officer, MCD, South Zone, Green Park, New Delhi.

**Conditions for the validity of Fire Safety Certificate**

1. All the fire safety and means of escape facilities shall be maintained in good working condition at all time. Any lapse rendering the fire safety or means of evacuation facilities non-functional shall be the responsibility of the management.
2. Building Sanctioning authority may verify any deviation with regard to construction/occupancy in the building. In case of any deviation, the fire safety certificate stands null & void.
3. The staff shall be trained for operating fire fighting system and mock evacuation drill be conducted at regular interval and record be maintained.
4. The basement shall be used strictly as per the provisions of Building Bye Laws.
5. The Owner/Occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules, 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
6. The Owner/Occupier shall apply for renewal of this Fire Safety Certificate to the Director in the form 'J' [sub rule (1) of rule 37] along with copy of this certificate, six months prior to its expiry. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).

N/10

**INSPECTION REPORT**

1	Name & Address of the Building	Evergreen Sweet house, S-29, 30, Green Park Market New Delhi-110016		
2	Type of Occupancy	Assembly Building "Group-D" Restaurant		
3	Building Comprised of	Basements, Ground plus two upper floors		
4	Type of Case	Renewal		
5	Details of Previous NOC	F6/DFS/MS/2013/EH/2013/SZ/1125dated 23.10.2013		
6	Fire Safety Directives Letter No	Nil		
7	Date of Inspection	28.09.2016		
8	Name of the Inspecting Officers	ADO R.N. Singh		
9	Name & Designation of Officers from the building side	Mr. Pramod Sharma (Manager)		
10	Year of construction	2004	Restaurant is running at First & Second Floor, Basement is used for storage, Ground floor is used for in-out stores	
11	Applicant letter No.	Nil dated 06.09.2016		
S. No	Minimum standards on Fire Prevention and Fire Safety U/R 33	NBC / BBL Requirements	Provided at Site	Remarks MR/NMR
1	<b>Access to Building.</b>			
	1. Road width	6 m	9 m	MR
	2. Gate width	2 m	2 m	MR
	3. Width of internal road	NA	NA	NA
2	<b>Number, width, type and arrangements of exits.</b>			
	<b>a. Number of Staircase</b>			
	1. Upper floors	2 Nos.	2 Nos.	MR
	2. Basement floor	2 Nos.	3 Nos.	MR
	<b>b. Width of Staircase</b>			
	1. Upper floors	Required	1.15 m & 1 m	MR
	2. Basement floor	Required	1.06 m, 1 m & 0.95 m	MR
	<b>c. Protection of exits</b>			
	1. Fire check door	Required	Provided	MR
	2. Pressurization	NA	NA	NA
	<b>d. No. of continuous staircase to terrace</b>	1 No	1 No	MR
	<b>e. Width of corridor</b>	NA	NA	NA
	<b>f. Door size</b>	Required	3 Nos. each of 1.87 m	MR
3	<b>Compartmentation.</b>			
	1. Fire check door.	Required	Provided	MR
	2. Sealing of electrical shafts.	NA	NA	NA
	3. Fire rating of shaft door.	NA	NA	NA
	4. Water curtain	NA	NA	NA
	5. Fire dampers.	NA	NA	NA
4.	<b>Smoke Management system.</b>			
	1. Basement	30 a/c per hour	Exhaust fan provided	MR
	2. Upper floors	12 a/c per hour	Exhaust fan provided	MR
5.	<b>Fire Extinguishers.</b>			
	1. Total numbers	ISI Marked 28 Nos	30 Nos.	MR
	2. Types		ABC- 20 & Co2-10 No	MR
	3. ISI Marking		Provided	MR
6.	<b>First Aid Hose Reels.</b>			
	1. Total numbers on each floor.	One	Provided	MR
	2. Length of hose-reel hose.	30 Mts.	Provided	MR
	3. Nozzle Diameter	5 mm	Provided	MR

Case: Renewal

Evergreen Sweet house, S-29, 30, Green Park Market

*for*



<b>7</b>	<b>Automatic Fire Detection and Alarming system.</b>			
	1. Type of detectors	NA	NA	NA
	2. Location of Main Panel	NA	NA	NA
	3. Location of Repeater Panel	NA	NA	NA
	4. Alternate source of power	NA	NA	NA
	5. Hooter's location	NA	NA	NA
<b>8.</b>	<b>MOEFA</b>	Required	Provided	MR
<b>9.</b>	<b>Public Address System</b>	Required	Provided	MR
<b>10.</b>	<b>Automatic Sprinkler System</b>			
	1. Basement	Required	Provided	MR
	2. Upper floors	Required	Provided	MR
	3. Sprinkler above false ceiling	NA	NA	NA
<b>11.</b>	<b>Internal Hydrants.</b>			
	1. Size of Riser / Down-comer	100 mm	100 mm	MR
	2. Number of Hydrant per floor	1 No	1 No	MR
	3. Hose box.	1 No	1 No	MR
<b>12.</b>	<b>Yard Hydrants.</b>			
	1. Total number of hydrants.	NA	NA	NA
	2. Hose box.	NA	NA	NA
<b>13.</b>	<b>Pumping arrangements.</b>			
	<b>1. Ground Level</b>			
	a) Discharge of main pump.	NA	NA	NA
	b) Head of main pump.	NA	NA	NA
	c) Number of main pumps.	NA	NA	NA
	d) Jockey Pump output.	NA	NA	NA
	e) Jockey Pump head.	NA	NA	NA
	f) Standby Pump output.	NA	NA	NA
	g) Standby Pump head.	NA	NA	NA
	h) Auto Starting / Manual Stopping.	NA	NA	NA
	i) Access to pump house	NA	NA	NA
	<b>2. Terrace Level</b>			
	a) Discharge of pump.	450 LPM	Provided	MR
	b) Head of pump.	Required	46 Mtr	MR
	c) Power supply.	Required	Provided	MR
	d) Auto starting of pump.	Required	Provided	MR
<b>14.</b>	<b>Captive water storage for Fire Fighting.</b>			
	1. Underground tank capacity.	NA	NA	NA
	2. Draw-off connection.	NA	NA	NA
	3. Fire Service Inlet.	NA	NA	NA
	4. Access to tank.	NA	NA	NA
	5. Overhead tank capacity.	10,000 Ltr.	10,000 Ltr.	MR
<b>15.</b>	<b>Exit Signage.</b>	Required	Provided	MR
<b>16.</b>	<b>Provision of Lifts.</b>			
	1. Pressurization of lift shaft.	NA	NA	NA
	2. Pressurization of lift lobby.	NA	NA	NA
	3. Communication in lift car.	NA	NA	NA
	4. Fireman's switch.	NA	NA	NA
	5. Lift signage.	NA	NA	NA
<b>17</b>	<b>Standby Power Supply</b>	Required	Provided	MR
<b>18.</b>	<b>Refuge Area</b>			
	1. Total area	NA	NA	NA
	2. Location	NA	NA	NA

*Pr*

N/12

<b>19.</b>	<b>Fire Control Room.</b>			
	1. Detector System Panel.	NA	NA	NA
	2. Flow Switch Panel.	NA	NA	NA
	3. PA system Panel.	NA	NA	NA
	4. Battery backup	NA	NA	NA
	5. Building floor plan	NA	NA	NA
<b>20.</b>	<b>Special Fire Protection System for the Protection of special Risk, if any :</b>	NA	NA	NA

The Fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter No. F6/DFS/MS/EH/2013/SZ/1125 dated 23/10/2013, renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended

Accordingly, DFA is put up for approval and signature please.

*R.N. Singh*  
30/9

Signature of the Inspecting Officer  
Name : R.N. Singh  
Designation: ADO

Case: Renewal

Evergreen Sweet house, S-29, 30, Green Park Market

Div. Officer (SD)

*Anilash*  
5/11/16

3-211 of 52  
10/11/16/21/11/16  
*dy. CFO (S2)*

*deval*  
6/10

*CFO S2P*

