

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/SCHOOL/2016/ W2/1551

Dated: 21/10/16

FIRE SAFETY CERTIFICATE

Certified that the **Nigam Pratibha Vidyalaya** Located at **Saraswati Vihar, D Block Delhi - 110034**, comprised of Ground + 1 Upper Floor was issued FSC vide Letter No. : **F6/DFS/MS/SCHOOL/2013/WZ/854, Dated-05/09/2013**. The premises was re inspected by the officer concerned of this department on 23-09-2016 in the presence of **Ms. Usha Gupta (Principal)** and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deem complied with the fire prevention and fire safety requirements in accordance DOE Cr. 17/01/2011/NBC - IV and that the premises is fit for occupancy class "Educational" Group B with effect from 21/10/16 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 21/10/16..... at New Delhi by.


(Atul Garg)
Chief Fire Officer
Delhi Fire Service

Copy to:

The Principal, **Nigam Pratibha Vidyalay Saraswati Vihar, D Block Delhi - 110034**.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. Basement shall be used as per BBL1983.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.

INSPECTION REPORT

1. Name & address of the building: **Nigam Pratibha Vidyalay Located at Saraswati Vihar, D Block Delhi - 110034.**
2. Type of Occupancy : Educational (Ground + 1 Upper Floor)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/SCHOOL/2013/WZ/854,Dated-05/09/2013
5. Fire Safety directives Letter No. : DOE 3298-3398 dated 01-03-2011
6. Date of inspection :23-09-2016
7. Name of the Inspecting Officer :Udai vir singh, ADO (WP)
8. Name and designation of Officer
 from the building side :Mis. Usha Gupta (Principal)
9. Year of Construction : 2006
10. Applicant's letter No. :Nil dated- 26/08/2016

No. of Students=548
No. of class rooms=32
Plot area=7449 sq.m
Covered area=2819.2sq.m

S No	Minimum standards on fire prevention and fire safety U/R 33	Cr.No.3298-3398 dated 1-3-11	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	<u>Accessible</u>	12mtrs Provided	MR
	• Gate width	Accessible	330cm Provided	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2	Provided <u>4 Nos</u>	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	1.5 cm	1x185,1x130,2x150,Provided	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	NA	NA	NA
	e. Width Of Corridor	Required	Provided	MR
	f. Door Size	1 mtr	117 cm Provided	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			

4. Details of previous NOC : F6/DFS/MS/SCHOOL/2013/WZ/854, Dated- 05/09/2013

5. Fire Safety directives Letter No. : DOE 3298-3398 dated 01-03-2011

6. Date of inspection : 23-09-2016

7. Name of the Inspecting Officer : Udai vir singh, ADO (WP)

8. Name and designation of Officer

from the building side : Mis. Usha Gupta (Principal)

9. Year of Construction : 2006

10. Applicant's letter No. : Nil dated- 26/08/2016

No. of Students=548
No. of class rooms=32
Plot area=7449 sq.m
Covered area=2819.2sq.m

S No	Minimum standards on fire prevention and fire safety U/R 33	Cr.No.3298-3398 dated 1-3-11	Provided at site	Remarks MR/NMR
1.	Access of building			
	<ul style="list-style-type: none">Road width	Accessible	12mtrs Provided	MR
	<ul style="list-style-type: none">Gate width	Accessible	330cm Provided	MR
	<ul style="list-style-type: none">Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	<ul style="list-style-type: none">Upper floors	2	Provided, 4 Nos	MR
	<ul style="list-style-type: none">Basements	NA	NA	NA
	b. Width of staircases			
	<ul style="list-style-type: none">Upper floors	1.5 cm	1x185,1x130,2x150, Provided	MR
	<ul style="list-style-type: none">Basements	NA	NA	NA
	c. Protection of exits			
	<ul style="list-style-type: none">Fire check door	NA	NA	NA
	<ul style="list-style-type: none">Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	NA	NA	NA
	e. Width Of Corridor	Required	Provided	MR
	f. Door Size	1 mtr	117 cm Provided	MR
3.	Compartmentation			
	<ul style="list-style-type: none">Fire check door	NA	NA	NA
	<ul style="list-style-type: none">Sealing of electrical shafts	NA	NA	NA
	<ul style="list-style-type: none">Fire Rating of shaft door	NA	NA	NA
	<ul style="list-style-type: none">Water Curtain	NA	NA	NA
	<ul style="list-style-type: none">Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	<ul style="list-style-type: none">Basements	NA	NA	NA
	<ul style="list-style-type: none">Upper floors	NA	NA	NA

	<ul style="list-style-type: none"> Total numbers Types IS marking 	10 nos. ABC & CO ₂ ISI marked	Provided Provided	MR MR
6.	First – Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	NA NA NA	NA NA NA	NA NA NA
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	NA NA NA NA NA	NA NA NA NA NA	NA NA NA NA NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basements Upper Floor Sprinkler above false ceiling 	NA NA NA	NA NA NA	NA NA NA
11.	Internal Hydrants:			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	NA NA NA	NA NA NA	NA NA NA
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	NA NA	NA NA	NA NA
13.	Pumping Arrangements:			
	<ul style="list-style-type: none"> Ground Level Discharge of main pump Head of main pump Number of main pumps Jockey pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/Manual stopping Pump House Access Terrace level Discharge of pump Head of the pump Power supply Auto starting of pump 	NA NA NA NA NA NA NA NA NA NA NA NA NA NA NA	NA NA NA NA NA NA NA NA NA NA NA NA NA NA	NA NA NA NA NA NA NA NA NA NA NA NA NA NA
14.	Captive water Storage for fire fighting:			
	<ul style="list-style-type: none"> Under ground tank capacity Draw off connection Fire service inlet Access to tank Overhead Tank 	NA NA NA NA NA	NA NA NA NA NA	NA NA NA NA NA

15.	Exit Signage	NA	NA	NA
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no. F6/DFS/MS/SCHOOL/2013/WZ/854, Dated-05/09/2013 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Signature of the Inspecting Officer

Signature of the Inspecting Officer

Name

Uday Vir Singh

Name

Designation

ADDO/WP

Designation

[Signature]

[Signature] 26/9/16