

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/ 24/2016/WZ/1552

Dated: 21/10/16

FIRE SAFETY CERTIFICATE

Certified that the **Wok In The Clouds (A unit of Galore Hospitality)** Located at 3, **Club Road, Punjabi Road, New Delhi - 110026** was issued FSC vide Letter No. **F6/DFS/MS/2014/WZ/325 Dated 10-03-2014**. The premises was re inspected by the team officers of this department on 28-09-2016 in the presence of **Sh. Kamaljeet (Manager)** and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and that the premises is fit for occupancy class "Assembly" Group D with effect from 21/10/16 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 21/10/16..... at New Delhi by.


(Atul Garg)

Chief Fire Officer,
Delhi Fire Service


21/10/16

Copy to:

1. Deputy Health Officer (Civil Line Zone), Public Health Department (NDMC), 16, Rajpur Road, Delhi - 110054.
2. Sh. Kamaljeet (Manager) Wok In The Clouds (A unit of Galore Hospitality) 3, Club Road, Punjabi Road, New Delhi - 110026.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used as per building bye laws.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1. Name & address of the building: **Wok In The Clouds (A unit of Galore Hospitality)** Located at, **3, Club Road, Punjabi Road, New Delhi – 110026.**
2. Type of Occupancy : **Assembly (B+G+03Upper Floor)Restaurant at G+FF** , kitchen at 2nd Floor and 3rd Floor vaccent)
3. Type of Case : **Renewal**
4. Details of previous NOC : **F6/DMS/MS/2014/WZ/325 Dated 10-03-2014**
5. Fire Safety directives Letter No. :
6. Date of inspection : **28- 09 -2016**
7. Name of the Inspecting Officer : **Udai vir Singh ADO (WP)**
8. Name and designation of Officer
from the building side : **Sh. Kamaljeet (Manager)**
9. Year of Construction : **2005**
10. Applicant's letter No. : **Nil dated Nil**

Sr. No	Minimum standards on fire prevention and fire safety U/R 33	NBC Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	12mtr	Provided	MR
	• Gate width	05 mtrs	Provided on main road	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2	Provided	MR
	• Basements	2	Provided	MR
	b. Width of staircases			
	• Upper floors	1m & 1.25m	1x1m & 1x.96m	MR(Being old case)
	• Basements	1m & 1.25m	1x1.04m & 1x1m	MR (Being Old Case)
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	NA	NA	NA
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	1m	Basement=1m &.82m GF=1.06m &.83m FF=.87m	MR (Being Old Case)

3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	30 a/c per hr	Provided(Exhaust Fan)	MR
	• Upper floors	12 a/c per hr	Provided	MR
5.	Fire Extinguishers			
	• Total numbers	08	Provided	MR
	• Types	ABC / CO2	Provided	MR
	• IS marking	ISI marked	Provided	MR
6.	First – Aid Hose Reels			
	• Total numbers on each floor	1	Provided	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	Yas	At entrance	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	• Basements	Required	Provided	MR
	• Upper Floor	Required	Provided	MR
	• Sprinkler above false ceiling	Required	Provided	MR
11.	Internal Hydrants:			
	• Size of riser/down-comer	100 mm	Provided	MR
	• Number of hydrants per floor	1	Provided	MR
	• Hose Box	Required	Provided	MR
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA

13.	Pumping Arrangements:			
	<ul style="list-style-type: none"> • Ground Level • Discharge of main pump ➤ Head of main pump ➤ Number of main pumps ➤ Jockey pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Staring/Manual stopping ➤ Pump House Access • Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power supply ➤ Auto starting of pump 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		2201 lpm, 1801 lpm	Provided	MR
		30 m	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
14.	Captive water Storage for fire fighting:			
	<ul style="list-style-type: none"> • Under ground tank capacity ➤ Draw off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	NA	NA	NA
		NA	NA	NA
		Required	Provided	NA
		NA	NA	NA
		5, 000 liters	Provided	MR
15.	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	<ul style="list-style-type: none"> ➤ Pressurization of Lift Shaft ➤ Pressurization of lift lobby ➤ Communication in lift Car ➤ Fireman's Grounding Switch ➤ Lift Signage 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area			
	<ul style="list-style-type: none"> ➤ Total area ➤ Location 	NA	NA	NA
		NA	NA	NA
19.	Fire control room			
	<ul style="list-style-type: none"> ➤ Detector system panel ➤ Flow Switch Panel ➤ PA System Panel ➤ Battery backup ➤ Building Floor Plans 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA

20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA
-----	--	----	----	----

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide Letter No. : **F6/DMS/MS/2014/WZ/325, Dated- 10-03-2014** renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Signature of the Inspecting Officer
Officer

Name

Designation

Uday Vir Singh
ADDO/WP

Signature of the Inspecting

Name

Designation

DO/WO
Inspector
17/10/16

CPD (WZ) - 42
CPD (West)
20/10/16

KT PLS