

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI - 110001


No. F6/DFS/MS/Indl/2016/WZ/ 1592

Dated: 26/10/16

FIRE SAFETY CERTIFICATE

Certified that the **Century Overseas**, Located at, Basement+ Ground + Mez/1st F+2nd F 37, **DLF Industrial Area Kirti Nagar, New Delhi-110015** in a building comprised of Basement+ Ground + Mez/1st F+2ndF & 3rd F (Sealed) was issued FSC vide Letter no. F6/DFS/MS/Indl/2011/WZ/3287 dated 01-12-2011. The premises was re inspected by the officers concerned of this department on 14-09-2016 in the presence of Mr Suresh Wadhwa (Manager) and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and that the premises is fit for occupancy class "Industry" Group G with effect from 26/10/16 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 26/10/16..... at New Delhi by.


(Atul Garg)
Chief Fire Officer,
Delhi Fire Service.

Copy to:

The Manager, Century overseas, 37, DLF Industrial Area Kirti Nagar, New Delhi-110015

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used strictly as per Building Bye Laws.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
9. FSC issued for Basement+ Ground + Mez/1st Floor +2nd Floor only
10. The 3rd floor is sealed and not used for any purpose.

INSPECTION REPORT

1. Name & address of the building: **Century overseas, 37 DLF Industrial Area Kirti Nagar, New Delhi-110015.**
2. Type of Occupancy : Class-G(GI) Industrial at Basement+G+2UFs in a building comprised of Basement+G+3UFs and Tin Shed at terrace. (Terrace and 3rd floor are vacant undertaking given by owner)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/INDU/2011/3287 Dated:-01/12/2011
5. Fire Safety directives Letter No. : F6/DFS/MS/BP/87/1565 dated 21-07-1987
6. Date of inspection : 14-09-2016
7. Name of the Inspecting Officer : Udavir Singh (ADO)
8. Name and designation of Officer from the building side : Mr. Wadhwa
9. Year of Construction : 1992-93
10. Applicant's letter No. : Nil dated- Nil

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	06mtrs	09 m	MR
	• Gate width	05 mtr	3.9m Provided	MR
	• Width of internal road	03 mtr	03 m	MR
2.	Number, width, Type & Arrangements of exits			
	• Number of staircases			
	• Upper floors	2	3 Provided	MR
	• Basements	2	3 Provided	MR
	• Width of staircases			
	• Upper floors	As per the sanctioned plan, 1.2 mtr	3x1.3m Provided	MR
	• Basements	As per the sanctioned plan, 1.2 mtr	3x1.3m Provided	MR
	• Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	NA	NA	NA
	• No of continuous staircase to terrace	1	Provided	MR
	• Width Of Corridor	NA. Halls only	NA. Halls only	MR
	• Door Size	1.5mtrs	1m	MR(Being old case)
3.	Compartmentation			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	No Shafts	No Shafts	NR
	• Fire Rating of shaft door	NR	NR	NR
	• Water Curtain	NA	NA	NA
	• Fire Door	NA	NA	NA

	<ul style="list-style-type: none"> Basements Upper floors 	Required NR	Provided NR	MR NR
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	20 nos. ABC & CO ₂ ISI marked	20 nos. Provided Provided	MR MR MR
6.	First – Aid Hose Reels			
	<ul style="list-style-type: none"> Total nos. on each floor Length of hose reel Nozzle diameter 	2 30 m 5 mm	2 Provided Provided Provided	MR MR MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	NR NR NR NR NR	NR NR NR NR NR	NR NR NR NR NR
8.	MOEFA	NR	Provided	MR
9.	Public Address System	NR	Provided	MR
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basements Upper Floor Sprinkler above false ceiling 	Required NR No false selling	Provided NR NR	MR NR MR
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down- comer Number of hydrants per floor Hose Box 	150 mm 2 2	Provided 2 Provided 2 Provided	MR MR MR
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	NR NR	NR NR	NR NR
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level Discharge of main pump Head of main pump Number of main pumps Jockey pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Staring/Manual stopping Pump House Access Terrace level Discharge of pump Head of the pump Power supply Auto starting of pump 	2280 lpm 60 m 2 180 lpm 60 m 2280 lpm 60 m Required Required 450 lpm 40 m Required Yas	Provided Provided Provided Provided Provided Provided Provided Provided Provided Provided Provided Provided Provided Provided	MR MR MR MR MR MR MR MR MR MR MR MR MR MR
14.	Captive water Storage for fire fighting			
	<ul style="list-style-type: none"> Under ground tank capacity Draw of connection Fire service inlet Access to tank Overhead Tank capacity 	1 lac litres Required Required Required Required 10, 000 litres	Provided Provided Provided Provided Provided	MR MR MR MR MR(Old Case)

15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NR	NR	NR
	➤ Pressurization of lift lobby	NR	NR	NR
	➤ Communication in lift Car	NR	NR	NR
	➤ Fireman's Grounding Switch	NR	NR	NR
	➤ Lift Signage	NR	NR	NR
17.	Standby power supply	Required	60 K.V.A	MR
18.	Refuge Area			
	➤ Total area	NR	NR	NR
	➤ Location	NR	NR	NR
19.	Fire control room			
	➤ Detector system panel	NR	NR	NR
	➤ Flow Switch Panel	NR	NR	NR
	➤ PA System Panel	NR	NR	NR
	➤ Battery backup	NR	NR	NR
	➤ Building Floor Plans	NR	NR	NR
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NR	NR	NR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no. F6/DFS/MS/INDU/2011/3287 Dated:-01/12/2011 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Signature of the Inspecting Officer

Signature of the Inspecting Officer

Name

Uday Vir Singh

Name

Designation

ASD/w/p

Designation

ASD/w/p

Uday Vir Singh
14/12/11