

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No F 6 / DFS / MS / 2016 / EH/2016/WZ/1588

Dated 26/10/16

FIRE SAFETY CERTIFICATE

Certified that the **New Eleven to Eleven Restaurant** located at **1st Floor ,Shop No. 12, CSC-5, DDA Gole Market, Sec.-9, Rohini, Delhi-85** in the building comprised of ground and First floor owned/ occupied by Mr. Sukhvinder Singh was granted Fire Safety Certificate by this department vide letter no. **F6/DFS/MS/EH/2013/WZ/822 dated 29.08.2013**. The premises was re-inspected by the officers concerned of this department on 17.10.2016 in the presence of Sh. **Nand Kishore , Manager** of the Restaurant and found the building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and premises is fit for **Class –D(Assembly)** occupancy with effect from - 26/10/16 for a period of **03 (Three) years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.


Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in
8. All the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.

Issued on 26/10/16..... at New Delhi by



(Abdul Garg)
Chief Fire Officer
Ph-011-23414250



Copy to:-

1. The Dy. Health Officer, North MCD,
Civil Line Zone, Sec-5, Rohini, Delhi-110054.
2. The Manager , New Eleven to Eleven, Shop No. 12, CSC-5, 1st Floor, DDA Gole Market,
Sector-9, Rohini, Delhi-85.

INSPECTION REPORT

1. Name & address of the building : New Eleven to Eleven, Shop No. 12, CSC-5, 1st Floor, DDA Gole Market, Sec.-9, Rohini, Delhi-85. **(First Floor)**
2. Type of Occupancy : Assembly (Restaurnat)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/EH/2013/822 dated 23.08.2013
5. Fire Safety directives letter No : NBC Part IV
6. Date of inspection : 17/10/2016
7. Name of the Inspecting Officers : ADO (RN)
8. Name and designation of officers
from the building side : Mr Nand Kishore (Manager)
9. Year of Construction : 2005/2010
10. Applicant's letter No. : DHO/RZ/2016/1129 dated 01.09.2016

	Minimum Standards on fire prevention and fire safety U/R 33	NBC/ BBL Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	09m	10m	MR
	• Gate width	NA	NA	NA
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	02	02	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	1.50m	1.46m & 1.45m	MR(old case)
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	01	01	MR
	e. Width of Corridor	NA	NA	NA
	f. Door Size	02 Exits	1.10m each	MR

N/10

3	Compartmentation. For the restaurant			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain ²	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System.			
	• Basements	30 a/c per hour	NA	NA
	• Upper floors	12 a/c per hour	Natural Ventilated	MR
5	Fire Extinguishers For the restaurant			
	• Total numbers	05nos	05nos	MR
	• Types	ABC/Co2	ABC-04 /Co2-01	MR
	• ISI marking	Yes	Yes	MR
6	First-Aid Hose Reels.			
	• Total numbers on each floor	01	01	MR
	• Length of hose reel hose	30 m	30m	MR
	• Nozzle diameter	5mm	5mm	MR
7	Automatic fire detection and alarming system.			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8	MOEFA	Required	Provided	MR
9	Public Address System.	NA	NA	NA
10	Automatic Sprinkler System.			
	• Basement	NA	NA	NA
	• Upper Floor	Required	Provided	MR
	• Sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants for the Mall			

	<ul style="list-style-type: none"> • Size of riser/down-comer • Number of hydrants per floor • Hose Box 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
12	Yard Hydrants. For the Mall			
	<ul style="list-style-type: none"> • Total number of hydrants 	Required	Provided	MR
	<ul style="list-style-type: none"> • Hose Box 	Required	Provided	MR
13	Pumping Arrangements			
	<ul style="list-style-type: none"> • Ground Level <ul style="list-style-type: none"> ➤ Discharge of main Pump ➤ Head of Main pump ➤ Number of main pumps ➤ Jockey Pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/ Manual stopping ➤ Pump House Access • Terrace level <ul style="list-style-type: none"> ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		180 lpm	180 lpm	MR
		40m	40m	MR
		NA	NA	NA
		Required	Provided	MR
		NA	NA	NA
		450 lpm	450 lpm	MR
		40m	40m	MR
		Required	Provided	MR
		Required	Provided	MR
14	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	NA	NA	NA
		NA	NA	NA
		Required	Provided	MR
		NA	NA	NA
		5000 ltr	5000 ltrs	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby 	NA	NA	NA
		NA	NA	NA

M/12

	<ul style="list-style-type: none"> • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
17	Standby power supply	Required	Provided	MR
18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 	NA	NA	NA
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	NA	NA	NA

The fire protection systems provided in the building were tested/ checked and found some in working order at the time of inspection.

Keeping in view of the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to renew Fire Safety Certificate issued vide this department letter of even no. 822 dated 29.08.2013 under rule 35 of the Delhi Fire Service Rules 2010.

ACC
18/10/16

Signature of the Inspecting Officer
Name: - Rajesh Kumar
Designation:- ADO/RN

D.O. No. 10
Singh
19.10.16

Dy CPO (WZ)


21/10/16

CPO - West
24/10/16
R DL