

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No F 6 / DFS / MS / GH / 2016 / *w2/1584*

Dated: *26/10/16*

FIRE SAFETY CERTIFICATE

Certified that the **Shanti Royal Banquets, B-4, , G.T.Road Indl. Area, Delhi** comprised of basement+ ground and two upper floors owned/ occupied by Shanti Royal Banquets has already been issue fire safety certificate vide letter no. **F6/DFS/MS/2013/239 dated 02/05/2013**.The premises was re-inspected by the officer concerned of Fire Service on 28/04/2016 in the presence of **Sh. Sanjay Grover (Manager)** and observed that all the fire prevention & fire safety arrangements as provided in the premises found in good working condition.. The premises have therefore deemed complied with the fire prevention and fire safety accordance with rule 33 of the Delhi Fire Service rule 2010 for a period, of **three years** in accordance with rules 36 unless renewed under rule. 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in
8. All the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.

Issued on *26/10/16*..... at New Delhi by

Atul Garg
25/10/16

(Atul Garg)
Chief Fire Officer
Ph:-011-23414250

Copy to : -

ca

1. The Additional Commissioner of Police (Lic), 1st floor, Police Station, Defence Colony, New Delhi.
2. The Manager, Shanti Royal Banquets, B-4, , G.T.Road Indl. Area, Delhi

N/24

INSPECTION REPORT

1. Name & address of the building : Shanti Royal Banquets, B-4, , G.T.Road Indl. Area, Delhi.
2. Type of Occupancy :Guest House(B+G+02 upper floors)
3. Type of Case :Renewal
4. Details of previous NOC :F6/DFS/MS/2013/239 dated 02/05/2013
5. Fire Safety directives letter No :old case
6. Date of inspection :10/10/2016
7. Name of the Inspecting Officers :ADO (RN)
8. Name and designation of officers
from the building side : Sh.Sanjay Grover (Manager)
9. Year of Construction :2012
10. Applicant's letter No. : Nil dated 23/09/2016

	Minimum Standards on fire prevention and fire safety U/R 33	NBC/ BBL Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	09m	20m	MR
	• Gate width	Directly Accessible	Directly Accessible	MR
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	02	03	MR
	• Basements	02	02	MR
	b. Width of staircases			
	• Upper Floors	02	1.50m, 2.60m & 1.16m	MR (old case)
	• Basements	02	1.50m & 2.00m	MR
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	02	03	MR
	e. Width of Corridor	NA	NA	NA

M

25

	f. Door Size	2.0m	2.0m	MR
3	Compartmentation.			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System.			
	• Basements	30 a/c per hour	Provided	MR
	• Upper floors	12 a/c per hour	Natural Ventilated	MR
5	Fire Extinguishers			
	• Total numbers	016nos	16	MR
	• Types	ABC & Co2	W. Co2 - 08 Co2 - 08	MR
	• ISI marking	Yes	Yes	MR
6	First-Aid Hose Reels.			
	• Total numbers on each floor	02	02	MR
	• Length of hose reel hose	30m	30m	MR
	• Nozzle diameter	5mm	5mm	MR
7	Automatic fire detection and alarming system.			
	• Type of detectors	Required	Provided	MR
	• Location of Main Panel	G.F	Provided	MR
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	Required	Provided	MR
	• Hooters' Location	Common Areas	Provided	MR
8	MOEFA	Required	Provided	MR
9	Public Address System.	NA	NA	NA
10	Automatic Sprinkler System.			
	• Basement	Required	Provided	MR
	• Upper Floor	NA	Provided	NA

M

11/26

	<ul style="list-style-type: none"> • Sprinkler above false ceiling 	NA	NA	NA
11	Internal Hydrants			
	<ul style="list-style-type: none"> • Size of riser/down-comer 	100mm	100mm	MR
	<ul style="list-style-type: none"> • Number of hydrants per floor • Hose Box 	02 Nos.	Provided	MR
12	Yard Hydrants.			
	<ul style="list-style-type: none"> • Total number of hydrants • Hose Box 	NA	NA	NA
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> • Ground Level 			
	➤ Discharge of main Pump	2280 lpm	2280 lpm	MR
	➤ Head of Main pump	40m	40m	MR
	➤ Number of main pumps	01 no.	01 no.	MR
	➤ Jockey Pump out put	180 lpm	180 lpm	MR
	➤ Jockey pump head	40m	40m	MR
	➤ Standby Pump out put	2280 lpm	2280 lpm	MR
	➤ Standby Pump Head	40m	40m	MR
	➤ Auto Starting/ Manual stopping	Required	Provided	MR
	➤ Pump House Access	900 LPM	900 lpm	MR
	• Terrace level	40m	40m	MR
	➤ Discharge of pump	Required	Provided	MR
➤ Head of the pump	Required	Provided	MR	
➤ Power Supply				
➤ Auto Starting of pump				
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> • Underground tank capacity 	50,000 ltr.	50,000 ltr.	MR
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	Required	Provided	MR
	• Overhead Tank capacity	10000 ltr	10000 ltr.	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			

M

N/29

	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	Required	Provided	MR
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
17	Standby power supply	Required	Provided inverter	MR
18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	Separate circuit for emergency service	Provided	MR

The fire protection systems provided in the building were tested/ checked and found some in working order at the time of inspection.

Keeping in view of the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules, it is recommended to renew Fire Safety Certificate issued vide this department letter of even no. 239 dated 02.05.2013 under rule 35 of the Delhi Fire Service Rules 2010.

10/14/16

Signature of the Inspecting Officer
 Name: - Rajesh Kumar
 Designation:- ADO/RN

DOIN/10
 Singh
 15.10.16

Dy CFA (WZ)

18/10/16
 17/10/16