

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No.

F6/DFS/MS/EH/ND2/2016/R78


Dated

16/08/16

FIRE SAFETY CERTIFICATE

Certified that the KFC Restaurant running at ground floor at F-25, Preet Vihar, Delhi-92, comprised of ground plus three upper floors owned/occupied by M/sYUM Restaurant (India) Pvt.Ltd was granted FSC vide letter No. F6/DFS/MS/EH/2013/NDZ/659 dt- 01/08/13. The Premises was re-inspected by the officer concerned of this department on 10.08.2016 in the presence of Mr. Deepak Kumar (Manager) and found that the restaurant have deemed complied with the fire prevention and fire safety requirements in accordance with the NBC Part -IV and found that the restaurant is fit for occupancy class "Eating House (Restaurant)" with effect from 16/8/16 for a period of three years in accordance with Rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rule 2010, subject to conditions printed overleaf.

Issued on 16/8/16 at New Delhi by



(Sunil Chaudhary)
Dy. Chief Fire Officer
Delhi Fire Service

To

M/S KFC (A Unit of YUM Restaurant (India) Pvt. Ltd,
F-25, Preet Vihar, Delhi-92

Copy to-

The Deputy Health Officer,
Shahdara (South) Zone, EDMC,
Health Department, Shahdara South Zone, Karkardooma, Delhi

1. Name & address of the building : KFC Restaurant at Ground floor,F-25, Preet Vihar,Delhi-92
2. Building is comprised of : Ground plus three upper floors(Restaurant at Ground floor Only)
3. Type of Occupancy : Assembly
4. Type of Case : Renewal
5. Details of Previous FSC : F6/DFS/MS/EH/2013/NDZ/659 dt- 01/08/13
6. Fire Safety direction letter No :NBC Part-IV.
7. Date of Inspection : 10/08/16
8. Name of the Inspecting Officers: : DO S.K.Dua & ADO R.K.Yadav
9. Name of the designation of Officer
from the building side : Mr. Deepak Kumar (Manager)
10. Year of Construction : 1988 as per owner statement
- 11.Applicant's letter No : Nil Dated 26.07.2016


Sr. no.	Minimum Standards on fire prevention and fire safety U/R33	NBC Requirement	Provided at Site	Remarks MR/NMR	
1	Access to building				
	Road width	06 m	30m	MR	
	Gate width	NA	NA	NA	
	Width of internal road	N/A	N/A	N/A	
2	Number, Width, Type and Arrangement of Exits				
	a. Number of Staircases				
	Upper Floor	N/A	N/A	N/A	
	Basement	N/A	N/A	N/A	
	b. Width of Staircases	N/A	N/A	N/A	
	Upper Floor	N/A	N/A	N/A	
	Basement	N/A	N/A	N/A	
	c. Protection of exits	N/A	N/A	N/A	
	Fire check door	N/A	N/A	N/A	
	Pressurization	N/A	N/A	N/A	
	e. No. of continuous staircases to terrace	N/A	N/A	N/A	
	g. Width of Corridor	N/A	N/A	N/A	
	h. Door Size	2 m	(I) 2 m,(ii)1.0 m & .80 m (Through kitchen both)	MR (Old case)	
3	Compartmentation.				
	• Fire check door	NA	NA	NA	
	• Sealing of electrical shafts	NA	NA	NA	
		N/A	N/A	N/A	
	• Fire rating of shaft door	N/A	N/A	N/A	
	• Water curtain	N/A	N/A	N/A	
	• Fire Dampers	N/A	N/A	N/A	
4	Smoke Management System.				
	• Basement	NA	NA	NA	
	• Upper floor	NA	NA	NA	
5.	Fire Extinguisher				
	• Total numbers		04 no.	Provided	MR
	• Types		CO ₂ + ABC	Provided	MR
	• IS marking		ISI marked	Provided	MR

6	First-aid-Hose Reels.			
	Total numbers of each floor	01 no.	Provided	MR
	Length of hose reel hose	30 m	Provided	MR
	Nozzle diameter	5 mm	Provided	MR
7	Automatic fire detection and alarming system.			
	Type of detectors	NA	Smoke Type	Acceptable
	Location of main panel	NA	Provided at reception	Acceptable
	Location of repeater panel	NA	NA	NA
	Alternate source of power	Required	Provided	MR
	Hooter's location	NA	NA	NA
8	MOEFA	Required	Provided	MR
9	Public address System.	NA	NA	NA
10	Automatic Sprinkler System.			
	basement	NA	NA	NA
	upper floor	NA	NA	NA
	sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants			
	size of riser/down-comer	100 mm	Provided	MR
	Number of hydrants per floor	1 no.	Provided	MR
	Hose Box	1 no.	Provided	MR
12	Yard Hydrants.			
	Total number of hydrants	NA	NA	NA
	Hose Box	NA	NA	NA
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> • Ground Level <ul style="list-style-type: none"> ➤ Discharge of main Pump ➤ Head of Main Pump ➤ Number of main pumps ➤ Jockey pump out put ➤ Jockey pump head ➤ Standby pump out put ➤ Standby pump Head ➤ Auto Starting /Manual stopping ➤ Pump House Access • Terrace Level <ul style="list-style-type: none"> ➤ Discharge of pump ➤ Head of the Pump ➤ Power supply ➤ Auto Starting of pump 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		450 LPM	Provided	MR
		40 M	Provided	MR
		Required	Provided	MR
		Required	Provided	MR


14	Captive Water Storage for Fire Fighting.			
	Underground tank capacity	NA	NA	NA
	Draw-off connection	NA	NA	NA
	Fire service inlet	NA	NA	NA
	Access to tank	NA	NA	NA
	Overhead Tank capacity	10,000 Liters	10,000 Liters	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	Pressurization of Lift Shaft	N/A	N/A	N/A
	Pressurization of Lift lobby	N/A	N/A	N/A
	Communication in lift car	N/A	N/A	N/A
	Firemen's grounding switch	N/A	N/A	N/A
	Lift Signage	N/A	N/A	N/A
17	Standby power supply	Required	Provided	MR
18	Refuge Area.			
	Total area	N/A	N/A	N/A
	Location	N/A	N/A	N/A
19	Fire Control Room			
	Detector system panel	NA	NA	NA
	Flow switch panel	N/A	NA	NA
	PA system panel	N/A	NA	NA
	Batter backup	N/A	NA	NA
	Building Floor Plans	N/A	NA	NA
20	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	N/A


The fire protection systems provided in the building were tested checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the NBC Part IV. The fire safety certificate issued vide letter no. F6/DFS/MS/EH/2013/NDZ/659 dt- 01/08/13 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.


 Signature of the Inspecting Officer / 10/08/2016
 Name:-R.K.Yadav
 Designation :-ADO(LN)

DO(ED)


 10/08


 11/8