

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001


No.F6/DFS/MS/EH/2016/ NO2/1187

Dated : 21/7/16

FIRE SAFETY CERTIFICATE

Certified that the M/s Kill the Bill, (A Unit of Dee Hospitality Pvt. Ltd.), at F-14/15, 1st floor, Shivam House, Middle Circle, Connaught Place, New Delhi comprises of Basement + Ground + 03 upper floor, Restaurant is running at First floor only owned /occupied by M/s Kill the Bill, (A Unit of Dee Hospitality Pvt. Ltd.), has complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of Delhi Fire Service on 08-07-2016 in the presence of Sh. Rajender Quazi (Manager) and that the building / premises, is fit for occupancy class **Assembly Building Group-D of Sub-Division D-5, Restaurant at first floor only** with effect from 21/7/16 for period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on21/7/16..... at New Delhi by.


(Vipin Kental)
Chief Fire Officer
Delhi Fire Officer

Copy to:-

1. The Medical Officer of Health,
NDMC, Palika Kendre, New Delhi.
2. The Manager,
M/s Kill the Bill, (A Unit of Dee Hospitality Pvt. Ltd.), at F-14/15, 1st floor, Shivam House, Middle Circle, Connaught Place, New Delhi.

Condition for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry”.

INSPECTION REPORT

1. Name & address of the building:- ✓ M/s Kill the Bill, (A Unit of Dee Hospitality Pvt. Ltd.), at F-14/15, 1st floor, Shivam House, Middle Circle, Connaught Place, New Delhi
2. Type of occupancy:- ✓ Assembly Building
B + Gr. + 3 upper floor
(Restaurant at 1st floor only) *App. 480sq.ft.*
3. Type of case:- ✓ New Case
4. Details of previous NOC:- NA
5. Fire safety directives No.- N/A
6. Date of inspection:- 8/07/16
7. Name of the inspecting officer:- Sh. Sunil Chaudhary Dy. CFO /NDZ
Sh. Gurmukh Singh Chauhan DO/CD &
Sh. Manoj Kumar Sharma ADO/CC
8. Name & designation of officer
From the building side:- Sh. Rajender Quazi (Manager)
Old
9. Year of construction:- MOH/D-857/(Lic.)/SI-I dated 17/06/16
10. Applicant's letter No:-

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement Existing fire safety arrangements	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	09 mtr.	18 mtr.	MR
	2) Gate width	N/A	N/A	N/A
	3) Width of internal road	N/A	N/A	N/A
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	02 Nos.	02 Nos.	MR
	2. Basements	01 Nos.	01 Nos.	N/A
	B. Width of staircase			
	1. Upper floors	0.80 & 1.25 mtr. <i>0.80 m.</i>	1 Nos. 1.30 mtr. 1 Nos. 1.25 mtr.	MR (old Bldg.)
	2. Basements	1.25 mtr N/A	1 Nos. 1.30 mtr.	MR or A
	C. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace			
	E. Width of corridor	N/A	N/A	N/A
	F. Door size	2 mtr. x 1 <i>1.1m x 1</i>	2 mtr x 1 <i>1.10m x 1</i>	MR
3.	Compartmentation			
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	N/A	N/A	N/A
	2) Upper floors	12 a/c per	Natural	MR


5.	Fire Extinguishers			
	1) Total numbers	08	08	MR
	2) Types	ABC & CO2	ABC & CO2	MR
	3) ISI marking	ISI	Provided	MR
6.	First-Aid Hose Reel			
	1) Total number each floor	01	01	MR
	2) Length of hose reel hose	30 m	30 m	MR
	3) Nozzle diameter	5 mm	5 mm	MR
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	N/A	Provided	N/A
	2) Location of main panel	N/A	Ground	N/A
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	N/A	Provided	N/A
	5) Hooter's Location	N/A	Ground floor	N/A
8.	MOEFA	Required	Provided	MR
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	1) Basement area less than 200 SQM	N/A	N/A	N/A
	2) Upper floors,	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	100 mm	100 mm	MR
	2) Number of hydrants 1 st floor	01	01	MR
	3) Hose box 1 st floor	01	01	MR
12.	Yard Hydrants			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A
13.	Pumping Arrangement			
	1) Ground level			
	a) Discharge of main pump	N/A	N/A	N/A
	b) Head of main pump	N/A	N/A	N/A
	c) Number of main pump	N/A	N/A	N/A
	d) Jockey pump output	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	2) Terrace level			
	a) Discharge of pump	450 LPM	450 LPM	MR
	b) Head of pump	40 mtr.	40 mtr.	MR
	c) Power supply	Required	Provided	MR
	d) Auto starting of pump	Required	Provided	MR
14.	Captive Water Storage for Fire Fighting			
	1) Under ground tank	N/A	N/A	N/A

	capacity			
	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	N/A	N/A	N/A
	c) Access to tank	N/A	N/A	N/A
	d) Over head tank capacity	10,000 ltrs.	10,000 Ltr.	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	N/A
17.	Stand by Power Supply	Required	Provided	MR
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room	N/A	N/A	N/A
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any:			MR

The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection existing fire fighting system has been clubbed.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules, grant of fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010 / is recommended please.

Signature of the Inspecting Officer



Name :- Sh. Sunil Chaudhary
Designation :- DCFO (NDZ)

Signature of the Inspecting Officer



Name :- G.S Chauhan
Designation :- DO (CD)

Signature of the Inspecting Officer



Name :- M.K. Sharma
Designation :- ADO (CC)