

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

No. F6/DFS/MS/School/SZ/2016/ 1598

Dated: 27/10/16

FIRE SAFETY CERTIFICATE

Certified that the **S.D.M.C. Primary School (Girls), Hauz Rani (Hindi), Malviya Nagar, New Delhi (School ID-1959005)** comprised of ground floor only Owned/Occupied by S.D.M.C. was granted Fire Safety Certificate by this department vide letter No. F.6/DFS/MS/School/2013/SZ/855 dated 05/09/2013. The premises was re-inspected by officer concerned of this department on 15.10.2016 in the presence of Ms. Mumtaz Bano, Principal of the school and found that said building have deemed complied with the fire prevention and fire safety arrangements in accordance with Directorate of Education circular no. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01/03/2011 issued by Director of Education and that the premises is fit for occupancy class "**Educational Building Group-B**" with effect from 27/10/ 2016 for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 27/10/16..... at New Delhi by


Vipin Kental
Chief Fire Officer
Ph.: 011-23412225

Ras

Copy to: -

1. The Principal, SDMC Primary School (Girls),
Hauz Rani (Hindi), Malviya Nagar, New Delhi-110017
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi.

Conditions for the validity of Fire Safety Certificate

1. All the fire safety and means of escape facilities shall be maintained in good working condition at all time. Any lapse rendering the fire safety or means of evacuation facilities non-functional shall be the responsibility of the management.
2. Building Sanctioning authority may verify any deviation with regard to construction/occupancy in the building. In case of any deviation, the fire safety certificate stands null & void.
3. The staff shall be trained for operating fire fighting system and mock evacuation drill be conducted at regular interval and record be maintained.
4. The basement shall be used strictly as per the provisions of Building Bye Laws.
5. The Owner/Occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules, 2010. The form is available on www.dfs.delhigovt.nic.in.
6. The Owner/Occupier shall apply for renewal of this Fire Safety Certificate to the Director in the form 'J' [sub rule (1) of rule 37] along with copy of this certificate, six months prior to its expiry. The form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1	Name & Address of the Building	S.D.M.C. Primary School (Girls), Hauz Rani (Hindi) Malviya Nagar, New Delhi-110017		
2	Type of Occupancy	Educational Building "Group-B" (School)		
3	Building Comprised of	Ground floor only		
4	Type of Case	Renewal		
5	Details of Previous NOC	F.6/DFS/MS/School/2013/SZ/835 Dt. 05/09/2013		
6	Fire Safety Directives Letter No	DOE circular no. F.16/Estate/CC/ Fire Safety/2011/3298 to 3398 Dt. 01.03.2011		
7	Date of Inspection	15/10/2016		
8	Name of the Inspecting Officers	ADO R.N. Singh		
9	Name & Designation of Officers from the building side	Ms. Mumtaz Bano (Principal)		
10	Year of construction	1961		
11	Applicant letter No.	Nil Dt. 19.09.2016		
S. No	Minimum standards on Fire Prevention and Fire Safety U/R 33	DOE Circular Dt. 01.03.2011 Requirements	Provided at Site Old FSC-2013	Remarks MR/NMR
1	Access to Building.			
	1. Road width	Accessible	5 Mtr	MR
	2. Gate width	NA	2.95 Mtr	NA
	3. Width of internal road	NA	NA	NA
2	Number, width, type and arrangements of exits.			
	a. Number of Staircase			
	1. Upper floors	N/A	N/A	N/A
	2. Basement floor	N/A	N/A	N/A
	b. Width of Staircase			
	1. Upper floors	N/A	N/A	N/A
	2. Basement floor	N/A	N/A	N/A
	c. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	d. No. of continuous staircase to terrace	N/A	N/A	N/A
	e. Width of corridor	N/A	N/A	N/A
	f. Door size	1.0 Mtr	Provided	MR
3	Compartmentation.			
	1. Fire check door.	N/A	N/A	N/A
	2. Sealing of electrical shafts.	N/A	N/A	N/A
	3. Fire rating of shaft door.	N/A	N/A	N/A
	4. Water curtain	N/A	N/A	N/A
	5. Fire dampers.	N/A	N/A	N/A
4.	Smoke Management system.			
	1. Basement	N/A	N/A	N/A
	2. Upper floors	N/A	N/A	N/A
5.	Fire Extinguishers.			
	1. Total numbers	Portable Fire Extinguishers	04 Nos.	MR
	2. Types		ABC 5 Kg.	MR
	3. ISI Marking		Provided	MR
6.	First Aid Hose Reels.			
	1. Total numbers on each floor.	N/A	N/A	N/A
	2. Length of hose-reel hose.	N/A	N/A	N/A
	3. Nozzle Diameter	N/A	N/A	N/A

Renewal

SDMC School (Girls), Hauz Rani (Hindi)

[Signature]

2/9

7	Automatic Fire Detection and Alarming System.			
	1. Type of detectors	N/A	N/A	N/A
	2. Location of Main Panel	N/A	N/A	N/A
	3. Location of Repeater Panel	N/A	N/A	N/A
	4. Alternate source of power	N/A	N/A	N/A
	5. Hooter's location	N/A	N/A	N/A
8.	MOEFA / SIREN	N/A	N/A	N/A
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	1. Basement.	N/A	N/A	N/A
	2. Upper floors	N/A	N/A	N/A
	3. Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants.			
	1. Size of Riser / Down-comer	N/A	N/A	N/A
	2. Number of Hydrant per floor	N/A	N/A	N/A
	3. Hose box.	N/A	N/A	N/A
12.	Yard Hydrants.			
	1. Total number of hydrants.	N/A	N/A	N/A
	2. Hose box.	N/A	N/A	N/A
13.	Pumping arrangements.			
	A. Ground Level			
	a) Discharge of main pump.	N/A	N/A	N/A
	b) Head of main pump.	N/A	N/A	N/A
	c) Number of main pumps.	N/A	N/A	N/A
	d) Jockey Pump output.	N/A	N/A	N/A
	e) Jockey Pump head.	N/A	N/A	N/A
	f) Standby Pump output.	N/A	N/A	N/A
	g) Standby Pump head.	N/A	N/A	N/A
	h) Auto Starting / Manual Stopping.	N/A	N/A	N/A
	i) Pump house access.	N/A	N/A	N/A
	B. Terrace Level			
	a) Discharge of pump.	N/A	N/A	N/A
	b) Head of pump.	N/A	N/A	N/A
	c) Power supply.	N/A	N/A	N/A
	d) Auto starting of pump.	N/A	N/A	N/A
14.	Captive water storage for Fire Fighting.			
	1. Underground tank capacity.	N/A	N/A	N/A
	2. Draw-off connection.	N/A	N/A	N/A
	3. Fire Service Inlet.	N/A	N/A	N/A
	4. Access to tank.	N/A	N/A	N/A
	5. Overhead tank capacity.	N/A	N/A	N/A
15.	Exit Signage.	N/A	N/A	N/A
16.	Provision of Lifts.			
	1. Pressurization of lift shaft.	N/A	N/A	N/A
	2. Pressurization of lift lobby.	N/A	N/A	N/A
	3. Communication in lift car.	N/A	N/A	N/A
	4. Fireman's switch.	N/A	N/A	N/A
	5. Lift signage.	N/A	N/A	N/A
17	Standby Power Supply	N/A	N/A	N/A
18.	Refuge Area			
	1. Total area	N/A	N/A	N/A
	2. Location	N/A	N/A	N/A

h

N/10

19.	Fire Control Room.			
	1. Detector System Panel.	N/A	N/A	N/A
	2. Flow Switch Panel.	N/A	N/A	N/A
	3. PA system Panel.	N/A	N/A	N/A
	4. Battery backup	N/A	N/A	N/A
	5. Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for the Protection of special Risk, if any.	N/A	N/A	N/A

The Fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the circular of Directorate of Education dated 01/03/2011, Fire Safety Certificate issued vide letter No. F.6/DFS/MS/School/2013/SZ/835 Dt. 05.09.2013, renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended.

Accordingly DFA is put up for approval and signature please.

R.N. Singh
14/14

Signature of the Inspecting Officer
Name : R.N. Singh
Designation: ADO

Renewal

SDMC School (Girls), Hauz Rani (Hindi)

Div. Officer (SD)



Div. Officer (SD)
18/11/16

By: [Signature]
10/11/16

[Signature]
10/11/16

344/cfo sz
20/11/16/2014

cfo sz

M. steen 11/11/16