

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110 001

No. F.6/DFS/MS/EH/2016/ 16/3

Dated: 31/10/16

**FIRE SAFETY CERTIFICATE**

Certified that the **Eat Food Lounge**, located at **1<sup>st</sup> Floor, Plot No. 3, Promenade Mall, Nelson Mandela Road, Vasant Kunj, New Delhi-110070** comprises of Two tier Basement, Lower Ground floor, Upper Ground Floor, 1<sup>st</sup> Floor and Projection Room but the Eat Food Lounge is running on first floor only was inspected by the officer concerned of this department on 17/10/16 in the presence of Mr. Manish (Fire Officer) and found that the said eating house have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class **Group- D Assembly Building** with effect from -- ~~31/10/16~~ 31/10/16 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule-38 of the Delhi Fire Service Rules, 2010.

Issued on..... 31/10/16 .....at New Delhi by.

  
(Vipin Kental)  
Chief Fire Officer  
Tel: 011-23412225

Copy to:-

1. The Dy. Health Officer, South Zone, MCD, Green Park, New Delhi
2. Joint Commissioner of Police (Lic), 1<sup>st</sup> Floor, Police Station, Defence Colony, New Delhi.
3. Dinaz Madhukar, M/s Eat Food Lounge, 1<sup>st</sup> Floor, DLF Promenade Mall Building, Plot No.3, Nelson Mandela Marg, Vasant Kunj, New Delhi-110070.

**Conditions for the validity of fire safety certificate:**

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. The owner/ occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
5. This fire safety certificate may not in any way be treated as regularization of unauthorized construction, if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry."
7. The seating plan attached/overleaf with direction that clear aisles shall be maintained by food court as marked on plan.



## INSPECTION REPORT

1. Name & address of the building: Eat Food Lounge, located at 1<sup>st</sup> Floor, Plot No. 3, Promenade Mall, Nelson Mandela Road, Vasant Kunj, New Delhi-110070.
2. Type of Occupancy : Group D Assembly Building[**Building is Two tier Basement, Lower Ground floor, Upper Ground Floor, 1st Floor and Projection Room**]
3. Type of Case : New [Eat Food Lounge is approved in plans of Mall and running at 1<sup>st</sup> floor only]
4. Details of Previous NOC : NA
5. Fire Safety directives letter No : Nil
6. Date of inspection : 17/10/2016
7. Name of Inspecting Officer : A.K. Malik
8. Name and designation of officers  
From the building side : Mr. Manish (Fire Officer)
9. Year of Construction : 2005
10. Applicant's letter No. : DHO/SZ/2016/D/1191 dated 30/09/2016

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC/BBL Requirement	Provided at site	Remarks MR/NMR
1.	<b>Access to building</b> [DLF Promenade Mall FSC No. of F6/DFS/MS/2014/SZ/881 dated 17/07/14]			
	<ul style="list-style-type: none"> <li>• Road width</li> <li>• Gate width</li> <li>• Width of internal road</li> </ul>	Eat Food Lounge within Mall	As Above	MR
2.	<b>Number, Width, Type &amp; Arrangement of Exits</b> [Provided & Maintained by Mall management]			
	a. Number of staircases			
	<ul style="list-style-type: none"> <li>• Upper Floors</li> <li>• Basements</li> </ul>	Eat Food Lounge within Mall	As Above	MR
		Eat Food Lounge within Mall	As Above	NA
	b. Width of staircases			
	<ul style="list-style-type: none"> <li>• Upper Floor</li> <li>• Basement</li> </ul>	Eat Food Lounge within Mall	As Above	MR
		Eat Food Lounge within Mall	As Above	NA
	c. Protection of exits			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Pressurization</li> </ul>	Eat Food Lounge within Mall	As Above	NA
		Eat Food Lounge within Mall	As Above	NA
		Eat Food Lounge within Mall	As Above	NA
	d. No. of continuous staircases to terrace	Eat Food Lounge within Mall	As Above	NA
	e. Width of Corridor	Eat Food Lounge within Mall	As Above	NA
	f. Door Size	NA	NA	NA
3.	<b>Compartmentation</b>			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Sealing of electrical shafts</li> <li>• Fire Rating of shaft door</li> <li>• Water Curtain</li> <li>• Fire Dampers</li> </ul>	Eat Food Lounge within Mall	As Above	NA
		Eat Food Lounge within Mall	As Above	NA
		Eat Food Lounge within Mall	As Above	NA
		Eat Food Lounge within Mall	As Above	NA
		Eat Food Lounge within Mall	As Above	NA
4.	<b>Smoke Management System</b> [Provided & Maintained by Mall management]			
	<ul style="list-style-type: none"> <li>• Basements</li> <li>• Upper floors</li> </ul>	30 ACPH	As Above	NA
		12 ACPH	As Above	MR
5.	<b>Fire Extinguishers</b>			
	<ul style="list-style-type: none"> <li>• Total numbers</li> <li>• Types</li> </ul>	12 No's ISI marked	24 Nos ABC/CO <sub>2</sub> /W. CO <sub>2</sub> -8/8/8 Nos	MR
	<ul style="list-style-type: none"> <li>• IS marking</li> </ul>		Yes	MR
6.	<b>First-Aid Hose Reels</b> [Provided & Maintained by Mall management]			
	<ul style="list-style-type: none"> <li>• Total numbers on each floor</li> <li>• Length of hose reel hose</li> <li>• Nozzle diameter</li> </ul>	TWO(Near to Restaurant) 30 m 5 mm	As Above	MR
			As Above	MR
			As Above	MR
7.	<b>Automatic fire detection and alarming system</b> [Provided & Maintained by Mall management]			
	<ul style="list-style-type: none"> <li>• Type of detectors</li> <li>• Location of Main Panel</li> <li>• Location of Repeater Panel</li> </ul>	NA NA NA	As Above	NA
			As Above	NA
			As Above	NA



8.	MOEFA	Required	Provided	MR
9.	Public Address System	NA	As Above	NA
10.	<b>Automatic Sprinkler System</b> [Provided & Maintained by Mallmanagement]			
	• Basement	NA	As Above	NA
	• Ground Floor	NA	As Above	NA
	• Sprinkler above false ceiling	NA	As Above	NA
11.	<b>Internal Hydrants</b> [Provided & Maintained by Mall management]			
	• Size of riser/down-comer	100mm	As Above	MR
	• Number of hydrants per floor	Two (near to Restaurant)	As Above	MR
	• Hose Box	Two (near to Restaurant)	As Above	MR
12.	<b>Yard Hydrants</b> [Provided & Maintained by Mall management]			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	<b>Pumping Arrangements</b> [Provided & Maintained by Mall management]			
	• Ground Level			
	➤ Discharge of main Pump	NA	NA	NA
	➤ Head of Main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey Pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Starting/Manual Stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	[Provided & Maintained by Mall management]		
	➤ Head of the pump	900 LPM	As Above	MR
	➤ Power Supply	40 M	As Above	MR
	➤ Auto Starting of pump	Required	As Above	MR
		Required	As Above	MR
14.	<b>Captive Water Storage for firefighting</b> [Provided & Maintained by Mall management]			
	• Underground tank capacity	NA	As Above	NA
	➤ Draw-off connection	NA	As Above	NA
	➤ Fire service inlet	NA	As Above	NA
	➤ Access to tank	NA	As Above	NA
	• Overhead Tank capacity	15,000 Lts	As Above	MR
15.	<b>Exit Signage.</b>	Required	Provided	MR
16.	<b>Provision of Lifts.</b> [Provided & Maintained by Mallmanagement]			
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift lobby	NA	NA	NA
	• Communication In lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
17.	<b>Standby power supply</b>	Required	Provided	MR
18.	<b>Refuge Area.</b> [Provided & Maintained by Mall management]			
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	<b>Fire Control Room</b> [Provided & Maintained by Mall management]			
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Batter backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20.	<b>Special Fire Protection System for Protection of special Risks, if any:</b>	NA	NA	NA

- N/3 -

Eat Food Lounge, 1<sup>st</sup> Floor, Plot No. 3, Promenade Mall, Nelson Mandela Road, Vasant Kunj, New Delhi-110070

Keeping in view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules, It is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010.

Accordingly FSC in shape of DFA is put up for approval.

*A.K. Malik*  
21/10/16

Signature of Inspecting Officer  
Name:- A.K. Malik  
Designation:- DO (SD)



Dy. CFO (SZ)

*[Signature]*  
24/10

24/10/16  
1187-

352 / CFO (SZ)  
26/10/16/21/X

pr speak  
28/10

DCFO SZ / DOS D  
Sponen with DO S-2  
The resumed DFA / FT to be put up.

m. self / DOS D.

Leantat  
31/10.