

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

No. F6/DFS/MS/EH/2016/SZ/ 1618

Dated: 31/10/16

FIRE SAFETY CERTIFICATE

Certified that the **Madhuban Restaurant, 18-19, Community Center, PVR Saket, New Delhi-110017**, comprised of Basement, Ground plus three upper floors (Restaurant is running at first floor only with seating capacity of 140 persons) was granted FSC by this department vide letter No. F.6/DFS/MS/EH/2013/SZ/890 dated 09/09/2013. The premises was re-inspected by the officer concerned of this department on 14.10.2016 in the presence of Mr. Navin, (Manager) and found that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fir for occupancy class **Group-D Assembly Building (Restaurant) at first floor only** with effect from 31/10/16 for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 31/10/16 at New Delhi by


Vipin Kental
Chief Fire Officer
Ph.: 011-23412225

Copy to: -

1. M/s Madhuban Restaurant, 18-19, Community Centre, PVR Saket, ND-110017
2. Dy. Health Officer, MCD, South Zone, Green Park, New Delhi.
3. Assistant Commissioner (Restt. Branch), O/o the Commissioner of Excise, Entt. & Tax, Govt. of NCT of Delhi, L & J Block, IP Estate, Vikas Bhawan, New Delhi-110002

Conditions for the validity of Fire Safety Certificate

1. All the fire safety and means of escape facilities shall be maintained in good working condition at all time. Any lapse rendering the fire safety or means of evacuation facilities non-functional shall be the responsibility of the management.
2. Building Sanctioning authority may verify any deviation with regard to construction/occupancy in the building. In case of any deviation, the fire safety certificate stands null & void.
3. The staff shall be trained for operating fire fighting system and mock evacuation drill be conducted at regular interval and record be maintained.
4. The basement shall be used strictly as per the provisions of Building Bye Laws.
5. The Owner/Occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules, 2010. The form is available on www.dfs.delhigovt.nic.in.
6. The Owner/Occupier shall apply for renewal of this Fire Safety Certificate to the Director in the form 'J' [sub rule (1) of rule 37] along with copy of this certificate, six months prior to its expiry. The form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1	Name & Address of the Building	MADHUBAN RESTAURANT, 18-19, COMMUNITY CENTRE, PVR SAKET, NEW DELHI-110017		
2	Type of Occupancy	Assembly Building "Group-D" Restaurant		
3	Building Comprised of	Basements, Ground + 03 upper floors		
4	Type of Case	Renewal		
5	Details of Previous NOC	F.6/DFS/MS/EH/2013/SZ/890 Dt. 09.09.2013		
6	Fire Safety Directives Letter No	Nil		
7	Date of Inspection	14.10.2016		
8	Name of the Inspecting Officers	ADO R.N. Singh		
9	Name & Designation of Officers from the building side	Mr. Navin (Manager)		
10	Year of construction	2005	Restaurant is running at First Floor only	
11	Applicant letter No.	Nil dated Nil Outdoor diary No. 9195 Dt. 14.09.2016		
S. No	Minimum standards on Fire Prevention and Fire Safety U/R 33	Old NOC 28.09.2005 Requirements	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	<ul style="list-style-type: none"> Road width Gate width Width of internal road 	<ul style="list-style-type: none"> Accessible N/A N/A 	<ul style="list-style-type: none"> Provided N/A N/A 	<ul style="list-style-type: none"> MR N/A N/A
2	Number, width, type and arrangements of exits.			
	a. Number of Staircase			
	<ul style="list-style-type: none"> Upper floors Basement floor 	<ul style="list-style-type: none"> Required N/A 	<ul style="list-style-type: none"> Two N/A 	<ul style="list-style-type: none"> MR N/A
	b. Width of Staircase			
	<ul style="list-style-type: none"> Upper floors Basement floor 	<ul style="list-style-type: none"> Required N/A 	<ul style="list-style-type: none"> 1.18 m & 1.35 m N/A 	<ul style="list-style-type: none"> MR N/A
	c. Protection of exits			
	<ul style="list-style-type: none"> Fire check door Pressurization 	<ul style="list-style-type: none"> Required N/A 	<ul style="list-style-type: none"> Provided N/A 	<ul style="list-style-type: none"> MR N/A
	d. No. of continuous staircase to terrace	One	One	MR
	e. Width of corridor	N/A	N/A	N/A
	f. Door size	Required	02 nos. 0.85 m & 01 no of 1.0 m)	MR (Old case)
3	Compartmentation.			
	<ul style="list-style-type: none"> Fire check door. Sealing of electrical shafts. Fire rating of shaft door. Water curtain Fire dampers. 	<ul style="list-style-type: none"> Required N/A N/A N/A N/A 	<ul style="list-style-type: none"> Provided N/A N/A N/A N/A 	<ul style="list-style-type: none"> MR N/A N/A N/A N/A
4.	Smoke Management system.			
	<ul style="list-style-type: none"> Basement Upper floors 	<ul style="list-style-type: none"> N/A Required 	<ul style="list-style-type: none"> N/A Exhaust fan 	<ul style="list-style-type: none"> N/A MR
5.	Fire Extinguishers.			
	<ul style="list-style-type: none"> Total numbers Types ISI Marking 	<ul style="list-style-type: none"> Portable Fire Extinguishers ISI Marked 	<ul style="list-style-type: none"> 05 Nos. ABC- 05 Nos. Provided 	<ul style="list-style-type: none"> MR MR MR
6.	First Aid Hose Reels.			
	<ul style="list-style-type: none"> Total numbers on each floor. Length of hose-reel hose. Nozzle Diameter 	<ul style="list-style-type: none"> Hose reels 	<ul style="list-style-type: none"> One on First floor 30 Mtr 05 mm 	<ul style="list-style-type: none"> MR MR MR

Renewal

Madhuban Restaurant, 18-19, Community Centre, PVR Saket

Yz

7	Automatic Fire Detection and Alarming system.			
	<ul style="list-style-type: none"> Type of detectors 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Location of Main Panel 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Location of Repeater Panel 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Alternate source of power 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Hooter's location 	N/A	N/A	N/A
8.	MOEFA	Required	Provided	MR
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Upper floors 	Required	Provided	MR
	<ul style="list-style-type: none"> Sprinkler above false ceiling 	N/A	N/A	N/A
11.	Internal Hydrants.			
	<ul style="list-style-type: none"> Size of Riser / Down-comer 	N/A	100 mm	MR
	<ul style="list-style-type: none"> Number of Hydrant per floor 	N/A	One on first floor	MR
	<ul style="list-style-type: none"> Hose box. 	N/A	One	MR
12.	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> 2. Hose box. 	N/A	N/A	N/A
13.	Pumping arrangements.			
	<ul style="list-style-type: none"> Ground Level 			
	<ul style="list-style-type: none"> ➤ Discharge of main pump. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Head of main pump. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Number of main pumps. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Jockey Pump output. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Jockey Pump head. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Standby Pump output. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Standby Pump head. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Auto Starting / Manual Stopping. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Access to pump house 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Terrace Level 			
	<ul style="list-style-type: none"> ➤ Discharge of pump. 	450 LPM	450 LPM	MR
	<ul style="list-style-type: none"> ➤ Head of pump. 	39 Mtr	39 Mtr	MR
	<ul style="list-style-type: none"> ➤ Power supply. 	Required	Provided	MR
	<ul style="list-style-type: none"> ➤ Auto starting of pump. 	N/A	Provided	N/A
14.	Captive water storage for Fire Fighting.			
	<ul style="list-style-type: none"> Underground tank capacity. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Draw-off connection. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Fire Service Inlet. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Access to tank. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Overhead tank capacity. 	5,000 Ltr.	Provided	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of lift shaft. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Pressurization of lift lobby. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Communication in lift car. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Fireman's switch. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Lift signage. 	N/A	N/A	N/A
17	Standby Power Supply	Required	Provided (DG Set)	MR
18.	Refuge Area			
	<ul style="list-style-type: none"> Total area 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Location 	N/A	N/A	N/A

hc


N/13

19.	Fire Control Room.			
	• Detector System Panel.	N/A	N/A	N/A
	• Flow Switch Panel.	N/A	N/A	N/A
	• PA system Panel.	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for the Protection of special Risk, if any :	N/A	N/A	N/A

The Fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter No. F.6/DFS/MS/EH/2013/SZ/890 Dt. 09.09.2013, renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended

Accordingly, DFA is put up for approval and signature please.


 Signature of the Inspecting Officer
 Name : R.N. Singh
 Designation: ADO

Renewal

Madhuban Restaurant, 18-19, Community Centre, PVR Saket

Div. Officer (SD)

Anilak
19/8/16

358/068
24/11/16/13/1X
Dy. CFO (S2)



deep
29/10

CFO (S2)

m. scell

FT/17

Ve
21/10