

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**

No. F6/DFS/MS/School/SZ/2016/ 1614

Dated: 31/10/16

**FIRE SAFETY CERTIFICATE**

Certified that the **Ravindra Memorial Public School located at Mandi Road Sultanpur, New Delhi-110030**, comprised of Ground + 01 upper floor was granted Fire Safety Certificate by this department vide letter No. F.6/DFS/MS/School/2012/3425 dated 18-09-2012. The premises was re-inspected by officer concerned of this department on 24.10.2016 in the presence of Mr. Virender Sing (Manager) of the school and found that said building have deemed complied with the fire prevention and fire safety arrangements in accordance with circular no. 262-362 dated 17/01/2005 issued by Director of Education and that the premises is fit for occupancy class **“Educational Building Group-B”** with effect from 31/10/ 2016 for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 31/10/16.....at New Delhi by

  
Vipin Kental  
Chief Fire Officer  
Ph.: 011-23412225  
h-

**Copy to: -**

1. The Manager, Ravindra Memorial Public School, Mandi Road, Sultanpur, ND-30
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi.

**Conditions for the validity of Fire Safety Certificate**

1. All the fire safety and means of escape facilities shall be maintained in good working condition at all time. Any lapse rendering the fire safety or means of evacuation facilities non-functional shall be the responsibility of the management.
2. Building Sanctioning authority may verify any deviation with regard to construction/occupancy in the building. In case of any deviation, the fire safety certificate stands null & void.
3. The staff shall be trained for operating fire fighting system and mock evacuation drill be conducted at regular interval and record be maintained.
4. The basement shall be used strictly as per the provisions of Building Bye Laws.
5. The Owner/Occupier shall submit a declaration every year in form ‘K’ provided in the first schedule of Delhi Fire Service Rules, 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
6. The Owner/Occupier shall apply for renewal of this Fire Safety Certificate to the Director in the form ‘J’ [sub rule (1) of rule 37] along with copy of this certificate, six months prior to its expiry. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).

N/G

**INSPECTION REPORT**

1	Name & Address of the Building	Ravindra Memorial Public School, Village Sultanpur Mandi Road, New Delhi-110030		
2	Type of Occupancy	Educational Building "Group-B" (School)		
3	Building Comprised of	Ground + 01 upper floor		
4	Type of Case	Renewal		
5	Details of Previous NOC	F.6/DFS/MS/School/3425 dated 18/09/2012		
6	Fire Safety Directives Letter No	DOE Circular No. 262-362 dated 17-01-2005		
7	Date of Inspection	24/10/2016		
8	Name of the Inspecting Officers	ADO R.N. Singh		
9	Name & Designation of Officers from the building side	Mr. <del>Vijinder</del> Singh (Manager)		
10	Year of construction	2000		
11	Applicant letter No.	Nil Dt.15.09.2016 outdoor diary no. 9309 Dt. 15/09/2016		
<b>S. No</b>	<b>Minimum standards on Fire Prevention and Fire Safety U/R 33</b>	<b>Old NOC Dt 22.06.2006 Requirements</b>	<b>Provided at Site</b>	<b>Remarks MR/NMR</b>
<b>1</b>	<b>Access to Building.</b>			
	1. Road width	Accessible	5 mtr	MR
	2. Gate width	N/A	4 Mtr	N/A
	3. Width of internal road	N/A	N/A	N/A
<b>2</b>	<b>Number, width, type and arrangements of exits.</b>			
	<b>a. Number of Staircase</b>			
	1. Upper floors	One	One	MR
	2. Basement floor	N/A	N/A	N/A
	<b>b. Width of Staircase</b>			
	1. Upper floors	1.50 mtr.	1.50 mtr.	MR
	2. Basement floor	N/A	N/A	N/A
	<b>c. Protection of exits</b>			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	<b>d. No. of continuous staircase to terrace</b>	One	One	MR
	<b>e. Width of corridor</b>	N/A	N/A	N/A
	<b>f. Door size</b>	1.0 mtr	1.0 mtr	MR
<b>3</b>	<b>Compartmentation.</b>			
	1. Fire check door.	N/A	N/A	N/A
	2. Sealing of electrical shafts.	N/A	N/A	N/A
	3. Fire rating of shaft door.	N/A	N/A	N/A
	4. Water curtain	N/A	N/A	N/A
	5. Fire dampers.	N/A	N/A	N/A
<b>4.</b>	<b>Smoke Management system.</b>			
	1. Basement	N/A	N/A	N/A
	2. Upper floors	N/A	Open corridor	N/A
<b>5.</b>	<b>Fire Extinguishers.</b>			
	1. Total numbers	Portable fire extinguishers ISI Marked	06 Nos.	MR
	2. Types		ABC-05 & Co2-01	MR
	3. ISI Marking		Provided	MR
<b>6.</b>	<b>First Aid Hose Reels.</b>			
	1. Total numbers on each floor.	Hose - reel	One	MR
	2. Length of hose-reel hose.		30 mtr	MR
	3. Nozzle Diameter		05 mm	MR

Renewal

Ravindra Memorial Public School, Mandi Road, Sultanpur

k-



7	<b>Automatic Fire Detection and Alarming System.</b>			
	1. Type of detectors	N/A	N/A	N/A
	2. Location of Main Panel	N/A	N/A	N/A
	3. Location of Repeater Panel	N/A	N/A	N/A
	4. Alternate source of power	N/A	N/A	N/A
	5. Hooter's location	N/A	N/A	N/A
8.	<b>MOEFA / SIREN</b>	N/A	N/A	N/A
9.	<b>Public Address System</b>	N/A	N/A	N/A
10.	<b>Automatic Sprinkler System</b>			
	1. Basement.	N/A	N/A	N/A
	2. Upper floors	N/A	N/A	N/A
	3. Sprinkler above false ceiling	N/A	N/A	N/A
11.	<b>Internal Hydrants.</b>			
	1. Size of Riser / Down-comer	N/A	N/A	N/A
	2. Number of Hydrant per floor	N/A	N/A	N/A
	3. Hose box.	N/A	N/A	N/A
12.	<b>Yard Hydrants.</b>			
	1. Total number of hydrants.	N/A	N/A	N/A
	2. Hose box.	N/A	N/A	N/A
13.	<b>Pumping arrangements.</b>			
	<b>a. Ground Level</b>			
	➤ Discharge of main pump.	N/A	N/A	N/A
	➤ Head of main pump.	N/A	N/A	N/A
	➤ Number of main pumps.	N/A	N/A	N/A
	➤ Jockey Pump output.	N/A	N/A	N/A
	➤ Jockey Pump head.	N/A	N/A	N/A
	➤ Standby Pump output.	N/A	N/A	N/A
	➤ Standby Pump head.	N/A	N/A	N/A
	➤ Auto Starting / Manual Stopping.	N/A	N/A	N/A
	➤ Pump house access.	N/A	N/A	N/A
	<b>b. Terrace Level</b>			
	➤ Discharge of pump.	Boosting pump	220 LPM	MR
	➤ Head of pump.	Required	40 mts	MR
	➤ Power supply.	Required	Provided	MR
	➤ Auto starting of pump.	Required	Provided	MR
14.	<b>Captive water storage for Fire Fighting.</b>			
	1. Underground tank capacity.	N/A	N/A	N/A
	2. Draw-off connection.	N/A	N/A	N/A
	3. Fire Service Inlet.	N/A	N/A	N/A
	4. Access to tank.	N/A	N/A	N/A
	5. Overhead tank capacity.	2,500 Ltr	Provided	MR
15.	<b>Exit Signage.</b>	N/A	N/A	N/A
16.	<b>Provision of Lifts.</b>			
	1. Pressurization of lift shaft.	N/A	N/A	N/A
	2. Pressurization of lift lobby.	N/A	N/A	N/A
	3. Communication in lift car.	N/A	N/A	N/A
	4. Fireman's switch.	N/A	N/A	N/A
	5. Lift signage.	N/A	N/A	N/A
17	<b>Standby Power Supply</b>	N/A	N/A	N/A
18.	<b>Refuge Area</b>			
	1. Total area	N/A	N/A	N/A
	2. Location	N/A	N/A	N/A

N/8

19.	<b>Fire Control Room.</b>			
	1. Detector System Panel.	N/A	N/A	N/A
	2. Flow Switch Panel.	N/A	N/A	N/A
	3. PA system Panel.	N/A	N/A	N/A
	4. Battery backup	N/A	N/A	N/A
	5. Building floor plan	N/A	N/A	N/A
20.	<b>Special Fire Protection System for the Protection of special Risk, if any.</b>	N/A	N/A	N/A

The Fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the circular of Directorate of Education dated 17.01.2005, FSC issued vide letter No. F.6/DFS/MS/School/2012/3425 dated 18.09.2012, renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended

Accordingly DFA is put up for approval and signature please.

*R.N. Singh*  
26/11/16

Signature of the Inspecting Officer  
Name : R.N. Singh  
Designation: ADO

Renewal

Ravindra Memorial Public School, Mandi Road Sultanpur

Div. Officer (SD)

*[Signature]*  
26/11/16



*[Signature]*  
Dy. CFO (S2)

*[Signature]*  
28/11

367/CFO S2  
28/11

CFO S2

M. S. Gill

FTD.

*[Signature]*  
28/11/16