

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE  
NEW DELHI-110 001.

No.F.6/DFS/MS/School/2016/SZ

1611

Dated: 31-10-16

FIRE SAFETY CERTIFICATE

Certified that the **Star Shine Public School**, Plot No.84-85, Block K-5, Mohan Garden (Near Vikrant Chowk), Uttam Nagar, New Delhi-110059, owned/occupied by the Star Shine Public School was issued FSC for Ground plus one upper floor by this department vide letter no. F6/DFS/MS/School/2013/1039 dated 07.10.2013. The school was re-inspected by the officer concerned of this department on 13.10.2016 in the presence of Sh. Mahender Rampal (Manager). The Star Shine Public School comprised of ground plus one upper floor of a three storied building have deemed complied with the fire prevention and fire safety requirements in accordance with the Circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by the Director of Education and that the building/ premises (Ground plus one upper floor only) is fit for occupancy class "Educational" for a period of three years, subject to compliance of the conditions printed as under.

Issued on.....31-10..... at New Delhi.

(VIPIN KENTAL)  
CHIEF FIRE OFFICER

Copy to:-

1. The Manager,  
Star Shine Public School, Plot No.84-85, Block K-5,  
Mohan Garden (Near Vikrant Chowk), Uttam Nagar,  
New Delhi-110059.
2. Director of Education,  
Govt. of NCT of Delhi, Old Secretariat,  
New Delhi - 110054.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

School building is comprised of ground plus one upper floor in three storied building.

### INSPECTION REPORT

1. Name & address of the building : Star Shine Public School, Plot No.84-85, Block K-5, Mohan Garden (Near Vikrant Chowk), Uttam Nagar, New Delhi-110059.
2. Type of Occupancy : Educational
3. Type of Case : Renewal
4. Details of Previous NOC : F6/DFS/MS/School/2013/1039 dated 07.10.2013
5. Fire Safety directives letter No : Circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011
6. Date of inspection : 13.10.2016
7. Name of Inspecting Officer : A.D.O. Sandeep Duggal
8. Name and designation of officers  
From the building side : Sh. Mahender Rampal (Manager)
9. Year of Construction : 2004-2005
10. Applicant's letter No. : Nil dated 22.09.2016

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Dir. Of Edu. Circular dt. 01.03.2011	Provided at site	Remarks MR/NMR
1.	<b>Access to building</b>			
	<ul style="list-style-type: none"> <li>• Road width</li> <li>• Gate width</li> <li>• Width of internal road</li> </ul>	Old Case Old Case N/A	4.5 mtrs 3.05 & 1.17 mtrs N/A	M/R, being old case M/R, being old case N/A
2.	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			
	<ul style="list-style-type: none"> <li>• Upper Floors</li> <li>• Basements</li> </ul>	02 No.'s N/A	02 No.'s N/A	MR N/A
	b. Width of staircases			
	<ul style="list-style-type: none"> <li>• Upper Floor</li> <li>• Basements</li> </ul>	Old Case N/A	110 & 94 cms N/A	M/R, being old case N/A
	c. Protection of exits			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Pressurization</li> </ul>	N/A N/A	N/A N/A	N/A N/A
	d. No. of continuous staircases to terrace	Required (02)	Two	MR
	e. Width of Corridor	150 cms	180 cms	MR
	f. Door Size	Old case	85 cms	M/R, being old case
3.	<b>Compartmentation</b>			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Sealing of electrical shafts</li> <li>• Fire Rating of shaft door</li> <li>• Water Curtain</li> <li>• Fire Dampers</li> </ul>	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A
4.	<b>Smoke Management System</b>			
	<ul style="list-style-type: none"> <li>• Basement</li> <li>• Upper floors</li> </ul>	N/A Required	N/A Natural ventilation	N/A MR
5.	<b>Fire Extinguishers</b>			
	<ul style="list-style-type: none"> <li>• Total numbers</li> <li>• Types</li> <li>• IS marking</li> </ul>	05 no's ABC type ISI marked	Provided Provided Provided	MR MR MR
6.	<b>First-Aid Hose Reels</b>			
	<ul style="list-style-type: none"> <li>• Total numbers on each floor</li> </ul>	N/A	01 no. Provided	N/A

## INSPECTION REPORT

1. Name & address of the building : Star Shine Public School, Plot No.84-85, Block K-5, Mohan Garden (Near Vikrant Chowk), Uttam Nagar, New Delhi-110059.
2. Type of Occupancy : Educational
3. Type of Case : Renewal
4. Details of Previous NOC : F6/DFS/MS/School/2013/1039 dated 07.10.2013
5. Fire Safety directives letter No : Circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011
6. Date of inspection : 13.10.2016
7. Name of Inspecting Officer : A.D.O. Sandeep Duggal
8. Name and designation of officers  
From the building side : Sh. Mahender Rampal (Manager)
9. Year of Construction : 2004-2005
10. Applicant's letter No. : Nil dated 22.09.2016

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Dir. Of Edu. Circular dt. 01.03.2011	Provided at site	Remarks MR/NMR
1.	<b>Access to building</b>			
	<ul style="list-style-type: none"> <li>• Road width</li> <li>• Gate width</li> <li>• Width of internal road</li> </ul>	Old Case Old Case N/A	4.5 mtrs 3.05 & 1.17 mtrs N/A	M/R, being old case M/R, being old case N/A
2.	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			
	<ul style="list-style-type: none"> <li>• Upper Floors</li> <li>• Basements</li> </ul>	02 No.'s N/A	02 No.'s N/A	MR N/A
	b. Width of staircases			
	<ul style="list-style-type: none"> <li>• Upper Floor</li> <li>• Basements</li> </ul>	Old Case N/A	110 & 94 cms N/A	M/R, being old case N/A
	c. Protection of exits			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Pressurization</li> </ul>	N/A N/A	N/A N/A	N/A N/A
	d. No. of continuous staircases to terrace	Required (02)	Two	MR
	e. Width of Corridor	150 cms	180 cms	MR
	f. Door Size	Old case	85 cms	M/R, being old case
3.	<b>Compartmentation</b>			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Sealing of electrical shafts</li> <li>• Fire Rating of shaft door</li> <li>• Water Curtain</li> <li>• Fire Dampers</li> </ul>	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A
4.	<b>Smoke Management System</b>			
	<ul style="list-style-type: none"> <li>• Basement</li> <li>• Upper floors</li> </ul>	N/A Required	N/A Natural ventilation	N/A MR
5.	<b>Fire Extinguishers</b>			
	<ul style="list-style-type: none"> <li>• Total numbers</li> <li>• Types</li> <li>• IS marking</li> </ul>	05 no's ABC type ISI marked	Provided Provided Provided	MR MR MR
6.	<b>First-Aid Hose Reels</b>			
	<ul style="list-style-type: none"> <li>• Total numbers on each floor</li> <li>• Length of hose reel hose</li> <li>• Nozzle diameter</li> </ul>	N/A N/A N/A	01 no. Provided Provided Provided	N/A N/A N/A



19.	<b>Fire Control Room</b>			
	<ul style="list-style-type: none"> <li>• Detector System Panel</li> <li>• Flow Switch Panel</li> <li>• PA System Panel</li> <li>• Battery backup</li> <li>• Building Floor Plans</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
20.	<b>Special Fire Protection System for Protection of special Risks, if any:</b>	N/A	N/A	N/A

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter number F6/DFS/MS/School/2013/1039 dated 07.10.2013 renewal in accordance with the Circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by the Director of Education is recommended.

Note:- As per the letter submitted by the Manager the school is running at ground floor plus one upper floor in a three storied building and second floor is being used for personal purpose only (placed at C-12).

*Sandeep*  
*21/10/16*

Signature of Inspecting Officer

Name:- Sandeep Duggal

Designation:- Asstt. Divisional Officer

~~D.O. (South West)~~

*[Signature]*  
*21/10/16*



*DCFO (SZ)*

*[Signature]*