

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001

No. F 6/DFS/MS/School/2016/1623

Dated: 03.11.16

FIRE SAFETY CERTIFICATE

Certified that the **Mata Sukhdevi Public School** located at **G.T.K. Road, Nangli Poona, Delhi-36** comprised of ground and first floor owned/occupied by the **Mata Sukhdevi Public School** was granted fire safety certificate vide this office letter no. **F.6/DFS/MS/2009/2357 dated 30/07/2009**. The premises was re-inspected by the officer and observed that the existing building is now comprised of ground and 02 upper floors but school is running at ground & first floor only. The school have deemed complied with the fire prevention and safety requirements in accordance with requirements of circular issued by Director of Education letter no. 3298-3398 dated 01.03.2011 and verified by the officer concerned of Fire Service on 25.10.2016 in presence of **Mrs. Lalita Yadav**, Manager and that the building/premises is fit for occupancy Group B Education for **ground and first floor only** with effect from....03.11.16.... for a period of three years, subject to compliance of the conditions mentioned below:

Conditions for the Validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc. shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
7. The owner/occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.Delhigovt.nic.in

Issued on 03.11.16 at New Delhi


(Atul Garg)

Chief Fire Officer

Ph:- 011-23414250

Copy to:-

1. The Director Education, Government of N.C.T of Delhi, Old Sectt., Delhi-54.
2. The Principal, Mata Sukhdevi Public School, G.T.K. Road, Nangli Poona, Delhi-36.

INSPECTION REPORT

1. Name & address of the building : Mata Sukhdevi Public School, G.T.K.Road, Nangli Poona, Delhi-36.
2. Type of Occupancy : Educational
3. Type of Case : Addl./Alt. – (G +02 floors), **School is running on Ground + 01 floor**
4. Details of previous NOC : F6/DFS/MS/2009/2357 dated 30.07.2009 (G+01 Floor bldg)
5. Fire Safety directives letter No : As per Director of Education circular dated 01.03.2011
6. Date of inspection : 25/10/2016
7. Name of the Inspecting Officers : ADO (RN)
8. Name and designation of officers from the building side : Mrs Lalita Yadav/ Manager
9. Year of Construction :
10. Applicant's letter No. : 402 dated 18.10.2016.

Plot Area-19484.60 sqm Covered Area: sq.yard, class rooms –36 nos , students---822 nos

	Minimum Standards on fire prevention and fire safety U/R 33	Director of education circular	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	06m	6m	MR
	• Gate width	4.5m	4.5m	MR
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors			
	• Basements	01	01	MR
	b. Width of staircases			
	• Upper Floors	NA	NA	NA
		1.50m	1.50m- iron staircase(old case)	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
• Pressurization	NA	NA	NA	
d. No. of continuous staircases to terrace	NA	NA	NA	

	e. Width of Corridor	NA	NA	NA
	f. Door Size	1 m	01m	MR
3	Compartmentation.			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System.			
	• Basements	30 a/c per hour	NA	NA
	• Upper floors	12 a/c per hour	Natural Ventilated	MR
5	Fire Extinguishers			
	• Total numbers	08 nos	10 nos	MR
	• Types	ABC	ABC	MR
	• ISI marking	ISI Marked	Yes	MR
6	First-Aid Hose Reels.			
	• Total numbers on each floor	01	Provided	MR
	• Length of hose reel hose	30m	Provided	MR
	• Nozzle diameter	5mm	Provided	MR
7	Automatic fire detection and alarming system.			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8	MOEFA			
		NA	NA	NA
9	Public Address System.			
		NA	NA	NA
10	Automatic Sprinkler System.			
	• Basement	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA

1/7

11	Internal Hydrants			
	<ul style="list-style-type: none"> • Size of riser/down-comer • Number of hydrants per floor • Hose Box 	NA	NA	NA
		NA	NA	NA
NA		NA	NA	
12	Yard Hydrants.			
	<ul style="list-style-type: none"> • Total number of hydrants • Hose Box 	NA	NA	NA
		NA	NA	NA
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> • Ground Level <ul style="list-style-type: none"> ➤ Discharge of main Pump ➤ Head of Main pump ➤ Number of main pumps ➤ Jockey Pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/ Manual stopping ➤ Pump House Access • Terrace level <ul style="list-style-type: none"> ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 			
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
14		Captive Water Storage for fire fighting.		
	<ul style="list-style-type: none"> • Underground tank capacity <ul style="list-style-type: none"> ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		2500 ltrs	2500 ltr(Old case)	MR
15	Exit Signage.	NA	NA	NA
16	Provision of Lifts.			
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby 	N/A	N/A	N/A
		N/A	N/A	N/A

l

N/A


	<ul style="list-style-type: none">• Communication In lift Car	N/A	N/A	N/A
	<ul style="list-style-type: none">• Fireman's Grounding Switch	N/A	N/A	N/A
	<ul style="list-style-type: none">• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	<ul style="list-style-type: none">• Detector System Panel	N/A	N/A	N/A
	<ul style="list-style-type: none">• Flow Switch Panel	N/A	N/A	N/A
	<ul style="list-style-type: none">• PA System Panel	N/A	N/A	N/A
	<ul style="list-style-type: none">• Batter backup	N/A	N/A	N/A
	<ul style="list-style-type: none">• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A

Accordingly, the fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection.

Keeping in view the satisfactory compliance of the minimum standards on fire prevention and fire safety required as stipulated in Director of Education Circular dated 17.01.2005 the FSC issued vide letter of even no.2357 dated 30.07.2009 renewal under rule 35 of the Delhi Fire Service Rules, 2010 is recommended

DO/NOO
S Singh
27.10.16
Dy CEO (WZ)


11/11/16


Signature of the Inspecting Officer
Name :- Rajesh Kumar
Designation:- ADO/RN