

FORM 'H'  
FORM FOR ISSUING FIRE SAFETY CERTIFICATE  
[Refer sub - rule (1) of rule 35]  
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE, NEW DELHI

No. F6/DFS/MS/Cinema/2016/21/1627

Dated: 03-11-16

**FIRE SAFETY CERTIFICATE**

Certified that the **Milan Cinema located at Karampura, New Delhi-110015** in a building comprised of Ground + Mezzanine + 02 Upper Floors was issued FSC vide Letter No. **F6/DFS/MS/Cinema/2015/115** dated **02/06/15**. The premises was re-inspected by the officers concerned of this department on **19-10-2016** in the presence of **Sh. Sobhraj (Manager)** and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and that the premises is fit for occupancy class "Assembly Building" Group D with effect from 03-11-16 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on .....03-11-16..... at New Delhi by.

  
(Atul Garg)

Chief Fire Officer  
Delhi Fire Service



Copy to:

1. **Sh. Sobhraj (Manager),**  
**Milan Cinema located at Karampura, New Delhi-110015**
2. **Sh. Ravindra Singh SDM (HQ-I/DDMA)**  
GNCT of Delhi, Old Middle School Complex, Rampura, Delhi - 110035

**Following fire safety directives must be adhered to:-**

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used as per building bye laws.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
9. FSC is issued for cinema only.

## INSPECTION REPORT

1. Name & address of the building : **Milan Cinema located at Karampura, New Delhi-110015**
2. Type of Occupancy : **Assembly**
3. Type of Case : **Renewal**
4. Details of previous NOC : **F6/DFS/MS/Cinema/2015/115 dated 02/06/15**
5. Fire Safety directives Letter No. : ~~6/DFS/MS/DP/00/Ci/11/100-1/11/09-05/200~~ **NIL**
6. Date of inspection : **19-10-2016**
7. Name of the Inspecting Officer : **Udai Vir Singh, ADO (MN)**
8. Name and designation of Officer  
from the building side : **Sh. Sobhraj (Manager)**
9. Year of Construction : **1981**
10. Applicant's letter No. : **F.81/DDMA)(W)LCT/MILAN(K.P.)/2015/03 dated 11/08/16**

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	9 m	20m Provided	MR
	• Gate width	6 m	06m Provided	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	03	03 Provided	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	2 mtr	2 x 163cm & 1 x 310cm	MR (Old Case)
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	Required	Provided	MR
	d. No of continuous staircase to terrace	Required	Provided	MR
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	10 exit Hall 5 exit Balcony	10 exit- Hall Provided 5 exit -Balcony Provided	MR (Being old case)
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA
5.	Fire Extinguishers			
	• Total numbers	20 nos.	20nos. Provided	MR
	• Types	ABC,CO2, ISI marked	Provided	MR
	• IS marking		Provided	MR

6.	First – Aid Hose Reels			
	<ul style="list-style-type: none"> <li>Total numbers on each floor</li> </ul>	02 nos in first floor, 02 in 2 <sup>nd</sup> floor	Provided	MR
	<ul style="list-style-type: none"> <li>Length of hose reel hose</li> </ul>	30 m	Provided	MR
	<ul style="list-style-type: none"> <li>Nozzle diameter</li> </ul>	5 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> <li>Type of detectors</li> </ul>	Smoke/ Heat	Provided	MR
	<ul style="list-style-type: none"> <li>Location of Main Panel</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>Location of Repeater Panel</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>Alternate source of power</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>Hooters' Location</li> </ul>	Required	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> <li>Basements</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>Upper Floor</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>Sprinkler above false ceiling</li> </ul>	NR	NR	NR
11.	Internal Hydrants			
	<ul style="list-style-type: none"> <li>Size of riser/down- comer</li> </ul>	NR	NR	NR
	<ul style="list-style-type: none"> <li>Number of hydrants per floor</li> </ul>	NR	NR	NR
	<ul style="list-style-type: none"> <li>Hose Box</li> </ul>	NR	NR	NR
12.	Yard Hydrants			
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> </ul>	01 no	01 Provided	MR
	<ul style="list-style-type: none"> <li>Hose Box</li> </ul>	01 no	01 Provided	MR
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> <li>Ground Level</li> </ul>			
	<ul style="list-style-type: none"> <li>Discharge of main pump</li> </ul>	450 LPM	450 LPM Provided	MR(old case)
	<ul style="list-style-type: none"> <li>Head of main pump</li> </ul>	40 mtr	40 mtr provided	MR(old case)
	<ul style="list-style-type: none"> <li>Number of main pumps</li> </ul>	01	02 Provided	MR(old case)
	<ul style="list-style-type: none"> <li>Jockey pump out put</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Jockey pump head</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Standby Pump out put</li> </ul>	450 lpm	450 lpm Provided	MR(old case)
	<ul style="list-style-type: none"> <li>Standby Pump Head</li> </ul>	40 m	40 m Provided	MR(Old case)
	<ul style="list-style-type: none"> <li>Auto Staring/Manual stopping</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>Pump House Access</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>Terrace level</li> </ul>			
	<ul style="list-style-type: none"> <li>Discharge of pump</li> </ul>	450 LPM	450 LPM Provided	MR
	<ul style="list-style-type: none"> <li>Head of the pump</li> </ul>	40 mtr	40 mtr provided	MR
	<ul style="list-style-type: none"> <li>Power supply</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>Auto starting of pump</li> </ul>	Required	Provided	MR
14.	Captive water Storage for fire fighting			
	<ul style="list-style-type: none"> <li>Under ground tank capacity</li> </ul>	15,000 ltrs	15,000 ltrs Provided	MR
	<ul style="list-style-type: none"> <li>Draw of connection</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>Fire service inlet</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>Access to tank</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>Overhead Tank capacity</li> </ul>	23, 500 litres	Provided	MR
15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	<ul style="list-style-type: none"> <li>Pressurization of Lift Shaft</li> </ul>	NR	NR	NR
	<ul style="list-style-type: none"> <li>Pressurization of lift lobby</li> </ul>	NR	NR	NR
	<ul style="list-style-type: none"> <li>Communication in lift Car</li> </ul>	NR	NR	NR
	<ul style="list-style-type: none"> <li>Fireman's Grounding Switch</li> </ul>	NR	NR	NR
	<ul style="list-style-type: none"> <li>Lift Signage</li> </ul>	NR	NR	NR

19.	Fire control room			
	➤ Detector system panel	Required	Provided	MR
	➤ Flow Switch Panel	Required	Provided	MR
	➤ PA System Panel	Required	Provided	MR
	➤ Battery backup	Required	Provided	MR
	➤ Building Floor Plans	Required	Provided	MR
20.	Special Fire Protection Systems for Protection of special Risks, if any;	Required	CO <sub>2</sub> flooding system for the protection of HT/LT panels in the basement	MR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no. **F6/DFS/MS/Cinema/2015/115 dated 02/06/15** renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Signature of the Inspecting Officer  
Inspecting Officer

Name **Udai Vir Singh**

Designation **ADO (MN)**

Signature of the

Name **SH/Mukesh Verma**

Designation **DO(W)**

~~Dy CPO/W2~~  
~~29/10/16~~

~~CPO. In-charge~~  
~~27/10/16~~

~~DO/W~~  
~~Mukesh Singh~~  
~~27/10/16~~