

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No. F6/DFS/MS/School/2016/ND2/1635

Dated: 07-11-16

FIRE SAFETY CERTIFICATE

Certified that the Govt. Co-ed. Middle School at East Rohtas Nagar, Shahdara, Delhi-110032, comprised of ground floor, owned/occupied by the Govt. Co-ed. Middle School was issued FSC vide letter No-F6/DFS/MS/School/2013/431 dated 11/06/2013. The school building was re-inspected by the officer concerned of this department on 18/10/2016 in the presence of Mrs. Renuka Saxena, Incharge of the school and found that the school building have deemed complied with the fire prevention and fire safety requirements in accordance with Circular Letter No-F16 Estate/CC/FireSafety/2011/3298 to 3398 dt-01/03/11 issued by Director of Education and found that the school building is fit for occupancy class "B" 'Educational Building' for ground floor with effect from 07-11-16 for a period of **three** years, subject to conditions, printed overleaf.

Issued on 07-11-16 at New Delhi by


(Vipin Kental)
Chief Fire Officer
Delhi Fire Service

To,
The Principal
Govt. Co-ed. Middle School
East Rohtas Nagar, Shahdara, Delhi-110032

Copy:-

1. The Joint Director of Education,
(Land & Estate) Director of Education
Lucknow Road, Delhi-110054



CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.
7. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry.

1. Name & address of the building : Govt. Co-ed. Middle School,
East Rohtas Nagar, Shahdara, Delhi-110032
2. Building is comprised of : Ground floor ✓
3. Type of Occupancy : Educational
4. Type of Case : Renewal ✓
5. Details of Previous FSC letter : F6/DFS/MS/School/2013/431 dated-11/06/2013
6. Fire Safety direction letter No : F16/Estate/CC/FireSafety/2011/3298to3398 dt-01/03/11
7. Date of Inspection : 18/10/2016
8. Name of the Inspecting officers : ADO Vijay Bahadur
9. Name and designation of Officer from the building side : Mrs. Renuka Sexsena (Incharge)
10. Year of Construction : 1970
11. Applicant's letter No : No.-G(co-ed)MS/ERN/2016/689A, Dated-01/06/2016


Sr. No.	Minimum Standards on Fire Prevention and Fire Safety U/R33	Circular Requirement	Provided at Site	Remarks MR/NMR
01	Access to Building.			
	• Road width	06 mtr.	04 mtr.	MR (old accepted)
	• Gate width	04 mtr.	04 mtr.	MR
	• Width of internal road	N/A	N/A	N/A
02	Number, Width, Type and Arrangement of Exits.			
	a. Number of Staircases			
	• Upper floor	N/A	N/A.	N/A
	• Basement	N/A	N/A.	N/A
	b. Width of Staircases			
	• Upper floor	N/A	N/A.	N/A
	• Basement	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No. of Continuous Staircases to Terrace	N/A	N/A.	N/A
	e. Width of Corridor	1.50 mtr.	1.50 mtr.	MR ✓
	f. Door Size	01 mtr.	01 mtr.	MR ✓
03	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire dampers	N/A	N/A	N/A
04	Smoke Management System.			
	• Basement	N/A	N/A	N/A
	• Upper floor	N/A	N/A	N/A
05.	Fire Extinguishers.			
	• Total numbers	04 nos.	09 nos.	MR ✓
	• Types	ABC /CO ₂	ABC /CO ₂	MR
	• IS marking	ISI marked	ISI marked	MR ✓

06	First-Aid-Hose Reels.			
	Total numbers on each floor	N/A	N/A	N/A
	• Length of hose reel hose	N/A	N/A	N/A
	• Nozzle diameter	N/A	N/A	N/A
07	Automatic Fire Detection and Alarming System.			
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's location	N/A	N/A	N/A
08	MOEFA			
09	Public Address System.			
		N/A	N/A	N/A
10	Automatic Sprinkler System.			
	• Basement	N/A	N/A	N/A
	• upper floor	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose box	N/A	N/A	N/A
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose box	N/A	N/A	N/A
13	Pumping Arrangements.			
	➤ Ground Level			
	• Discharge of main pump	N/A	N/A	N/A
	• Head of main pump	N/A	N/A	N/A
	• Number of main pumps	N/A	N/A	N/A
	• Jockey pump out put	N/A	N/A	N/A
	• Jockey pump head	N/A	N/A	N/A
	• Standby pump out put	N/A	N/A	N/A
	• Standby pump head	N/A	N/A	N/A
	• Auto starting/manual stopping	N/A	N/A	N/A
	• Pump house access	N/A	N/A	N/A
	➤ Terrace Level			
	• Discharge of pump	N/A	N/A	N/A
	• Head of the pump	N/A	N/A	N/A
	• Power supply	N/A	N/A	N/A
	• Auto starting of pump	N/A	N/A	N/A
14	Captive Water Storage for Fire Fighting.			
	• Underground tank capacity	N/A	N/A	N/A
	• Draw-off connection	N/A	N/A	N/A
	• Fire service inlet	N/A	N/A	N/A
	• Access to tank	N/A	N/A	N/A
	• Overhead tank capacity	N/A	N/A	N/A
15	Exit Signage.			
		N/A	N/A	N/A

16	Provision of Lifts.			
	<ul style="list-style-type: none"> • Pressurization of lift shaft • Pressurization of lift lobby • Communication in lift car • Firemen's grounding switch • Lift signage 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
17	Standby Power Supply	N/A	N/A	N/A
18	Refuge Area.			
	<ul style="list-style-type: none"> • Total area • Location 	N/A	N/A	N/A
		N/A	N/A	N/A
19	Fire Control Room			
	<ul style="list-style-type: none"> • Detector system panel • Flow switch panel • PA system panel • Battery backup • Building floor plans 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of Special Risks, if any:	N/A	N/A	N/A


The fire protection systems provided in the building were tested/checked at the time of inspection.

In view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter No.- F6/DFS/MS/School/2013/431 dated-11/06/2013, renewal under the circular- F16/Estate/CC/FireSafety/2011/3298to3398 dt-01/03/11 is recommended.


19/11/16

Signature of the Inspecting Officer
Name- Vijay Bahadur
Designation- A.D.O. (T.Pur)

~~DO(ED)~~

Ring

19/10

~~DEFO(ND2)~~


19/X

58/CF-ND2
20/12/14/7/11

i.c F/O. FT M.