

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110 001

No. F6/DFS/MS/EH/2016/M02/1795

Dated: 16/12/16

**FIRE SAFETY CERTIFICATE**

Certified that M/s Café Connexion (A Unit of Devyani Food Street Pvt. Ltd.) located at 3<sup>rd</sup> Floor, Security Hold Area, International Departure side, Terminal 3, IGI Airport, New Delhi, comprised of two basements, Ground plus five upper floors but Restaurant is at third floor only, was granted No Objection Certificate by this department vide letter No. F6/MS/DFS/EH/2011/180, dated 31-01-2011. The premises was re-inspected by the officer concerned of this department on 06-12-2016 in the presence of Sh. Ashwani Arora, Manager and found that the said eating house at third floor only have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class Group-D Assembly Building(Eating House) at ground floor only with effect from 16/12/2016 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 16/12/2016 at New Delhi by.

16/12  
(Vipin Kental)

Chief Fire Officer

T.No.011-23412225

To:- 1. Joint Commissioner of Police Licensing, PS Defence Colony, New Delhi. o/c

2. M/s Café Connexion (A Unit of Devyani Food Street Pvt. Ltd.) located at 3<sup>rd</sup> Floor, Security Hold Area, International Departure side, Terminal 3, IGI Airport, New Delhi. kv

**Conditions for the validity of fire safety certificate are under:-**

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate in form J, six month prior to its expiry.

## INSPECTION REPORT

1. Name & address of the building: M/s Café Connexion (A Unit of Devyani Food Street Pvt. Ltd.)  
located at 3<sup>rd</sup> Floor, Security Hold Area, International Departure  
Side, Terminal 3, IGI Airport, New Delhi.
2. Building comprises of : B1+B2+G+5, but restaurant is at 3<sup>rd</sup> floor only.
3. Type of Occupancy : "Group-D" (Restaurant)
4. Type of Case : Renewal
5. Details of previous NOC : F6/DFS/MS/EH/2011/182, dated 31.01.2011.
6. Fire Safety directives Letter No. : F6/DFS/MS/2007/1781, dated 05.07.2007 for whole terminal.
7. Date of inspection : 06.12.2016
8. Name of the Inspecting Officer : Vedpal (ADO).
9. Name and designation of Officer  
from the building side : Sh. Ashwani Arora (Manager).
10. Year of Construction : 2010
11. Applicant's letter No. : 9289/Joint CP/Lic/EH(DA-I), Dated 19.10.2016.

S No	Minimum standards on fire prevention and fire safety U/R 33	Old NOC Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	<ul style="list-style-type: none"> <li>• Road width</li> <li>• Gate width</li> <li>• Width of internal road</li> </ul>	9 M 5 M 6 M	12M >5M > 6 M	MR MR MR
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases	Required	Provided	MR
	<ul style="list-style-type: none"> <li>• Upper floors</li> <li>• Basements</li> </ul>	02nos. Near Restaurant N.A.	02nos. Near Restaurant N.A.	MR N.A.
	b. Width of staircases			
	<ul style="list-style-type: none"> <li>• Upper floors</li> <li>• Basements</li> </ul>	1.5m N.A.	1.9m N.A.	MR N.A.
	c. Protection of exits			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Pressurization</li> </ul>	Required Required	Provided Provided	MR MR
	d. No of continuous staircase to terrace	01no.	01no.	MR
	e. Width Of Corridor	1.5 m	2.5 m	MR
	f. Door Size	2 m	No Door All Front side Open	MR
3.	Compartmentation			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Sealing of electrical shafts</li> <li>• Fire Rating of shaft door</li> <li>• Water Curtain</li> <li>• Fire Dampers</li> </ul>	Required Required 1 Hrs. N.A. Required	Provided Provided 1 Hrs. N.A. Provided	MR MR MR N.A. MR
4.	Smoke managements System			
	<ul style="list-style-type: none"> <li>• Basements</li> <li>• Upper floors</li> </ul>	30 a/c per hour 12 a/c per hour	N.A. Automatic Smoke Extraction System Provided.	N.A. MR
5.	Fire Extinguisher			

6.	First – Aid Hose Reels	Fire Fighting System is common for entire building		
	<ul style="list-style-type: none"> <li>Total numbers on each floor</li> </ul>	02Nos near Restaurant	02Nos near Restaurant	MR
	<ul style="list-style-type: none"> <li>Length of hose reel hose</li> </ul>	30m	30m	MR
	<ul style="list-style-type: none"> <li>Nozzle diameter</li> </ul>	6mm	6mm	MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> <li>Type of detectors</li> </ul>	Smoke & Heat	Smoke & Heat	MR
	<ul style="list-style-type: none"> <li>Location of Main Panel</li> </ul>	Ground floor	Ground floor	MR
	<ul style="list-style-type: none"> <li>Location of Repeater Panel</li> </ul>	FCC	FCC	MR
	<ul style="list-style-type: none"> <li>Alternate source of power</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>Hooters' Location</li> </ul>	Required	All areas	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System (Fire Fighting System is common for entire building)			
	<ul style="list-style-type: none"> <li>Basements</li> </ul>	N.A.	N.A.	N.A.
	<ul style="list-style-type: none"> <li>Upper Floor</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>Sprinkler above false ceiling</li> </ul>	N.A.	N.A.	N.A.
11.	Internal Hydrants (Fire Fighting System is common for entire building)			
	<ul style="list-style-type: none"> <li>Size of riser</li> </ul>	150 mm	200 mm	MR
	<ul style="list-style-type: none"> <li>Number of hydrants per floor</li> </ul>	02Nos near Restaurant	02Nos near Restaurant	MR
	<ul style="list-style-type: none"> <li>Hose Box</li> </ul>	02Nos near Restaurant	02Nos near Restaurant	MR
12.	Yard Hydrants (Fire Fighting System is common for entire building)			
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> </ul>	154nos.	154nos.	MR
	<ul style="list-style-type: none"> <li>Hose Box</li> </ul>	154nos.	154nos.	MR
13.	Pumping Arrangements (Fire Fighting System is common for entire building)			
	<ul style="list-style-type: none"> <li>Ground Level</li> </ul>			
	<ul style="list-style-type: none"> <li>Discharge of main pump</li> </ul>	2280 LPM(Each)	4731 LPM Sprinkler – 3785 LPM	MR
	<ul style="list-style-type: none"> <li>➤ Head of main pump</li> </ul>	70meters(Each)	130 Meter & 70 Meter	MR
	<ul style="list-style-type: none"> <li>➤ Number of main pumps</li> </ul>	01+01no.	01+01no.	MR
	<ul style="list-style-type: none"> <li>➤ Jockey pump out put</li> </ul>	280LPM(Each)	280LPM +280LPM	MR
	<ul style="list-style-type: none"> <li>➤ Jockey pump head</li> </ul>	70m(Each)	130m & 70m	MR
	<ul style="list-style-type: none"> <li>➤ Standby Pump out put</li> </ul>	2280(Each)	4731LPM & 3785LPM	MR
	<ul style="list-style-type: none"> <li>➤ Standby Pump Head</li> </ul>	70(Each)	130m & 80m	MR
	<ul style="list-style-type: none"> <li>➤ Auto Staring/Manual stopping</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>➤ Pump House Access</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>• Terrace level</li> </ul>	N.A.	N.A.	N.A.
	<ul style="list-style-type: none"> <li>➤ Discharge of pump</li> </ul>	N.A.	N.A.	N.A.
	<ul style="list-style-type: none"> <li>➤ Head of the pump</li> </ul>	N.A.	N.A.	N.A.
	<ul style="list-style-type: none"> <li>➤ Power supply</li> </ul>	N.A.	N.A.	N.A.
	<ul style="list-style-type: none"> <li>➤ Auto starting of pump</li> </ul>	N.A.	N.A.	N.A.
14.	Captive water Storage for fire fighting (Fire Fighting System is common for entire building)			
	<ul style="list-style-type: none"> <li>• Underground tank capacity</li> </ul>	6Lakh Liters	6 Lakh Liters	MR
	<ul style="list-style-type: none"> <li>➤ Draw off connection</li> </ul>	Required	Provided (6 Nos.)	MR
	<ul style="list-style-type: none"> <li>➤ Fire service inlet</li> </ul>	Required	Provided (06 Nos.)	MR
	<ul style="list-style-type: none"> <li>➤ Access to tank</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>• Overhead Tank capacity</li> </ul>	N.A.	N.A.	N.A.
15.	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	<ul style="list-style-type: none"> <li>➤ Pressurization of Lift Shaft</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>➤ Pressurization of Lift Hall</li> </ul>	Required	Provided	MR

N16  
N16 Cafe Connexion at 3rd floor, Terminal-3 IGI Airport.

17.	Standby power supply	Required	Provided (UPS/ DG Set)	MR
18.	Refuge Area			
	➤ Total area	N.A.	N.A.	N.A.
	➤ Location	N.A.	N.A.	N.A.
19.	Fire control room			
	➤ Detector system panel	Required	Provided	MR
	➤ Flow Switch Panel	Required	Provided	MR
	➤ PA System Panel	Required	Provided	MR
	➤ Batter backup	Required	Provided	MR
	➤ Building Floor Plans	Required	Provided	MR
20.	Special Fire Protection Systems for Protection of special Risks, if any;	Required	Gas Suppression system (NOVEC 1230, Co2 Flooding system, Trace tube and FM 200 in all electric panels and sub stations.	MR

The fire protection systems provided in the building were test checked at random and found functional at the time of inspection. In view of the deemed compliance of the minimum standards on fire prevention and fire safety required under the rules the NOC issued vide letter No.F.6/DFS/MS/EH/2011/182, dated 31.01.2011 renewal under rule 37 of the Delhi Fire Service Rule 2010 is recommended

*[Signature]*  
8/12/16

Signature of the Inspecting Officer

Name : Vedpal

Designation: Assistant Divisional Officer

~~D.O. (S.D)~~

It put up with FSC of T-3, IGI Airport.

*[Signature]*  
9/12/16



~~ADD~~  
~~(S.D)~~

Needful done.

*[Signature]*  
15/12

~~D.O. (S.D)~~

*[Signature]*  
15/12/16

~~By [Signature]~~

*[Signature]*  
15/12

442/cfo-2

CFO EP

m.scell

*[Signature]*