

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001**

No.F6/DFS/MS/2016/ School/ NDZ/1812

Dated: 22/12/16

**FIRE SAFETY CERTIFICATE**

Certified that the **N. P. Bengali Girls Sr. Sec. School**, located at **Gole Market, New Delhi** comprises of ground + 02 upper floor was granted FSC by this department vide letter No. **F6/DFS/MS/School/2013/NDZ/1264 dated 29/11/2013**. The premises was re-inspected by the officer concerned of this department on 06/12/2016 in the presence of Sh. Sajjan Kumar (Fire Officer) and found that the said school building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy of class **Group B “Educational Building” Sub-Div. B-I** with effect from 22/12/16 2016 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010 on the conditions printed below.

Issued on ..22/12/16..... at New Delhi by.

Vipin Kental  
(Vipin Kental)  
Chief Fire Officer  
Delhi Fire Service  
ofc  
m

Copy to:-

1. Director of Education,  
Govt. of NCT, Delhi.
2. The Principal,  
N. P. Bengali Girls Sr. Sec. School at Gole Market, New Delhi
3. Sh. Sajjan Kumar, Fire Officer,  
Fire Department, NDMC,  
Palika Kendra, New Delhi.

**Condition for the validity of fire safety certificate**

1. All the fire safety arrangements provided there in shall be maintained in good working condition at all time. The owner / occupier shall submit a declaration every year in Form ‘K’ provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
2. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. “The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form ‘J’ [sub rule (I) of rule 37] along with a copy of this Certificate, six months prior to its expiry”.

**INSPECTION R**

1. Name & address of the building:- N.P. Middle Girls School located at Gole Market, New Delhi
2. Type of occupancy:- Educational Group B-I, Gr.+01 Upper Floor
3. Type of case:- Renewal
4. Details of previous NOC:- No. F6/DFS/MS/School/2013/NDZ/1325 dated 20/12/2013.
5. Fire safety directives No.- N/A
6. Date of inspection:- 06/12/16
7. Name of the inspecting officer:- Sh. Manoj Kumar Sharma (ADO/CC)
8. Name & designation of officer  
From the building side:- Sh. Sajjan Kumar (Fire Officer)
9. Year of construction:- 2005
10. Applicant's letter No:- Nil dated 06/10/2016.

| S.No. | Minimum Standards on fire Prevention and fire safety U/R 33 | Requirement<br>NBC/DOE in<br>D-17705 | Provided at site    | Old Case<br>Remarks<br>MR/NMR |
|-------|---|--------------------------------------|---------------------|-------------------------------|
| 1.    | Access to Building  |                                      |                     |                               |
|       | 1) Road width   | 09 mtr.                              | 17 mtr.             | MR                            |
|       | 2) Gate width   | 04 mtr.                              | 04 mtr.             | MR                            |
|       | 3) Width of internal road                                   | NA                                   | NA                  | NA                            |
| 2.    | Number, Width Type & Arrangement of Exits                   |                                      |                     |                               |
|       | A. Number of staircases                                     |                                      |                     |                               |
|       | 1. Upper floors   | 02                                   | 02                  | MR                            |
|       | 2. Basements  | N/A                                  | N/A                 | N/A                           |
|       | B. Width of staircase                                       |                                      |                     |                               |
|       | 1. Upper floors   | 1.5mtr                               | 1.1mtr. & 0.84 mtr. | MR                            |
|       | 2. Basements  | N/A                                  | N/A                 | N/A                           |
|       | C. Protection of exits                                      |                                      |                     |                               |
|       | 1. Fire check door  | N/A                                  | N/A                 | N/A                           |
|       | 2. Pressurization   | N/A                                  | N/A                 | N/A                           |
|       | D. No. of continuous staircase to terrace                   |                                      |                     |                               |
|       |   | 02                                   | 02                  | MR                            |
|       | E. Width of corridor  |                                      |                     |                               |
|       |   | 1.5 mtr.                             | 1.5 mtr.            | MR                            |
|       | F. Door size  |                                      |                     |                               |
|       |   | 1 mtr.                               | 1 mtr.              | MR                            |
| 3.    | Compartmentation  |                                      |                     |                               |
|       | 1) Fire check door  | N/A                                  | N/A                 | N/A                           |
|       | 2) Sealing of electrical shafts                             | N/A                                  | N/A                 | N/A                           |
|       | 3) Fire rating of shaft door                                | N/A                                  | N/A                 | N/A                           |
|       | 4) Water curtain  | N/A                                  | N/A                 | N/A                           |
|       | 5) Fire Dampers   | N/A                                  | N/A                 | N/A                           |
| 4.    | Smoke Management System                                     |                                      |                     |                               |
|       | 1) Basements  |                                      |                     |                               |
|       |   | N/A                                  | N/A                 | N/A                           |
|       | 2) Upper floors   |                                      |                     |                               |
|       |   | N/A                                  | N/A                 | N/A                           |
| 5.    | Fire Extinguishers  |                                      |                     |                               |
|       | 1) Total numbers  |                                      |                     |                               |
|       |   | 06 Nos.                              | 10 Nos.             | MR                            |
|       | 2) Types  |                                      |                     |                               |
|       |   | ABC & CO2                            | ABC & CO2           | MR                            |
|       | 3) ISI marking  |                                      |                     |                               |
|       |   | Required                             | Provided            | MR                            |

|     |  |     |          |     |
|-----|--|-----|----------|-----|
| 6.  | First-Aid Hose Reel                        |     |          |     |
|     | 1) Total number of each floor              | N/A | 02       | N/A |
|     | 2) Length of hose reel hose                | N/A | 30 mtr.  | N/A |
|     | 3) Nozzle diameter                         | N/A | 05 mm    | N/A |
| 7.  | Automatic Fire Detection & Alarming System |     |          |     |
|     | 1) Type of detectors                       | N/A | N/A      | N/A |
|     | 2) Location of main panel                  | N/A | N/A      | N/A |
|     | 3) Location of repeater panel              | N/A | N/A      | N/A |
|     | 4) Alternate source of power               | N/A | N/A      | N/A |
|     | 5) Hooter's Location                       | N/A | N/A      | N/A |
| 8.  | MOEFA                                      | N/A | N/A      | N/A |
| 9.  | Public Address System                      | N/A | N/A      | N/A |
| 10. | Automatic Sprinkler System                 |     |          |     |
|     | 1) Basement                                | N/A | N/A      | N/A |
|     | 2) Upper floors                            | N/A | N/A      | N/A |
|     | 3) Sprinkler above false ceiling           | N/A | N/A      | N/A |
| 11. | Internal Hydrants                          |     |          |     |
|     | 1) Size of riser/down-comer                | N/A | N/A      | N/A |
|     | 2) Number of hydrants per floor            | N/A | N/A      | N/A |
|     | 3) Hose box                                | N/A | N/A      | N/A |
| 12. | Yard Hydrants                              |     |          |     |
|     | 1) Total number of hydrants                | N/A | N/A      | N/A |
|     | 2) Hose box                                | N/A | N/A      | N/A |
| 13. | Pumping Arrangement                        |     |          |     |
|     | 1) Ground level                            | N/A | N/A      | N/A |
|     | a) Discharge of main pump                  | N/A | N/A      | N/A |
|     | b) Head of main pump                       | N/A | N/A      | N/A |
|     | c) Number of main pump                     | N/A | N/A      | N/A |
|     | d) Jockey pump out put                     | N/A | N/A      | N/A |
|     | e) Jockey pump head                        | N/A | N/A      | N/A |
|     | f) Stand by pump output                    | N/A | N/A      | N/A |
|     | g) Stand by pump head                      | N/A | N/A      | N/A |
|     | h) Auto starting/Manual stopping           | N/A | N/A      | N/A |
|     | 2) Terrace level                           |     |          |     |
|     | a) Discharge of pump                       | N/A | 450 LPM  | N/A |
|     | b) Head of pump                            | N/A | 30 mtr.  | N/A |
|     | c) Power supply                            | N/A | Provided | N/A |
|     | d) Auto starting of pump                   | N/A | Provided | N/A |
| 14. | Captive Water Storage for Fire Fighting    |     |          |     |
|     | 1) Under ground tank capacity              | N/A | N/A      | N/A |
|     | a) Draw-off connection                     | N/A | N/A      | N/A |
|     | b) Fire service inlet                      | N/A | N/A      | N/A |

|     |  |          |           |     |
|-----|--|----------|-----------|-----|
|     | c) Access to tank  | N/A      | N/A       | N/A |
|     | d) Over head tank capacity   | N/A      | 2500 ltr. | N/A |
| 15. | Exit Signage.  | Required | Provided  | MR  |
| 16. | Provision of Lifts.  |          |           |     |
|     | a) Pressurization of lift shaft  | N/A      | N/A       | N/A |
|     | b) Pressurization of lift lobby  | N/A      | N/A       | N/A |
|     | c) Communication in lift car   | N/A      | N/A       | N/A |
|     | d) Fireman's switch  | N/A      | N/A       | N/A |
|     | e) Lift signage  | N/A      | N/A       | N/A |
| 17. | Stand by Power Supply  | N/A      | N/A       | N/A |
| 18. | Refuge Area  | N/A      | N/A       | N/A |
|     | Total area location  | N/A      | N/A       | N/A |
| 19. | Fire Control Room  | N/A      | N/A       | N/A |
|     | a) Detector system panel   | N/A      | N/A       | N/A |
|     | b) Flow switch panel   | N/A      | N/A       | N/A |
|     | c) PA system panel   | N/A      | N/A       | N/A |
|     | d) Battery backup  | N/A      | N/A       | N/A |
|     | e) Building floor plan   | N/A      | N/A       | N/A |
| 20. | Special Fire Protection System for Protection of special Risk, if any: |          |           | N/A |

The fire protection system provided in the school building were tested, checked at random and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter No. F6/DFS/MS/School/2013/NDZ/1325 dated 20/12/2013, renewal under Rule 35 of the Delhi Fire Service rules 2010, is recommended

Signature of the Inspecting Officer

*M.K. Sharma*

Name :- M.K. Sharma

Designation :- A. D.O. (CC)

DO (CD)

*g.s. sharma*  
21/12/16

*1/CF-NDZ*  
21/12/16/2012

*Dy CBO (NDZ)*

*[Signature]*  
21/12

*m.s cell*

*FT 101*

*[Signature]*  
8/12