FORM 'H' FORM FOR ISSUING FIRE SAFETY CERTIFICATE

[Refer sub - rule (1) of rule 35]

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE

NEW DELHI

No. F.6/DFS/MS/2016/WZ/ 1830

Dated: 23.12.2016

FIRE SAFETY CERTIFICATE

Certified that the **Delhi Metro Rail Corporation** located at **Keshav Puram Metro Station (Except PD area)** comprised of Ground, Concourse and Platform was issued FSC vide letter no. F.6/DFS/MS/2014/WZ/133 dated 30-01-2014. The premises was re inspected by the officer concerned of this department on 06-12-2016 in the presence of Mr Vikas Bhardawaj (AM Fire) and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and that the building / premises is fit for the occupancy class "Assembly" Group D Sub Division D – 7 with effect from he prevention and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on ... 23:12-2016... at New Delhi by.

Chief Fire Officer, Delhi Fire Service.

Copy to:

1. Sh. Vikas Bhardawaj (AM Fire) DMRC, Metro Bhawan, Fire Brigade Lane, Barakhamba Road, New Delhi – 110001.

Following fire safety directives must be adhered to:-

- 1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
- 2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
- 3. The trained staff should be available round the clock.
- 4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
- 5. The basement shall be used as per building bye laws 1983.
- 6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
- 7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
- 8. All the exit/passage must not be kept under lock and key and free from any obstruction.

INSPECTION REPORT

1. Name & address of the building: Keshav Puram Metro Station (Except PD area)

2. Type of Occupancy : Assembly

3. Type of Case : Renewal (Ground + Concourse + Platform)

4. Details of previous NOC: Letter No. F6/DFS/MS/2014/WZ/133 Dated 30-01-14

5. Fire Safety directives Letter No.: Letter No. F6/DFS/MS/BP/2003/450 dated 27-02-03

6. Date of inspection : 06-12-2016

7. Name of the Inspecting Officer: Udai vir Singh ADO (WP)

8. Name and designation of Officer

from the building side : Vikesh Bhardawaj (AM Fire)

9. Year of Construction : 2004

10. Applicant's letter No. : DMRC/O&M/Fire/NOC/L-3/2016/49 Dated

23-11-16

S	Minimum standards on fire	BBL		Provided at	Remark	CS
No	prevention and fire safety U/R	Requiremen	nts	site	MR/NN	MR
	33	in the second				ii .
1.	Access of building					
	Road width	On Main Ro	oad	Provided	MR	*
***************************************	Gate width	5 m		On Main Road	d MR	
	Width of internal road	NA		NA	NA	
2.	Number, width, Type & Arrang	gements of exi	ts			
	a. Number of staircases					
	Upper floors	2 for each f	loor	Provided	MR	
	 Basements 	NA		NA	NA	
	b. Width of staircases					
	 Upper floors 	1.5m &4 m		90,1x150 each F	lat farm	MR(6k
and the second	 Basements 	NA	NA-			NA
	c. Protection of exits					*
	 Fire check door 	NA		NA	NA	
	 Pressurization 	NA		NA	NA	8
	d. No of continuous	NA		NA	NA	,
	staircase to terrace e. Width Of Corridor	NA		NA	NA	
	f. Door Size	2 mtr		190 cm	MR	20
			-			
	a ·					



2		T		
3.	Compartmentation	D : 1	D :1.1	1.00
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire Rating of shaft door	Required	Provided	MR
	Water Curtain	NA	NA	NA
	Fire Dampers	NA	NA	NA
4.	Smoke managements System			*
	Basements	NA	NA	NA
	 Upper floors 	NA	NA	NA
5.	Fire Extinguishers			
	Total numbers	35 nos.	28 Co2,7 W C	MR
	• Types	CO ₂ & WCO ₂	Provided	MR
	IS marking	ISI marked	Provided	MR
6.	First – Aid Hose Reels			
	Total numbers on each floor	2 on each platform	Provided	MR
	Length of hose reel hose	30 m	Provided	MR
	Nozzle diameter	5 mm	Provided	MR
7.	Automatic fire detection and ala	rming system		
	Type of detectors	Smoke	Provided	MR
	 Location of Main Panel 	Required	Provided	MR
	Location of Repeater Panel	Required	Provided	MR
	Alternate source of power	Required	Provided	MR
	Hooters' Location	Required	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System	required	TTOVIGCG	TVIIC
	Basements	NA	NA	NA
	Upper Floor	NA	NA	NA
	Sprinkler above false	NA	NA	NA
	ceiling			
11.	Internal Hydrants	L		
	Size of riser/down- comer	150 mm	Provided	MR
	Number of hydrants	2	Provided	MR
	per floor	Required	Provided	MR
	Hose Box	1 10 1011 0 0	2.207.400	
12.	Yard Hydrants	I		
	Total number of hydrants	2	Provided	MR
	 Hose Box 	Required	Provided	MR



13.	Pumpin	g Arrangements				
3.		Ground Level	All the pumps a	re connected with	generator also	
		Discharge of main	1800lpm	Provided	MR	
		pump	•			
		Head of main pump	60m	Provided	MR	
		Number of main pumps	1	Provided	MR	
	>	Jockey pump out put	180lpm	Provided	MR	
		Jockey pump head	60m	Provided	MR	
		Standby Pump out put	1800lpm	Provided	MR	
		Standby Pump Head	60m	Provided	MR	
		Auto Staring/Manual stopping	Required	Provided	MR	
	>	Pump House Access	Required	Provided	MR	
	•	Terrace level				
	>	Discharge of pump	NA	NA	NA '	
	>	Head of the pump	NA	NA	NA	
		Power supply	NA	NA	NA	
	>	Auto starting of pump	NA	NA	NA	
14.	Cantiv	e water Storage for fire fi				
7	Captiv	Under ground tank	50,000ltrs	Provided 1	MR	
		capacity		lac ltrs	3	
	>	Draw of connection	Required	Provided	MR	
		Fire service inlet	Required	Provided	MR	
		Access to tank	Required	Provided	MR	
		Overhead Tank	NA	NA	MR	
		capacity		-		
15	Exit S	ignage	Required	Provided	MR	
16.		ion of Lifts				
10.		Pressurization of Lift Shaft	NA	NA	NA	
	>	Pressurization of lift lobby	NA	NA	NA	
	>	Communication in lift	Required	Provided	MR	
	>	Fireman's Grounding Switch	Required	Provided	MR	
	>		Required	Provided	MR	
17.		by power supply	Required	Provided	MR	
18.		ge Area				
10.		Total area	NA	NA	NA	
			NA	NA	NA	
19.	, 100000					
17.	File C	1	Required	Provided	MR	
		-1 0 1 D 1	NA	NA	NA	
		D 1	Required	Provided	MR	
			Required	Provided	MR	
	>	71 71	NA	NA	NA	



			The same of the sa	AND DESCRIPTION OF THE PARTY OF	4
20. Special Fire Protection Systems for Protection of	CO ₂ flooding for ASS, HT,	Provided	MR	0	6
special Risks, if any;	L1 paner				

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no. Letter No. F6/DFS/MS/2014/WZ/133 Dated 30-01-2014 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Signature of the Inspecting Officer

Signature of the inspecting Officer

Name

Volunta Sigh

Designation

ADO(W)

Name

Designation