

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110 001.

No.F.6/DFS/MS/School/2016/SZ /1817

Dated: 23/12/16

FIRE SAFETY CERTIFICATE

Certified that the **Don Vasco Convent School (Recognised)**, WZ-238, Shiv Nagar, Jail Road, New Delhi-110058, comprised of ground floor plus three upper floors, owned/occupied by Don Vasco Convent School was issued NOC by this department vide letter F6/MS/DFS/2006/2746 dated 22.09.2006. The School building was re-inspected by the officer concerned of this department on 01.12.2016 in the presence of Sh. Mahesh Kumar (Chairman) and found that the Don Vasco Convent School have deemed complied the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building/ premises is fit for occupancy class "Educational" for a period of three years in accordance with rule 36 unless renewed under, rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule-38 of the Delhi Fire Service Rules, 2010 printed as below.

Issued on.....23/12/16..... at New Delhi.

(VIPIN KENTAL)
CHIEF FIRE OFFICER

13/12/16

Copy to:-

1. Sh. Mahesh Kumar (Chairman),
Don Vasco Convent School (Recognised),
WZ-238, Shiv Nagar, Jail Road, New Delhi-110058
2. Director of Education,
Govt. of NCT of Delhi, Old Secretariat,
New Delhi-110054.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

2/6

Ground plus three upper floors

INSPECTION REPORT

1. Name & address of the building : Don Vasco Convent School (Recognised), WZ-238, Shiv Nagar, Jail Road, New Delhi-110058
2. Type of Occupancy : Educational
3. Type of Case : Renewal
4. Details of Previous NOC : F6/MS/DFS/2006/2746 dated 22.09.2006
5. Fire Safety directives letter No : N/A
6. Date of inspection : 01.12.2016
7. Name of Inspecting Officer : A.D.O. Sandeep Duggal
8. Name and designation of officers
From the building side : Sh. Mahesh Kumar (Chairman)
9. Year of Construction : 2006
10. Applicant's letter No. : DVCS/2016 dated 03.11.2016.

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Requirement as per NOC dt. 22.09.2006	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	Accessible N/A N/A	06 & 09 mtrs 2.25 mtrs N/A	M/R N/A N/A
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> • Upper Floors • Basements 	01 No N/A	02 No's N/A	M/R N/A
	b. Width of staircases			
	<ul style="list-style-type: none"> • Upper Floor • Basements 	150 cms/additional staircase of 75 cms if less than 150 cms	100 & 100 to 75 cms	M/R
	c. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	N/A N/A	N/A N/A	N/A N/A
	d. No. of continuous staircases to terrace	N/A	N/A	N/A
	e. Width of Corridor	Required	One	M/R
	f. Door Size	Old case Old case	230 to 80 cms 90 cms	M/R, being old case M/R, being old case
3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A
4.	Smoke Management System			
	<ul style="list-style-type: none"> • Basements • Upper floors 	N/A Required	N/A Natural ventilation provided .	N/A M/R
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	06 no's ABC/CO ₂ type ISI marked	Provided Provided Provided	M/R M/R M/R

4. Details of Previous NOC : F6/MS/DFS/2006/2746 dated 22.09.2006
 5. Fire Safety directives letter No : N/A
 6. Date of inspection : 01.12.2016
 7. Name of Inspecting Officer : A.D.O. Sandeep Duggal
 8. Name and designation of officers
 From the building side : Sh. Mahesh Kumar (Chairman)
 9. Year of Construction : 2006
 10. Applicant's letter No. : DVCS/2016 dated 03.11.2016.

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Requirement as per NOC dt. 22.09.2006	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> Road width Gate width Width of internal road 	Accessible N/A N/A	06 & 09 mtrs 2.25 mtrs N/A	M/R N/A N/A
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> Upper Floors Basements 	01 No N/A	02 No's N/A	M/R N/A
	b. Width of staircases			
	<ul style="list-style-type: none"> Upper Floor Basements 	150 cms/additional staircase of 75 cms if less than 150 cms	100 & 100 to 75 cms	M/R
	c. Protection of exits			
	<ul style="list-style-type: none"> Fire check door Pressurization 	N/A N/A	N/A N/A	N/A N/A
	d. No. of continuous staircases to terrace	N/A	N/A	N/A
	e. Width of Corridor	Required	One	M/R
	f. Door Size	Old case Old case	230 to 80 cms 90 cms	M/R, being old case M/R, being old case
3.	Compartmentation			
	<ul style="list-style-type: none"> Fire check door Sealing of electrical shafts Fire Rating of shaft door Water Curtain Fire Dampers 	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A
4.	Smoke Management System			
	<ul style="list-style-type: none"> Basements Upper floors 	N/A Required	N/A Natural ventilation provided .	N/A M/R
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	06 no's ABC/CO ₂ type ISI marked	Provided Provided Provided	M/R M/R M/R
6.	First-Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	Required Required Required	Provided Provided Provided	M/R M/R M/R

Sau

N/7

7.	Automatic fire detection and alarming system			
	• Type of detectors	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooters' Location	N/A	N/A	N/A
8.	MOEFA			
9.	Public Address System			
10.	Automatic Sprinkler System			
	• Basement	N/A	N/A	N/A
	• Ground Floor	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	• Size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
12.	Yard Hydrants			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13.	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey Pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Starting/Manual Stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace level			
	➤ Discharge of pump	Old case	220 LPM provided	M/R, being old case
	➤ Head of the pump	30 mtrs	Provided	M/R
	➤ Power Supply	N/A	N/A	N/A
	➤ Auto Starting of pump	N/A	N/A	N/A
14.	Captive Water Storage for fire fighting			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	5,000 ltrs	Provided	M/R
15.	Exit Signage.	Required	Provided	M/R
16.	Provision of Lifts. No Lift			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17.	Standby power supply	N/A	N/A	N/A

2/8

19.	Fire Control Room			
	<ul style="list-style-type: none">• Detector System Panel• Flow Switch Panel• PA System Panel• Battery backup• Building Floor Plans	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection and shortcomings communicated vide letter no. F.6/DFS/MS/School/2016/SZ/1653 dated 11.03.2016 has been complied.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter number F6/MS/DFS/2006/2746 dated 22.09.2006 renewal under rule 37 of the Delhi Fire Service Rules 2010 is recommended.

Sandeep
02/12/16

Signature of Inspecting Officer

Name:- Sandeep Duggal

Designation:- Asstt. Divisional Officer

D.O. (South West)

dg
05/12/16

