

FORM 'H'  
FORM FOR ISSUING FIRE SAFETY CERTIFICATE  
[Refer sub - rule (1) of rule 35]  
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE  
NEW DELHI - 110001


No: F6/DFS/MS/SCHOOL/ 1832

Dated: 23/12/2016

**FIRE SAFETY CERTIFICATE**

Certified that the building of **Govt Girls Sr Sec. School**, Located at **Narang Colony Tri Nagar, Delhi-110035**, comprised ( Total Five -Block) (Two Block G. Floor & Three Block Ground + 1 Upper Floor) owned/ occupied by **Govt Girls Sr Sec. School**, have complied with the fire prevention and fire safety requirements in accordance with the Circular No-F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011/ NBC Part IV issued by the Director of Education and verified by the officers concerned of Fire Service on 03/12/2016 in the presence of **Ms. Subhra Talwar (Principal)** and that the building / premises is fit for the occupancy class "Educational" Group B Sub Division B – 1 with effect from 23.12.2016 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 23.12.2016 at New Delhi.

  
(Atul Garg)  
Chief Fire Officer,  
Delhi Fire Service

Copy to:-

The Principal, **Govt Girls Sr Sec. School, Narang Colony Tri Nagar, Delhi-110035.**

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The basement shall be used as per building bye laws.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigov](http://www.dfs.delhigov)
8. Trimming of the trees must be done time to time to erasure free passage for fire vehicle near the main entry gate.

## INSPECTION REPORT

2. Name & address of the building: **Govt Girls Sr Sec. School, Located at Narang Colony Tri Nagar, Delhi-110035.**
3. Type of Occupancy : Educational ( Total Five -Block) (Two Block G. Floor & Three Block Ground + 1 Upper Floor)
4. Type of Case : New
5. Details of previous NOC : Nil
6. Fire Safety directives Letter No. : DOE 3298-3398 dated 01-03-2011
7. Date of inspection : 03-12-2016
8. Name of the Inspecting Officer : Udai vir singh, ADO (WP)
9. Name and designation of Officer  
     from the building side : Ms. Subhra Talwar (Principal)
10. Year of Construction : 1998
11. Applicant's letter No. : 743 dated 18/11/2016

No. of Students=695
No. of class rooms=19
Plot area=8618sqm
Covered area=5574sqm

S No	Minimum standards on fire prevention and fire safety U/R 33	Cr.No.3298-3398 dated 1-3-11	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	6 mtr	Provided	MR
	• Gate width	Accessible	5 mtr Provided	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2	Block D=One Block E=Three Block C=Two Block A&B=G.Floor only	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	1.5 trm	Block D=1x154cm Block E=2x155,1x144cm Block C=1x150,1x146cm	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	1	Provided	MR
	e. Width Of Corridor	1.5 mtr	154 cm Provided	MR
	f. Door Size	1 mtr	105cm <u>890 cm</u>	MR

3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA
5.	Fire Extinguishers			
	• Total numbers	18 nos.	18 Provided	MR
	• Types	CO <sub>2</sub>	Provided	MR
	• IS marking	ISI marked	Provided	MR
6.	First – Aid Hose Reels			
	• Total numbers on each floor	NA	NA	NA
	• Length of hose reel hose	NA	NA	NA
	• Nozzle diameter	NA	NA	NA
7.	Automatic fire detection and alarming system			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location			
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	• Basements	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants:			
	• Size of riser/down-comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA

13	<ul style="list-style-type: none"> <li>● Ground Level</li> <li>● Discharge of main pump</li> </ul>	NA	NA	NA
	➤ Head of main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Staring/Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	● Terrace level			
	➤ Discharge of pump	NA	NA	NA
	➤ Head of the pump	NA	NA	NA
	➤ Power supply	NA	NA	NA
➤ Auto starting of pump	NA	NA	NA	
14.	Captive water Storage for fire fighting:			
	<ul style="list-style-type: none"> <li>● Under ground tank capacity</li> </ul>	NA	NA	NA
	➤ Draw off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	<ul style="list-style-type: none"> <li>● Overhead Tank capacity</li> </ul>	NA	NA	NA
15	Exit Signage	NA	NA	NA
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/issue shortcomings as noted at serial numbers

..... Nil .....

Signature of the Inspecting Officer

Signature of the Inspecting Officer

Name

Uday Vir Singh

Name

Designation

ADD/WF

Designation

~~DOTW~~  
9/12/16

15/12/16

Dy. IFO (WZ)