

Dated: 23/12/16

FIRE SAFETY CERTIFICATE

Certified that the M/s "Krishna's International Lodging House" located at C-43, Neeti Bagh, New Delhi, comprised of basement (Storage), ground plus two upper floors (Ground floor=04 guest rooms, 1st floor=04 guest rooms & 2nd floor=01 guest room), total 09 guest rooms only, owned/occupied by M/s "Krishna's International Lodging House" was granted FSC by this department vide letter No. F6/DFS/MS/GH/2013/SZ/555, dated 12-07-2013. The premises was re-inspected by the officer concerned of this department on 19-12-2016 in the presence of Adv. Sh. Krishana Murti, Owner and found that the said guest house have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class Residential (Guest House with 09 guest rooms only) with effect from ..23.12.2016 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on..23.12.2016 at New Delhi by.


(Vipin Kental)
Chief Fire Officer
T.No.011-23412225

Copy to:- 1. Joint Commissioner of Police, Licensing Branch, 1st floor, P.S. Defence Colony, New Delhi. 

2. M/s "Krishna's International Lodging House" at C-43, Neeti Bagh, New Delhi. 

Conditions for the validity of fire safety certificate are under:-


1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate on form J, six month prior to its expiry.

INSPECTION REPORT


1	Name & address of the building	M/s "Krishna's International Lodging House" located at C-43, Neeti Bagh, New Delhi.		
2	Type of Occupancy	Residential, Lodging House "A"		
3	Building Comprised of	Basement, ground plus two upper floors. Basemnt=Storage, Ground Floors=04 Guest Rooms, 1st floor = 04Guest Rooms & 2nd floor=01Guest Room. Total=09 Guest Rooms.		
4	Type of case	Renewal		
5	Details of previous NOC	No.F6/DFS/MS/GH/2013/SZ/555, Dated 12.07.2013.		
6	Fire safety directives letter No	Nil.		
7	Date of inspection	19.12.2016		
8	Name of the inspecting Officers	Vedpal ADO		
9	Name and designation of officers from the building side	Adv. Krishan Murti.		
10	Year of construction	Prior to 1983		
11	Applicant's letter No.	NO. 103-04/Joint C.P./Lic (H), Dt 21.11.2016.		
S. NO.	Minimum Standards on fire prevention and fire safety U/R 33	Requirements/ Existing fire protection arrangements	Provided at site	Remarks MR / NMR
1	Access to building			
	1) Road width	Accessible	9m Provided	MR
	2) Gate width	N/A	N/A	N/A
	3) Width of internal road	N/A	N/A	N/A
2	Number, width Type & arrangement of exits			
	a. Number of staircases			
	1. Upper floors	01no.	01no.	MR
	2. basements	01no.	01no.	MR(old case)
	b. Width of staircase			
	1. Upper floors	90cm	01m.	MR(old case)
	2. basements	90cm	01m.	MR(old case)
	c. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	d. No. of continuous staircase to terrace	N/A	N/A	N/A
	e. Width of corridor	N/A	N/A	N/A
	f. Door size	N/A	N/A	N/A
3	Compartmentation.			
	1. Fire check door	N/A	N/A	N/A
	2. Sealing of electrical shafts	N/A	N/A	N/A
	3. Fire Rating of shaft door	N/A	N/A	N/A
	4. water curtain	N/A	N/A	N/A
	5. Fire dampers	N/A	N/A	N/A
4	Smoke Management system.			
	Basement	30 a/c per hour	Exhaust Fans Provided	MR
	Upper floors	12 a/c per hour	Natural Ventilation	MR
5	Fire Extinguishers			
	Total numbers	08 Nos.	08Nos.	MR
	Types	WCO2 & CO2 Types	CO2 & WCO2	MR
	ISI marking	ISI	ISI Mark	MR
6	First-Aid Hose Reels.			
	Total numbers on 1st floor only	01no.	01no.	MR
	Length of Hose reel hose	30m	30m	MR
	Nozzle Diameter	5mm	5mm	MR

7 Automatic fire detection and alarming system				
	Type of detectors	N/A	N/A	N/A
	Location of Main Panel	N/A	N/A	N/A
	Location of Repeater panel	N/A	N/A	N/A
	Alternate source of power	N/A	N/A	N/A
	hooter's location	N/A	N/A	N/A
8	MOEFA	N/A	N/A	N/A
9	Public Address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	Basement	Required	Provided	MR
	Upper floors	N/A	N/A	N/A
	Sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	Size of riser/down-corner	N/A	N/A	N/A
	Number of Hydrants per floor	N/A	N/A	N/A
	hose Box	N/A	N/A	N/A
12	Yard Hydrants.			
	total number of hydrants	N/A	N/A	N/A
	hose box	N/A	N/A	N/A
13	Pumping arrangements			
	1. Ground level			
	a. Discharge of main Pump	N/A	N/A	N/A
	b. Head of main pump	N/A	N/A	N/A
	c. Number of main pumps	N/A	N/A	N/A
	d. jockey pump out put	N/A	N/A	N/A
	e. jockey pump head	N/A	N/A	N/A
	f. Standby Pump output	N/A	N/A	N/A
	g. Stanby Pump head	N/A	N/A	N/A
	h. Auto Starting/Manual stopping	N/A	N/A	N/A
	pump house access	N/A	N/A	N/A
	2. Terrace level			
	a. Discharge of pump	Boosting	450LPM	MR
	b. head of the pump	N/A	40m	N/A
	c. Power supply	Required	Provided	MR
	d. Auto starting of pump	N/A	Provided	N/A
14	Captive water storage for fire fighting			
	1. Underground tank capacity	N/A	N/A	N/A
	a. Draw-off connection	N/A	N/A	N/A
	b. fire service inlet	N/A	N/A	N/A
	c. Access to tank	N/A	N/A	N/A
	Over head tank Capacity	2500Liters	2500Liters	N/A
15	Exit Signage.	Required	Provided	MR
16	Provision of lifts.			
	a. Pressurization of lift shaft	N/A	N/A	N/A
	b. pressurization of lift lobby	N/A	N/A	N/A
	c. communication in lift car	N/A	N/A	N/A
	d. Fireman's grounding switch	N/A	N/A	N/A
	e. Lift signage	N/A	N/A	N/A
17	Standby power supply	Required	Provided	MR
18	Refuge Area.	Not Required		
	total area			
	location			
19	Fire control room			
	a. Detector system Panel	N/A	N/A	N/A
	b. Flow switch Panel	N/A	N/A	N/A
	c. PA system Panel	N/A	N/A	N/A
	d. Batter backup	N/A	N/A	N/A
	e. Building floor plans	N/A	N/A	N/A

N/29

20	Special Fire Protection systems for protection of special risks, if any: N/A
<p>The fire protection systems provided in the building were test checked randomly and found functional at the time of inspection. In view of the deemed compliance of the minimum standards on fire prevention and fire safety required under the rules the FSC issued vide letter No.F.6/DFS/MS/GH/2013/SZ/555, dated 12.07.13 renewal under rule 37 of the Delhi Fire Service Rule 2010 is recommended. Shortcomings communicated vide letter dated 28.11.16 have been complied at serial numbers 4,8,13 & 15. ✓</p> <p>Accordingly DFA is put up for your approval and signature please.</p> <p> 19/12/16</p> <p>Signature of the inspecting officer</p> <p>Name Vedpal</p> <p>Designation : Assistant Divisional Officer</p>	

~~D.O. (S.D)~~

~~ 19/12/16~~

466/CFR/22
20/12/16.