

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**

Fax No. 011-23412593, Ph. 011-23412225


No. F6/DFS/MS/School/SZ/2016/ 1845

Dated: 28/12/16..

**FIRE SAFETY CERTIFICATE**

Certified that the **Smart Kids Public School, E-17, Abul Fazal Enclave, Jamia Nagar, New Delhi**, comprised of basement (Not in use), ground, mezzanine floor plus two upper floors **Owned/Occupied** Smart Kids Public School have complied with the fire prevention and fire safety requirements in accordance with Directorate of Education circular no. F.16//Estate/CC/Fire Safety/2011/3298 to 3398 Dated 01.03.2011 issued by Director of Education, Govt. of NCT of Delhi and verified by the officer concerned of Delhi Fire Service on 21.11.2016 in the presence of Mrs. Ghazala Azeen, Manager of the school and that the building is fit for occupancy class **“Educational Building Group-B”** with effect from 28/12/ 2016 for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on ..28.12.16..... at New Delhi by

  
Vipin Kental  
Chief Fire Office

**Copy to: -**

1. The Principal, Smart Kids Public School,  
E-17, Abul Fazal Enclave, Jamia Nagar, New Delhi
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi.

**Conditions for the validity of Fire Safety Certificate**

1. All the fire safety and means of escape facilities shall be maintained in good working condition at all time. Any lapse rendering the fire safety or means of evacuation facilities non-functional shall be the responsibility of the management.
2. Building Sanctioning authority may verify any deviation with regard to construction/occupancy in the building. In case of any deviation, the fire safety certificate stands null & void.
3. The staff shall be trained for operating fire fighting system and mock evacuation drill be conducted at regular interval and record be maintained.
4. This certificate cannot be treated in any case for the regularization of unauthorized construction.
5. The basement shall be used strictly as per the provisions of Building Bye Laws.
6. The Owner/Occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules, 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
7. The Owner/Occupier shall apply for renewal of this Fire Safety Certificate to the Director in the form 'J' [sub rule (1) of rule 37] along with copy of this certificate, six months prior to its expiry. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).

N/2

**INSPECTION REPORT**

1	Name & Address of the Building	Smart Kids Public School, E-17, Abul Fazal Enclave, Jamia Nagar, New Delhi		
2	Type of Occupancy	Educational Building "Group-B" (School)		
3	Building Comprised of	Basement (Not in use), Ground, Mezzanine floor plus two upper floors		
4	Type of Case	New		
5	Details of Previous NOC	Nil		
6	Fire Safety Directives Letter No	DOE Circular dated 01.03.2011		
7	Date of Inspection	21.11.2016		
8	Name of the Inspecting Officers	ADO R.N Singh		
9	Name & Designation of Officers from the building side	Mrs. Ghazala Azeen (Manager)		
10	Year of construction	2009		
11	Applicant letter No.	SK10025 dated 07.10.16		
<b>S. No</b>	<b>Minimum standards on Fire Prevention and Fire Safety U/R 33</b>	<b>DOE Circular Dt. 01/03/2011 Requirement</b>	<b>Provided at Site</b>	<b>Remarks MR/NMR</b>
<b>1</b>	<b>Access to Building.</b>			
	1. Road width	Accessible	6 Mts. Provided	<b>MR</b>
	2. Gate width	NA	4.5 Mts.	NA
	3. Width of internal road	NA	NA	NA
<b>2</b>	<b>Number, width, type and arrangements of exits.</b>			
	<b>a. Number of Staircase</b>			
	1. Upper floors	2 Nos.	2 Nos.	<b>MR</b>
	2. Basement floor	NA	NA	MR
	<b>b. Width of Staircase</b>			
	1. Upper floors	1.50 Mts / 0.75 Mts.	1.00 & 0.95 Mts.	<b>MR</b>
	2. Basement floor	NA	NA	NA
	<b>c. Protection of exits</b>			
	1. Fire check door	NA	NA	NA
	2. Pressurization	NA	NA	NA
	<b>d. No. of continuous staircase to terrace</b>	01 No	01 No	<b>MR</b>
	<b>e. Width of corridor</b>	NA	NA	NA
	<b>f. Door size</b>	1.0 Mts.	1.0 Mts.	<b>MR</b>
<b>3</b>	<b>Compartmentation.</b>			
	1. Fire check door.	NA	NA	NA
	2. Sealing of electrical shafts.	NA	NA	NA
	3. Fire rating of shaft door.	NA	NA	NA
	4. Water curtain	NA	NA	NA
	5. Fire dampers.	NA	NA	NA
<b>4.</b>	<b>Smoke Management system.</b>			
	1. Basement	NA	NA	NA
	2. Upper floors	NA	NA	NA
<b>5.</b>	<b>Fire Extinguishers.</b>			
	1. Total numbers	8 No.	8 No. Provided	<b>MR</b>
	2. Types	ABC & Co2	ABC	<b>MR</b>
	3. ISI Marking	Required	Provided	<b>MR</b>
<b>6.</b>	<b>First Aid Hose Reels.</b>			
	1. Total numbers on each floor.	1 No.	1 No. Provided	MR
	2. Length of hose-reel hose.	30 Mtr	30 Mtr Provided	MR
	3. Nozzle Diameter	5 MM	5 MM	MR

New

Smart Kids Public School, E-17, Abul Fazal Enclave, ND-25

P

<b>7</b>	<b>Automatic Fire Detection and Alarming system.</b>			
	1. Type of detectors	NA	NA	NA
	2. Location of Main Panel	NA	NA	NA
	3. Location of Repeater Panel	NA	NA	NA
	4. Alternate source of power	NA	NA	NA
	5. Hooter's location	NA	NA	NA
<b>8.</b>	<b>MOEFA</b>	NA	Provided	NA
<b>9.</b>	<b>Public Address System</b>	NA	Provided	NA
<b>10.</b>	<b>Automatic Sprinkler System</b>			
	1. Basement	NA	NA	NA
	2. Upper floors	NA	NA	NA
	3. Sprinkler above false ceiling	NA	NA	NA
<b>11.</b>	<b>Internal Hydrants.</b>			
	1. Size of Riser / Down-comer	NA	NA	NA
	2. Number of Hydrant per floor	NA	NA	NA
	3. Hose box.	NA	NA	NA
<b>12.</b>	<b>Yard Hydrants.</b>			
	1. Total number of hydrants.	NA	NA	NA
	2. Hose box.	NA	NA	NA
<b>13.</b>	<b>Pumping arrangements.</b>			
	<b>1. Ground Level</b>			
	a) Discharge of main pump.	NA	NA	NA
	b) Head of main pump.	NA	NA	NA
	c) Number of main pumps.	NA	NA	NA
	d) Jockey Pump output.	NA	NA	NA
	e) Jockey Pump head.	NA	NA	NA
	f) Standby pump output.	NA	NA	NA
	g) Standby pump head.	NA	NA	NA
	h) Auto Starting / Manual Stopping.	NA	NA	NA
	i) Pump house access.	NA	NA	NA
	<b>2. Terrace Level</b>			
	a) Discharge of pump.	450 lpm	450 lpm	MR
	b) Head of pump.	40 Mtr	40 Mtr	MR
	c) Power supply.	Required	Provided	MR
	d) Auto starting of pump.	Required	Provided	MR
<b>14.</b>	<b>Captive water storage for Fire Fighting.</b>			
	1. Underground tank capacity.	NA	NA	NA
	2. Draw-off connection.	NA	NA	NA
	3. Fire Service Inlet.	NA	NA	NA
	4. Access to tank.	NA	NA	NA
	5. Overhead tank capacity.	10,000 Ltr	10,000 Ltr	MR
<b>15.</b>	<b>Exit Signage.</b>	Required	Provided	<b>MR</b>
<b>16</b>	<b>Provision of Lifts.</b>			
	1. Pressurization of lift shaft.	NA	NA	NA
	2. Pressurization of lift lobby.	NA	NA	NA
	3. Communication in lift car.	NA	NA	NA
	4. Fireman's switch.	NA	NA	NA
	5. Lift signage.	NA	NA	NA

New

br


2/14

17	Standby Power Supply	NA	NA	NA
18.	Refuge Area	NA	NA	NA
	1. Total area	NA	NA	NA
	2. Location	NA	NA	NA
19.	Fire Control Room.	NA	NA	NA
20.	<b>Special Fire Protection System for the Protection of special Risk, if any.</b>			NA

The Fire Protection system provided in the building were checked at random and found functional at the time of inspection. The shortcomings communicated by this department vide letter no. F.6/DFS/MS/School/2014/1714 dated 30/07/2014 have been rectified by the school management.

In view of the substantial compliance of the minimum standards on fire prevention and fire safety measures as required under the DOE circular dated 01/03/2011, it is recommend to grant FSC under rules 35 of the DFS Rules-2010, is recommended

Accordingly DFA is put up for approval and signature please.

  
 Signature of the Inspecting Officer  
 Name: R.N. Singh  
 Designation: ADO

Smart Kids Public School, E-17, Abul Fazal Enclave, ND-25

New

Bl Speak

D.O. (SD)

Amilash  
5/8/16