

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI**

No.F6/DFS/MS/School/2013/1021 18

Dated: 04/01/17

**FIRE SAFETY CERTIFICATE**

Certified that **Rajkiya Pratibha Vikas Vidyalaya** located at **Civil Line, Delhi-110054**, comprised of **3 Blocks 1. Ground +3 Upper Floor 2. Ground + 1 upper floor** was granted FSC by this department vide letter **No.F6/DFS/MS/School/2013/1016 dated 03/10/13**. The premises was re-inspected by the officer concerned of this department on **21/12/16** in the presence of **Mrs. Urvashi Gupta (Principal)** and observed that one more block comprised of ground floor only have been added in the school premises and found to have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of Delhi Fire Service Rules 2010 and the premises / building is fit for occupancy, class **B "Educational Building"** with effect from ..... **04/01/17** ..... for a period of three years, in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010. mentioned below.

Issued on ..... **04/01/17** ..... at New Delhi

  
(Vipin Kental)  
Chief Fire Officer  
Delhi Fire Service  
Ph. 011-23412225

Copy to:- (1) Rajkiya Pratibha Vikas Vidyalaya,  
Civil Line, Delhi-110054.  
(2) Director of Education,  
Old Secretariat, Delhi.

Conditions for the validity of fire safety certificate.

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire protections measures shall be maintained in perfect conditions all the time as seen during inspection.
3. All the staff members must know the correct method of operation of fire fighting system.
4. Any lapse rendering fire fighting system/equipment non-functional shall be the risk and responsibility of the management.
5. This inspection report may not in any way be treated as regularization of unauthorized construction, if any.
6. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. the form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry.

### INSPECTION REPORT

1. Name & address of the building: - Rajkiya Pratibha Vikas Vidyalaya, Civil Line, Delhi-110054.
2. Type of occupancy:- Group – B Educational Building  
3 Blocks Ground + 3, Ground + 1 & Ground floor only
3. Type of case:- Renewal / Addition of one block (G-Fonly)
4. Details of previous FSC:- No.F6/DFS/MS/School/2013/1016 dated 03/10/13.
5. Fire safety directives No.- N/A
6. Date of inspection:- 21/12/16
7. Name of the inspecting officer:- Dy. CFO Sunil Chowdhary & D.O. Gurmukh Singh
8. Name & designation of officer:-  
From the building side:- Mrs. Urvashi Gupta ( Principal).
9. Year of construction:- 1961.
10. Applicant's letter No:- N0. RPVB/CL/2016/681-683 Dated 26/11/16

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	As per Education Circular	Provided at site	Remarks MR/NMR
<b>1.</b>	<b>Access to Building</b>			
	1) Road width	Required	12 mtr.	MR
	2) Gate width	4.5 mtr.	5 mtr.	MR
	3) Width of internal road	N/A	N/A	N/A
<b>2.</b>	<b>Number, Width Type &amp; Arrangement of Exits</b>			
	<b>A. Number of staircases</b>			
	1. Upper floors	01 no.	01 no. at each block	MR
	2. Basements	N/A	N/A	N/A
	<b>B. Width of staircase</b>			
	1. Upper floors	1.50 mtr.	(G+1) 1.50 & (G +3) 1.72 mtr.	MR both block connected at 1 <sup>st</sup> floor with bridge.
	2. Basements	N/A	N/A	N/A
	<b>C. Protection of exits</b>			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	<b>D. No. of continuous staircase to terrace</b>			
		N/A	N/A	N/A
	<b>E. Width of corridor</b>			
		N/A	N/A	N/A
	<b>F. Door size</b>			
		N/A	N/A	N/A
<b>3.</b>	<b>Compartmentation</b>			
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A

*h*

4.	<b>Smoke Management System</b>			
	1) Basements	30 a/c per hour	N/A	N/A
	2) Upper floors	12 a/c per hour	Natural	MR
5.	<b>Fire Extinguishers</b>			
	1) Total numbers	23 Nos.	23 Nos.	MR
	2) Types	ABC & co2	ABC & co2	MR
	3) ISI marking	Required	Provided	MR
6.	<b>First-Aid Hose Reel</b>			
	1) Total number at each floor	01 No.	01 No.	MR
	2) Length of hose reel hose	30 mtr.	30 mtr	MR
	3) Nozzle diameter	5 mm.	05 mm	MR
7.	<b>Automatic Fire Detection &amp; Alarming System</b>			
	1) Type of detectors	N/A	N/A	N/A
	2) Location of main panel	N/A	N/A	N/A
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	N/A	N/A	N/A
	5) Hooter's Location	N/A	N/A	N/A
8.	<b>MOEFA</b>			
9.	<b>Public Address System</b>			
10.	<b>Automatic Sprinkler System</b>			
	1) Basement	N/A	N/A	N/A
	2) Upper floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	<b>Internal Hydrants</b>			
	1) Size of riser/down-comer	N/A	N/A	N/A
	2) Number of hydrants per floor	N/A	N/A	N/A
	3) Hose box	N/A	N/A	N/A
12.	<b>Yard Hydrants</b>			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A
13.	<b>Pumping Arrangement</b>			
	1) Ground level	N/A	N/A	N/A
	a) Discharge of main pump	N/A	N/A	N/A
	b) Head of main pump	N/A	N/A	N/A
	c) Number of main pump	N/A	N/A	N/A
	d) Jockey pump out put	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	2) Terrace level			
	a) Discharge of pump	450 LPM	450 LPM	MR
	b) Head of pump	40 mtr.	40 mtr.	MR
	c) Power supply	Required	Provided	MR

	d) Auto starting of pump	Required	Provided	MR
<b>14.</b>	<b>Captive Water Storage for Fire Fighting</b>			
	1) Under ground tank capacity	N/A	N/A	N/A
	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	N/A	N/A	N/A
	c) Access to tank	N/A	N/A	N/A
	d) Over head tank capacity	10,000 ltrs.	10,000 ltrs.	MR
<b>15.</b>	<b>Exit Signage.</b>	N/A	N/A	N/A
<b>16.</b>	<b>Provision of Lifts.</b>	N/A	N/A	N/A
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	N/A
<b>17.</b>	<b>Stand by Power Supply</b>	N/A	N/A	N/A
<b>18.</b>	<b>Refuge Area</b>	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
<b>19.</b>	<b>Fire Control Room</b>	N/A	N/A	N/A
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
<b>20.</b>	<b>Special Fire Protection System for Protection of special Risk, if any:- 4 sand buckets provided.</b>			MR

The fire protection system provided in the school were tested, checked at random and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required as per rules FSC issued vide letter No.F6/DFS/MS/School/2013/178 dated 09/01/13, renewal under rule35 of the Delhi Fire Service rules 2010, is recommended.

*Gurmukh Singh*  
22/12/16  
Gurmukh Singh  
Divisional Officer

1911/CF/NO2  
27/12/16/4/11/17

*Dy CBO (N/DZ)*

*[Signature]*  
23/12 8210

C.F.P. m-seen *[Signature]*  
26/12

F.T. letter is put up for sign. *[Signature]*