

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI- 110001




NO. F6/DFS/MS/School/2016/SZ/ 21

Dated: 06.01.2017

FIRE SAFETY CERTIFICATE

Certified that the New Evergreen Public School, C-138, Vikas Vihar (Bharat Vihar), Kakrola, New Delhi-110078, located at ground and first floor was granted NOC by this department vide letter No.F6/ DFS/MS/School/2013/SZ/905 dated 12.9.2013. Management has constructed two rooms at second floor which are being used for servant residence. The school building was re-inspected by the officer concerned of this department on 15.12.2016 in presence of Smt. Sunita (Principal) and found that the premises have deemed complied with the fire prevention and fire safety requirements in accordance with Directorate of Education GNCT of Delhi Circular No. F16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 1.3.2011 and that the Premises/building is fit for occupancy of class B "Educational Building" **for ground & First floor** with effect from 06.01.2017 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010 subject to conditions printed overleaf.

Issued on 06.01.2017 at New Delhi by


(Vipin Kental)
Chief Fire Officer



Copy to:

- 1 Dy. Director, (Education) SDMC, 23rd floor, Civic Centre, Minto Road, New Delhi.
- 2 Manager, New Evergreen Public School located at C-138, Vikas Vihar (Bharat Vihar), Kakrola, New Delhi-110078.

CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner / occupier shall apply for renewal of this **Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37)** along with copy of the certificate, six months prior to its expiry.

ADD Dwar K9

INSPECTION REPORT

1	Name & address of the building	New Evergreen Public School, C-138, Vikas Vihar Bharat Vihar) Kakrola, New Delhi-110078.		
2	Type of Occupancy	Educational Building "B" (Ground + First Floor)		
3	Type of case	Renewal		
4	Details of previous NOC	F6FS/MS/School/2013/SZ/905 dated 12.9.2013		
5	Fire safety directives letter No	Edu. Circular. No. F.16/Estate/CC/Fire Safety/2011/3298 dated 01.03.2011.		
6	Date of inspection	15.12.2016		
7	Name of the inspecting Officers :	ADO S.P. Bhardwaj		
8	Name and designation of officers from the building side	Mrs. Sunita (Principal)		
9	Year of construction	Before 2010		
10	Applicant's letter No.	Nil Dated 21.11.2016	Management has constructed Two rooms at Second floor, are being used as servant residence	
S. NO.	Minimum Standards on fire prevention and fire safety U/R 33	D.O.E letter dated 01.03.2011	Provided at site	Remarks MR / NMR
1	Access to building			
	1) Road width	6 Mtrs.	6 Mtrs.	MR
	2) Gate width	4.5 Mtrs.	5 Mtrs.	MR
	3) Width of internal road	N/A	N/A	N/A
2	Number, width Type & arrangement of exits			
	a. Number of staircases			
	1. Upper floors	2 Nos.	2 Nos.	MR
	2. basements	N/A	N/A	N/A
	b. Width of staircase			
	1. Upper floors	1.5 Mtrs. or Less plus .75 Mtr.	1.00 & .97 Mtrs.	MR
	2. basements	N/A	N/A	N/A
	c. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	d. No. of continuous staircase to terrace	One	One	MR
	e. Width of corridor	N/A	N/A	N/A
	f. Door size	1 Mtr.	1 Mtr.	MR
3	Compartmentation.			
	1. Fire check door	N/A	N/A	N/A
	2. Sealing of electrical shafts	N/A	N/A	N/A
	3. Fire Rating of shaft door	N/A	N/A	N/A
	4. water curtain	N/A	N/A	N/A
	5. Fire dampers	N/A	N/A	N/A
4	Smoke Management system.			
	basement	N/A	N/A	N/A
	upper floors	N/A	N/A	N/A
5	Fire Extinguishers			
	total numbers	Two nos. each floor	5 Nos.	MR
	Types	Co2 OR ABC	ABC	MR

6	First-Aid Hose Reels.			
	total numbers on each floor	N/A	One	MR
	Length of Hose reel hose	N/A	30 M	MR
	Nozzle Diameter	N/A	5MM	MR
7	Automatic fire detection and alarming system			
	Type of detectors	N/A	N/A	N/A
	location of Main Panel	N/A	N/A	N/A
	location of Repeater panel	N/A	N/A	N/A
	Alternate source of power	N/A	N/A	N/A
	hooter's location	N/A	N/A	N/A
8	MOEFA	N/A	N/A	N/A
9	Public Address System.	N/A	Provided	N/A
10	Automatic Sprinkler System.			
	basement	N/A	N/A	N/A
	upper floors	N/A	N/A	N/A
	sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	Size of riser/down-corner	N/A	N/A	N/A
	Number of Hydrants per floor	N/A	N/A	N/A
	hose Box	N/A	N/A	N/A
12	Yard Hydrants.			
	total number of hydrants	N/A	N/A	N/A
	hose box	N/A	N/A	N/A
13	Pumping arrangements			
	1. Ground level			
	a. Discharge of main Pump	N/A	N/A	N/A
	b. Head of main pump	N/A	N/A	N/A
	c. Number of main pumps	N/A	N/A	N/A
	d. jockey pump out put	N/A	N/A	N/A
	e. jockey pump head	N/A	N/A	N/A
	f. Standby Pump output	N/A	N/A	N/A
	g. Stanby Pump head	N/A	N/A	N/A
	h. Auto Starting/Manual stopping	N/A	N/A	N/A
	pump house access	N/A	N/A	N/A
	2. Terrace level			
	a. Discharge of pump	N/A	280 LPM	N/A
	b. head of the pump	N/A	30 M	N/A
	c. Power supply	N/A	Providede	N/A
	d. Auto starting of pump	N/A	Provided	N/A
14	Captive water storage for fire fighting			
	1. Underground tank capacity	N/A	N/A	N/A
	a. Draw-off connection	N/A	N/A	N/A
	b. fire service inlet	N/A	N/A	N/A
	c. Access to tank	N/A	N/A	N/A
	Over head tank Capacity	N/A	2500 Ltrs.	N/A
15	Exit Signage.	N/A	N/A	N/A
16	Provision of lifts.			
	a. Pressurization of lift shaft	N/A	N/A	N/A
	b. pressurization of lift lobby	N/A	N/A	N/A
	c. communication in lift car	N/A	N/A	N/A
	d. Fireman's grounding switch	N/A	N/A	N/A
	e. Lift signage	N/A	N/A	N/A

119

17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.	Not Required		
	total area			
	location			
19	Fire control room			
	a. detector system Panel	N/A	N/A	N/A
	b. Flow switch Panel	N/A	N/A	N/A
	c. PA system Panel	N/A	N/A	N/A
	d. Batter backup	N/A	N/A	N/A
	e. Building floor plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special risks, if any: ABC Fire extinguisher near electric meter	MR		

The fire protection system provided in the building were checked and found functional at the time of inspection.

Keeping in view deemed compliance of the minimum standards on fire prevention and fire safety required under the rules, renewal of fire safety certificate vide letter no. F6/DFS/MS/School/2013/SZ/905 dated 12.9.2013 for ground and first floor is recommended under rule 37 of the Delhi Fire Service Rules 2010.

Accordingly DFA is put up for approval and signature please.

S.P. Bhardwaj
16/12/16

Signature of the Inspecting Officer

Name S.P. Bhardwaj

Designation ADO (Dwarka)

DOSW

487/DOSW
dt- 19.12.16

[Signature]
19/12/16

DCFO(SZ)

488/CP-12
26/12/16

[Signature]
22/12

Chief Fire Officer
South Zone
No. of Receipt.....
No. of FPW.....
No. of Dispatch.....

cto (sz)

FTM
m-scell *[Signature]*
23/12



FT letter is put up for signature please.

S.P. Bhardwaj
21/12/16

[Signature]
m-scell *[Signature]*
4/11