

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE ,NEW DELHI- 110001**



NO.F6/DFS/MS/EH/2016/SZ/ 22

Dated: 06.01.2017

**FIRE SAFETY CERTIFICATE**

Certified that the **Restaurant Drool Kitchen** (A unit of 4RS Hospitality Pvt. Ltd.) located at ground floor of Commercial space Metro Station Sector-10, Dwarka, New Delhi 110075, was granted NOC By this department vide letter no. F6/DFS/MS/EH/2012/2962 dated 14.08.2012. The building was re-inspected by the officer concerned of this department on 15.12.2016 in presence of Sh. Suresh Kumar (Manager) and found that the premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building/Premises is fit for occupancy class "Assembly" D with effect from...06.01.2017 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010, printed overleaf.

Issued on ...06.01.2017... at New Delhi by

  
(Vipin Kental)  
Chief Fire Officer  


Copy To:-

1. The Director, 4RS Hospitality, No-17, Sector-14A, Pocket-1, Dwarka, New Delhi-110075.

## CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
8. The owner / occupier shall apply for renewal of this **Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37)** along with copy of the certificate, six months prior to its expiry.

ADO Dwarka

## INSPECTION REPORT

1	Name & address of the building	Restaurant "DROOL KITCHEN" (Aunit of 4RS Hospitality Pvt. Ltd.) at Metro Commercial Space, Metro Station, Sector-10, Dwarka, New Delhi-11075	
2	Type of Occupancy	Assembly "D"	
3	Type of case	Renewal (Restaurant Ground floor)	
4	Details of previous NOC	F6/DFS/MS/EH/2012/2962 dated 14.08.2012	
5	Fire safety directives letter No	Nil	
6	Date of inspection	15.12.2016	
7	Name of the inspecting Officers :	DO M K Chattoupadhyay, ADO S.P. Bhardwaj	
8	Name and designation of officers from the building side	Sh. Suresh Kumar (Manager)	
9	Year of construction	2010	
10	Applicant's letter No.	Nil dated 25.11.2016	<b>Restaurant at groun floor at Metro Station Sector-10 Dwarka.</b>

S. NO.	Minimum Standards on fire prevention and fire safety U/R 33	Fire safety requirements as per letter dated 17.11.2006	Provided at site	Remarks MR / NMR
--------	---	---	------------------	------------------

<b>1</b>	<b>Access to building</b>			
	1) Road width	12 Mtrs.	12 Mtrs.	MR
	2) Gate width	4.5 Mtrs.	Direct Accessible from road	MR
	3) Width of internal road	6 Mtrs.	6 Mtrs.	MR

<b>2</b>	<b>Number, width Type &amp; arrangement of exits</b>			
	<b>a. Number of staircases</b>			
	1. Upper floors	N/A	N/A	N/A
	2. basements	N/A	N/A	N/A
	<b>b. Width of staircase</b>			
	1. Upper floors	N/A	N/A	N/A
	2. basements	N/A	N/A	N/A
	<b>c. Protection of exits</b>			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	<b>d. No. of continuous staircase to terrace</b>	N/A	N/A	N/A
	<b>e. Width of corridor</b>	N/A	N/A	N/A
	<b>f. Door size</b>	2 Mtrs.	2 Mtrs. 1.08 Mtrs.	MR

<b>3</b>	<b>Compartmentation.</b>			
	1. Fire check door	N/A	N/A	N/A
	2. Sealing of electrical shafts	N/A	N/A	N/A
	3. Fire Rating of shaft door	N/A	N/A	N/A
	4. water curtain	N/A	N/A	N/A
	5. Fire dampers	N/A	N/A	N/A

<b>4</b>	<b>Smoke Management system.</b>			
	basement	12 ac charge	N/A	N/A
	Ground Floor		Exhaust Fan Provided	MR
	upper floors		N/A	N/A

<b>5</b>	<b>Fire Extinguishers</b>			
	total numbers	8 Nos. ABC	8 Nos.	MR
	Types	ABC	ABC	MR

<b>6</b>	<b>First-Aid Hose Reels.</b>			
	total numbers on each floor	1 No.	Provided	MR
	Length of Hose reel hose	30 M	Provided	MR
	Nozzle Diameter	5 mm	Provided	MR
<b>7</b>	<b>Automatic fire detection and alarming system</b>			
	Type of detectors	Smoke	Provided	MR
	location of Main Panel	Reception	Reception	MR
	location of Repeater panel	N/A	N/A	N/A
	Alternate source of power	Required	Battery Backup	MR
	hooter's location	Near Entry	Provided	MR
<b>8</b>	<b>MOEFA</b>	Required	Provided	MR
<b>9</b>	<b>Public Address System.</b>	Required	Provided	MR
<b>10</b>	<b>Automatic Sprinkler System.</b>			
	basement	N/A	N/A	N/A
	upper floors	Ground floor	Provided	MR
	sprinkler above false ceiling	N/A	N/A	N/A
<b>11</b>	<b>Internal Hydrants</b>			
	Size of riser/down-corner	100 mm.	Provided	MR
	Number of Hydrants per floor	Ground floor	Two	MR
	hose Box	Required	Provided	MR
<b>12</b>	<b>Yard Hydrants.</b>			
	total number of hydrants	N/A	N/A	N/A
	hose box	N/A	N/A	N/A
<b>13</b>	<b>Pumping arrangements</b>	<b>System Connected to Metro Station</b>		
	<b>1. Ground level</b>			
	a. Discharge of main Pump	1800 LPM	1800 LPM	MR
	b. Head of main pump	70 Mtrs.	70 Mtrs.	MR
	c. Number of main pumps	One	One	MR
	d. jockey pump out put	180 LPM	180 LPM	MR
	e. jockey pump head	70 Mtrs.	70 Mtrs.	MR
	f. Standby Pump output	1800 LPM	1800 LPM	MR
	g. Stanby Pump head	70 Mtrs.	70 Mtrs.	MR
	h. Auto Starting/Manual stopping	Required	Provided	MR
	pump house access	Required	Provided	MR
	<b>2. Terrace level</b>			
	a. Discharge of pump	N/A	N/A	N/A
	b. head of the pump	N/A	N/A	N/A
	c. Power supply	N/A	N/A	N/A
	d. Auto starting of pump	N/A	N/A	N/A
<b>14</b>	<b>Captive water storage for fire fighting</b>			
	1. Underground tank capacity	50000 Ltrs.	50000 Ltrs.	MR
	a. Draw-off connection	Required	Provided	MR
	b. fire service inlet	Required	Provided	MR
	c. Access to tank	Required	Provided	MR
	Over head tank Capacity	N/A	N/A	N/A
<b>15</b>	<b>Exit Signage.</b>	Required	Provided	MR
<b>16</b>	<b>Provision of lifts.</b>			
	a. Pressurization of lift shaft	N/A	N/A	N/A
	b. pressurization of lift lobby	N/A	N/A	N/A
	c. communication in lift car	N/A	N/A	N/A
	d. Fireman's grounding switch	N/A	N/A	N/A
	e. Lift signage	N/A	N/A	N/A


N/15


17	Standby power supply	Required	DG Set 125 KVA	MR
18	Refuge Area.	Not Required		
	total area			
	location			
19	Fire control room			
	a. detector system Panel	N/A	N/A	N/A
	b. Flow switch Panel	N/A	N/A	N/A
	c. PA system Panel	N/A	N/A	N/A
	d. Batter backup	N/A	N/A	N/A
	e. Building floor plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special risks, if any: Co2 fire extinguisher provided for electric panel. MR			

The fire protection systems provided in the building were checked and found functional at the time of inspection. Shortcomings vide letter no. F6/DFS/MS/South/2595 dated 15.12.2015 found rectified.

Keeping in view deemed compliance of the minimum standard of fire prevention and fire safety required under the rule, renewal of FSC issued vide letter no. F6/DFS/MS/EH/2012 dated 14.08.2012 is recommended under 37 of the Delhi Fire Service Act 2007 & Rules 2010.


Accordingly DFA is put up for approval and signature please.

  
 Signature of the Inspecting Officer-II  
 Name M K Chattopadhyay  
 Designation DO (South West)

  
 Signature of the Inspecting Officer  
 Name S.P. Bhardwaj  
 Designation ADO (Dwarka)


362/DO(SW)  
 19/12/16

DCFO (SZ)

  
 22/12

483/CP/SZ  
 20/12

UFO (SZ)

  
 m-skell  
 23/12

