

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/2017/29

Dated: 06.01.2017

FIRE SAFETY CERTIFICATE

Certified that the **Delhi Metro Rail Corporation** located at **Tagore Garden Metro Station (Except PD area)** comprised of Ground, Concourse and Platform was issued FSC vide letter no. **F.6/DFS/MS/2014/WZ/131 dated 30/01/2014**. The premises was re inspected by the officer concerned of this department on **15-12-2016** in the presence of **Sh. Kumar Waibhav (AM/Fire)** and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and that the building / premises is fit for the occupancy class "Assembly" Group D Sub Division D - 7 with effect from 06.01.2017 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 06.01.2017 at New Delhi by.


(Atul Garg)

Chief Fire Officer,
Delhi Fire Service.

Copy to:

1. Sh. Kumar Waibhav (AM/Fire),
DMRC, Metro Bhawan, Fire Brigade Lane, Barakhamba Road, New Delhi - 110001.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The basement shall be used as per building bye laws 1983.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
9. All the exit/passage must not be kept under lock and key & kept free from any obstruction.

INSPECTION REPORT

1. Name & address of the building : Tagore Garden Metro Station (Except PD area)
2. Type of Occupancy : Assembly
3. Type of Case : Renewal (Ground + Concourse + Platform)
4. Details of previous NOC : F.6/DFS/MS/2014/WZ/131 dated 30/01/2014
5. Fire Safety directives Letter No. : F6/DFS/MS/BP/2004/2283 dated 01-10-2004
6. Date of inspection : 15-12-2016
7. Name of the Inspecting Officer : Udai Vir Singh, ADO (WP)
8. Name and designation of Officer
from the building side : Sh. Kumar Waibhav (AM/Fire)
9. Year of Construction : 2005
10. Applicant's letter No. : DMRC/O&M/Fire/NOC/L-3/2016/52 dated 23/11/16

S No	Minimum standards on fire prevention and fire safety U/R 33	NBC Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	On main road	Provided	MR
	• Gate width	5m	On main road	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2	Provided	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	1.5 m	2 x 460 cm each platform	MR being old case
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	NA	NA	NA
	e. Width Of Corridor	1.5 m	197 cm	MR
	f. Door Size			
3.	Compartmentation			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire Rating of shaft door	Required	Provided	MR
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA
5.	Fire Extinguishers			
	• Total numbers	35	28 CO2, 7 WCO2	MR
	• Types	CO2 & WCO2	Provided	MR
	• IS marking	Required	Provided	MR
6.	First – Aid Hose Reels			
	• Total numbers on each floor	3 on each platform	Provided	MR
			Provided	MR

7.	Automatic fire detection and alarming system			
	• Type of detectors	Smoke	Provided	MR
	• Location of Main Panel	Required	Provided	MR
	• Location of Repeater Panel	Required	Provided	MR
	• Alternate source of power	Required	Provided	MR
	• Hooters' Location	Required	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	• Basements	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants			
	• Size of riser/down-comer	150mm	Provided	MR
	• Number of hydrants per floor	3 on each platform	Provided	MR
	• Hose Box	Required	Provided	MR
12.	Yard Hydrants			
	• Total number of hydrants	2	Provided	MR
	• Hose Box	Required	Provided	MR
13.	Pumping Arrangements			
	Ground Level	All the pumps are connected with generator also, OH water storage tank and overhead pumps of same capacity are provided in place of UGWST and pumps.		
	• Discharge of main pump	1800lpm	Provided at terrace	MR
	➤ Head of main pump	60m	Provided at terrace	MR
	➤ Number of main pumps	1	Provided at terrace	MR
	➤ Jockey pump out put	180lpm	Provided at terrace	MR
	➤ Jockey pump head	60m	Provided at terrace	MR
	➤ Standby Pump out put	1800lpm	Provided at terrace	MR
	➤ Standby Pump Head	60m	Provided at terrace	MR
	➤ Auto Starting/Manual stopping	Required	Provided at terrace	MR
	➤ Pump House Access	Required	Provided	MR
	• Terrace level			
	➤ Discharge of pump	NA	NA	NA
	➤ Head of the pump	NA	NA	NA
	➤ Power supply	NA	NA	NA
	➤ Auto starting of pump	NA	NA	NA
14.	Captive water Storage for fire fighting			
	• Under ground tank capacity	50000ltrs	Not Provided	MR (Provided at terrace)
	➤ Draw of connection	Required	Provided	MR
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	Required	Provided	MR
	• Overhead Tank capacity	NA	50000ltrs	MR
15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	Required	Provided	MR
	➤ Fireman's Grounding Switch	Required	Provided	MR
	➤ Lift Signage	Required	Provided	MR

18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	Required	Provided	MR
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	Required	Provided	MR
	➤ Battery backup	Required	Provided	MR
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risk, if any;	CO2 flooding for ASS, HT, LT panel	Provided	MR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no. F.6/DFS/MS/2014/WZ/131 dated 30/01/2014 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Signature of the ^{19/12} Inspecting Officer

Signature of the Inspecting Officer

Name Udai Singh

Name

Designation SO (WP)

Designation

D0/10

19/12/16

23/12/16

Dy. SO (WZ)

23/12/16

CPD - WZ