

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI- 110001



NO. F6/DFS/MS/School/2014/SZ/ 45

Dated: 10/01/17

FIRE SAFETY CERTIFICATE

Certified that the Delight Public School D-264, Nawada Housing Complex, Near Dwarka More, New Delhi-110059, located at ground and first floor in a building comprised of ground plus three upper floors was granted NOC by this department vide letter No.F6/ DFS/MS/2008/67 dated 10.1.2008 for **Ground and First floor** . The school building was re-inspected by the officer concerned of this department on 07.12.2016 in presence of Sh. Ankur Papreja (Manager) and found that the premises have deemed complied with the fire prevention and fire safety requirements in accordance with Directorate of Education GNCT of Delhi Circular No: 262-362 dated 17.01.2005 and that the school building is fit for occupancy of class B "Educational Building" **for ground & First floors** with effect from 10/01/17 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010 subject to conditions printed overleaf.

Issued on 10/01/17..... at New Delhi by


(Vipin Kental)
Chief Fire Officer


Copy to:

- 1 Dy. Director, (Education) GNCT of Delhi, Old Secretariat, New Delhi-110054.
- 2 Manager, Delight Public School D-264, Nawada Housing Complex, Near Dwarka More, New Delhi-110059.

CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner / occupier shall apply for renewal of this **Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37)** along with copy of the certificate, six months prior to its expiry.

INSPECTION REPORT

1	Name & address of the building	Delight Public School, D-264, Nawada Housing Complex, Near Dwarka Mode, New Delhi-110059.		
2	Type of Occupancy	Educational Building "B"		
3	Type of case	Renewal (Ground & First Floor)		
4	Details of previous NOC	F6/DFS/MS/School/08/1940 Dated 11.07.2008 (Ground & First floor)		
5	Fire safety directives letter No	DOE letter no. 262-362 dated 17.01.2005		
6	Date of inspection	07.12.2016		
7	Name of the inspecting Officers	ADO S.P. Bhardwaj		
8	Name and designation of officers from the building side	Sh. Ankur Papreja (Manager)		
9	Year of construction	Groun & First floor 2006, Second & third floor 2013-14.		
10	Applicant's letter No.	Nil dated 16.06.2016	Building Comprised of ground plus three upper floors	
S. NO.	Minimum Standards on fire prevention and fire safety U/R 33	Fire safety requirements as per letter dated 11.7.2008	Provided at site	Remarks MR / NMR
1	Access to building			
	1) Road width	6 Mtrs.	6 Mtrs.	MR
	2) Gate width	4.5 Mtrs.	Directly accessible from road.	M/R
	3) Width of internal road	N/A	N/A	N/A
2	Number, width Type & arrangement of exits			
	a. Number of staircases			
	1. Upper floors	Two	Two	MR
	2. basements	N/A	N/A	N/A
	b. Width of staircase			
	1. Upper floors	1 Mtr.	1 Mtr. Each	MR
	2. basements	N/A	N/A	N/A
	c. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	d. No. of continuous staircase to terrace	One	One	MR
	e. Width of corridor	1.5 Mtrs.	2.41 Mtrs.	MR
	f. Door size	1 Mtr.	1 Mtr.	MR
3	Compartmentation.			
	1. Fire check door	N/A	N/A	N/A
	2. Sealing of electrical shafts	N/A	N/A	N/A
	3. Fire Rating of shaft door	N/A	N/A	N/A
	4. water curtain	N/A	N/A	N/A
	5. Fire dampers	N/A	N/A	N/A
4	Smoke Management system.			
	basement	N/A	N/A	N/A
	upper floors		N/A	N/A
5	Fire Extinguishers			
	total numbers	Two at each floor	4 Nos.	MR
	Types	ABC /CO2		

6	First-Aid Hose Reels.			
	total numbers on each floor	One	Provided	MR
	Length of Hose reel hose	30 m	Provided	MR
	Nozzle Diameter	5 mm	Provided	MR
7	Automatic fire detection and alarming system			
	Type of detectors	N/A	N/A	N/A
	location of Main Panel	N/A	N/A	N/A
	location of Repeater panel	N/A	N/A	N/A
	Alternate source of power	N/A	N/A	N/A
	hooter's location	N/A	N/A	N/A
8	MOEFA	N/A	N/A	N/A
9	Public Address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	basement	N/A	N/A	N/A
	upper floors	N/A	N/A	N/A
	sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	Size of riser/down-corner	N/A	N/A	N/A
	Number of Hydrants per floor	N/A	N/A	N/A
	hose Box	N/A	N/A	N/A
12	Yard Hydrants.			
	total number of hydrants	N/A	N/A	N/A
	hose box	N/A	N/A	N/A
13	Pumping arrangements			
	1. Ground level			
	a. Discharge of main Pump	N/A	N/A	N/A
	b. Head of main pump	N/A	N/A	N/A
	c. Number of main pumps	N/A	N/A	N/A
	d. jockey pump out put	N/A	N/A	N/A
	e. jockey pump head	N/A	N/A	N/A
	f. Standby Pump output	N/A	N/A	N/A
	g. Stanby Pump head	N/A	N/A	N/A
	h. Auto Starting/Manual stopping	N/A	N/A	N/A
	pump house access	N/A	N/A	N/A
	2. Terrace level			
	a. Discharge of pump	220 LPM	220 LPM	MR
	b. head of the pump	30 M	Provided	MR
	c. Power supply	Required	Provided	MR
	d. Auto starting of pump	N/A	N/A	N/A
14	Captive water storage for fire fighting			
	1. Underground tank capacity	N/A	N/A	N/A
	a. Draw-off connection	N/A	N/A	N/A
	b. fire service inlet	N/A	N/A	N/A
	c. Access to tank	N/A	N/A	N/A
	Over head tank Capacity	2500 Ltrs.	2500 Ltrs.	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of lifts.			
	a. Pressurization of lift shaft	N/A	N/A	N/A
	b. pressurization of lift lobby	N/A	N/A	N/A
	c. communication in lift car	N/A	N/A	N/A
	d. Fireman's grounding switch	N/A	N/A	N/A
	e. Lift signage	N/A	N/A	N/A

17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.	Not Required		
	total area			
	location			
19	Fire control room			
	a. detector system Panel	N/A	N/A	N/A
	b. Flow switch Panel	N/A	N/A	N/A
	c. PA system Panel	N/A	N/A	N/A
	d. Battery backup	N/A	N/A	N/A
	e. Building floor plans	N/A	Provided	N/A
20	Special Fire Protection systems for protection of special risks, if any: Co2 fire extinguisher provided near electric meter MR			

Fire protection system provided in the building checked and found functional at the time of inspection.

Keeping in view deemed compliance of minimum standards on fire prevention and fire safety measures under the rules, renewal of Fire safety certificate issued vide letter no. F6/DFS/MS/School/08/1940 Dated 11.07.2008 for Ground and First floor is recommended under rule 37 of the Delhi Fire Service Rules 2010.

Accordingly DFA is put up for approval and signature please.

Sum
27/12/16

Signature of the Inspecting Officer

Name S.P. Bhardwaj

Design. ADO (Dwarka)

~~DOCSW~~

Where is the affidavit / declaration of the owner for not using second floor? whether sealed or not?

~~ADO (Dwrk)~~

dy
08/12/16

Declaration submitted by the management is placed at C-11 of the file please.

426/DOCSW
19.12.2016

~~DOCSW~~ *dy* 19/12/16

Sum
15/12/16

~~DCFO (SZ)~~ *Kamp*
27/12

