

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No. F6/DFS/MS/GH/SZ/2016/47


Dated: 12/01/17

**FIRE SAFETY CERTIFICATE**

Certified that M/s **Aura De Asia** guest house located at 1/12, West Patel Nagar, New Delhi-110008, comprised of Basement (hall & store), stilt (parking & office), ground floor (reception and 08 guest rooms), first floor (11 guest rooms), second floor (11 guest rooms) and third floor (11 guest rooms) was issued FSC by this department vide letter no. F.6/DFS/MS/GH/SZ/2013/787 dated 23.08.2013 for 41 guest rooms. The guest house was re-inspected by the officer concerned of this department on 27.12.2016 in presence of Mr. Rishi Kumar, manager and found the guest house is using basement floor as Storage/ Hall, stilt floor for parking and reception, ground floor as waiting lobby and hall, first, second & third floor each having eleven guest rooms (Total 33 guest rooms) and one staff room & pantry for staff on terrace floor and also found that the owner have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building/premises is fit for occupancy class residential (Guest house) w.e.f. the date of issue of this certificate for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010 printed overleaf.

Issued on 12/01/17 at New Delhi.

  
(VIPIN KENTAL)  
CHIEF FIRE OFFICER

92   
20/1/2017

Copy to: -

1. The Joint C.P..C.P (Lic.), Police Station,  
Defence Colony, 1<sup>st</sup> floor, New Delhi.
2. The Manager,  
M/s Aura De Asia guest house,  
1/12, West Patel Nagar,  
New Delhi-110008

Following fire safety directives must be adhered to: -

- a. All the fire safety and means of escape facilities shall be maintained in good working conditions at all time. Any lapse rendering fire safety or means of evacuation facilities rendering non-functional shall be the responsibility of the management.
- b. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
- c. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
- d. Building Sanctioning authority may verify any deviation with regard to the construction / occupancy in the building. In case of any deviation, the fire safety certificate stands null and void.
- e. Basement shall be used as per the building bye laws.
- f. The staffs shall be trained for operating fire fighting system and mock evacuation drills be conducted at regular intervals and record be maintained.
- g. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on website [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
- h. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' (sub rule (1) of rule 37) along with a copy of this Certificate, six months prior to its expiry.

## INSPECTION REPORT

1. Name & address of the building : M/s Aura De Asia guest house, 1/12, West Patel Nagar, New Delhi- 110008
2. Type of Occupancy : Lodging House
3. Type of Case : Renewal
4. Details of previous NOC : F.6/DFS/MS/GH/SZ/2013/787 dated 23.08.2013
5. Fire Safety directives letter No : N/A.
6. Date of inspection : 27-12-2016
7. Name of the Inspecting Officers : M.K. Chattopadhyay, Divisional Officer (South West)
8. Name and designation of officers  
from the building side : Mr. Rishi Kumar, manager
9. Year of Construction : Before 2010
10. Applicant's letter No. : 4142-43/Joint C.P./Lic(H) dated New Delhi the 24.11.2016

The said guest house is comprised of basement, stilt, ground plus three upper floors .

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Requirement as per letter No.- 14.05.2012	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	• Road width	06 mts	Provided	MR
	• Gate width	4.5 mts	Directly accessible	MR
	• Width of internal road	N/A	N/A	N/A
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases	-	-	-
	• Upper Floors	01	Provided	MR being old case
	• Basements	02	Provided	MR
	b. Width of staircases	-	-	-
	• Upper Floors	1.25 mts.	1.28 mts.	MR
	• Basements	1.25 mts.	1.25, 1.23 mts	MR being old case
	c. Protection of exits	-	-	-
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	e. No. of continuous staircases to terrace	01	01	MR
	g. Width of Corridor	1.25 mts	1.45 mts	MR
	h. Door Size	Old case	Provided (0.87 mt.)	MR being old case
3	<b>Compartmentation.</b>			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4	<b>Smoke Management System.</b>			
	• Basements	30 a/c per hour	Exhaust fan provided	MR
	• Upper floors	12 a/c per hour	Natural ventilation	MR
5	<b>Fire Extinguishers</b>			

		ISI marked	Provided	MR
6	<b>First-Aid Hose Reels.</b>			
	• Total numbers on each floor	01	Provided	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR
7	<b>Automatic fire detection and alarming system.</b>			
	• Type of detectors	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooters' Location	N/A	N/A	N/A
8	<b>MOEFA</b>	Required	Provided	MR
9	<b>Public Address System.</b>	Required	Provided	MR
10	<b>Automatic Sprinkler System.</b>			
	• Basement	Required	Provided	MR
	• Upper Floor	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11	<b>Internal Hydrants</b>			
	• Size of riser/down-comer	N/A	80 mm provided	----
	• Number of hydrants per floor	N/A	01 No.	----
	• Hose Box	N/A	01 No.	----
12	<b>Yard Hydrants.</b>			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	<b>Pumping Arrangements.</b>			
	• Ground Level	---	---	---
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey Pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Starting/ Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace level	-----	-----	-----
	➤ Discharge of pump	450 LPM X 02	Provided (02 nos.)	MR
	➤ Head of the pump	30 mts each	30 mts each	MR

**Captive Water Storage for fire fighting.**


	<ul style="list-style-type: none"> <li>• Underground tank capacity</li> <li>➤ Draw-off connection</li> <li>➤ Fire service inlet</li> <li>➤ Access to tank</li> <li>• Overhead Tank capacity</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		10,000 lts	Provided (10,000 lts)	MR being old case
15	<b>Exit Signage.</b>	Required	Provided	MR
16	<b>Provision of Lifts.</b>			
	<ul style="list-style-type: none"> <li>• Pressurization of Lift Shaft</li> <li>• Pressurization of Lift lobby</li> <li>• Communication In lift Car</li> <li>• Fireman's Grounding Switch</li> <li>• Lift Signage</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
17	<b>Standby power supply</b>	Required	Provided	MR
18	<b>Refuge Area.</b>			
	<ul style="list-style-type: none"> <li>➤ Total Area</li> <li>➤ Location</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
19	<b>Fire Control Room</b>			
	<ul style="list-style-type: none"> <li>• Detector System Panel</li> <li>• Flow Switch Panel</li> <li>• PA System Panel</li> <li>• Batter backup</li> <li>• Building Floor Plans</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	Required	Two ABC type fire extinguisher found provided near elect. panel	MR

The fire protection system provided in the building were checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules the FSC issued vide letter no. F.6/DFS/MS/GH/SZ/2013/787 dated 23.08.2013, renewal under rules 35 of the Delhi Fire Service Rules 2010 is recommended.

Accordingly, DFA is put up please.

**Note:** - The guest house is internally renovated and certain changement have been done. Reception is shifted from ground floor to still floor. Guest rooms at ground floor have been removed and converted to hall & waiting lobby. Total 33 guest rooms provided at first, second & third floor (11 rooms at each floor)

  
 30/12/2016  
 M.K. CHATTOPADHYAY  
 Divisional Officer (South West)

509/CF/S2  
4/1/11/1

DCFO (SZ)

