

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110 001

No.

F6/DFS/MS/2017/52/60

Dated: 13/01/17

FIRE SAFETY CERTIFICATE

Certified that **M/s Auditorium building at National Academy of Medical Sciences (India), Ansari Nagar, Mahatma Gandhi Marg, New Delhi-110029**, comprised of small basement for electric panel only, ground plus one upper floor, Auditorium at ground floor only without balcony, owned/occupied by National Academy of Medical Sciences (India) was granted No Objection Certificate by this department vide letter no. **F6/DFS/MS/2008/629, dated 03.08.2008**. The premises was re-inspected by the officer concerned of this department on **10.12.2016** in the presence of Sh A.K.Chanana, Chief Technical Advisor and found that the building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building is fit for **Occupancy Class-D Assembly Building(Auditorium)** with effect from **13/01/.....2017** for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on **13/01/.....2017** at New Delhi by


13/1
(Vipin Kental)

Chief Fire Officer

T.No.011-23412225

- Copy To:- 1. Joint C.P.Licensing, PS Defence Colony, New Delhi.
2. M/s National Academy of Medical Sciences (India), Ansari Nagar, Mahatma Gandhi Marg, New Delhi-110029.

Conditions for the validity of fire safety certificate

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate in form J, six month prior to its expiry.

1	Name & address of the building	M/s Auditorium building at National Academy of Medical Sciences (India), Ansari Nagar, Mahatma Gandhi Marg, New Delhi-110029.		
2	Type of Occupancy	Group "D" Assembly Building.		
3	Building Comprised of	Basement, ground plus one upper floor. (Auditorium at ground floor only <u>without balcony</u> & a very small basement for electric pannel only). At 1st floor offices.		
4	Type of case	Renewal		
5	Details of previous NOC	F6/DFS/MS/2008/629, dated 03.08.2008.		
6	Fire safety directives letter No	F6/DFS/MS/BP/94/173, Dated 15.12.1994.		
7	Date of inspection	10.12.2016.		
8	Name of the inspecting Officers	ADO Vedpal		
9	Name and designation of officers from the building side	Sh. A.K.Chanana, Chief Technical Advisor		
10	Year of construction	1998		
11	Applicant's letter No.	No.21-1/2016/NAMS/4621, Dated 09.11.2016		
S. NO.	Minimum Standards on fire prevention and fire safety U/R 33	Requirements as per Directives dated 15.12.94	Provided at site	Remarks MR / NMR
1	Access to building			
	1) Road width	Accessible	24m	MR
	2) Gate width	5m	5m	MR
	3) Width of internal road	N/A	N/A	N/A
2	Number, width Type & arrangement of exits			
	a. Number of staircases			
	1. Upper floors	01no.	01no.	MR
	2. Basements	01no.	01no.	MR
	b. Width of staircase			
	1. Upper floors	1.25m	1.40m	MR
	2. basements	1.25m	1.25m	MR
	c. Protection of exits			
	1. Fire check door	Required	Provided	MR
	2. Pressurization	N/A	N/A	N/A
	d. No. of continuous staircase to terrace	01no.	01no.	MR
	e. Width of corridor	1.2m	1.2m	MR
	f. Door size	1.2m(each)	05 Exit gates at ground floor=1.20m(each)	MR
3	Compartmentation.			
	1. Fire check door	Required	Provided in basement	MR
	2. Sealing of electrical shafts	Required	Provided	MR
	3. Fire Rating of shaft door	N/A	N/A	N/A
	4. water curtain	N/A	N/A	N/A
	5. Fire dampers	N/A	N/A	N/A
4	Smoke Management system.			
	Basement	30 a/c per hour	Exhaust Fans	MR
	Upper floors	12 a/c per hour	Provided	MR
5	Fire Extinguishers			
	Total numbers	10Nos	14 Nos. Provided	MR
	Types	ABC, CO2 & WCO2	ABC, W CO2 & CO2	MR
	ISI marking	ISI	Provided	MR
6	First-Aid Hose Reels.			
	Total numbers on each floor	02nos. At ground floor only	02nos. At ground floor only	MR
	Length of Hose reel hose	30 Mtr	Provided	MR
	Nozzle Diameter	5mm	Provided	MR
7	Automatic fire detection and alarming system			
	Type of detectors	N/A	Somke Detector	N/A
	Location of Main Panel	N/A	Provided	N/A
	Location of Repeater panel	N/A	Ground Floor	N/A
	Alternate source of power	N/A	N/A	N/A
	Hooter's location	N/A	Battery Backup	N/A
		N/A	Provided	N/A
8	MOEFA	N/A	Provided	N/A
9	Public Address System.	N/A	Provided	N/A
10	Automatic Sprinkler System.			
	Basement	N/A	N/A	N/A


INSPECTION REPORT



11	Internal Hydrants			
	Size of riser/down-corner	N/A	N/A	N/A
	Number of Hydrants per floor	N/A	N/A	N/A
	hose Box	N/A	N/A	N/A
12	Yard Hydrants.			
	total number of hydrants	N/A	N/A	N/A
	house box	N/A	N/A	N/A
13	Pumping arrangements			
	1. Ground level			
	a. Discharge of main Pump	Boosting	450 LPM	MR
	b. Head of main pump	Required	40 Mtr	MR
	c. Number of main pumps	01no.	01no.	MR
	d. jockey pump out put	N/A	N/A	N/A
	e. jockey pump head	N/A	N/A	N/A
	f. Standby Pump output	N/A	N/A	N/A
	g. Stanby Pump head	N/A	N/A	N/A
	h. Auto Starting/Manual stopping	Required	Provided	MR
	pump house access	Required	Provided	MR
	2. Terrace level		Old Case	
	a. Discharge of pump	N/A	N/A	N/A
	b. head of the pump	N/A	N/A	N/A
	c. Power supply	N/A	N/A	N/A
	d. Auto starting of pump	N/A	N/A	N/A
14	Captive water storage for fire fighting			
	1. Underground tank capacity	25,000 ltr	100,000 Ltr Provided	MR
	a. Draw-off connection	Required	Provided	MR
	b. fire service inlet	Required	Provided	MR
	c. Access to tank	Required	Provided	MR
	Over head tank Capacity	2500 ltr	10,000 ltr Provided	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of lifts.			
	a. Pressurization of lift shaft	N/A	N/A	N/A
	b. pressurization of lift lobby	N/A	N/A	N/A
	c. communication in lift car	N/A	N/A	N/A
	d. Fireman's grounding switch	N/A	N/A	N/A
	e. Lift signage	N/A	N/A	N/A
17	Standby power supply	Required	Provided	MR
18	Refuge Area.			
	total area	N/A	N/A	N/A
	location	N/A	N/A	N/A
19	Fire control room			
	a. Detector system Panel	N/A	Provided	N/A
	b. Flow switch Panel	N/A	N/A	N/A
	c. PA system Panel	N/A	Provided	N/A
	d. Batter backup	Required	Provided	MR
	e. Building floor plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special risks, if any: CO2 local flooding provided for electric panel.			



The fire protection systems provided in the building were checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards on fire prevention and fire safety required under the rules the NOC issued vide letter No.F.6/MS/DFS/2008/629, dated 03.08.2008 renewal under rule 37 of the Delhi Fire Service Rule 2010 is recommended.

Accordingly DFA is put up for your approval and signature please.


 Signature of the Inspecting Officer
 Name Vedpal
 Designation : ADO

 D/O (S.D.)
 J. Singh
 9/11/17

 Dy. CPO (S2)
 J. Singh

FTM.

