

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110 001**

NO. *F6/dfs/ms/school/2017/SZ/57*

Dated: *13/01/17*

FIRE SAFETY CERTIFICATE

Certified that M/s Gyan Public School, located at Bijwasan, New Delhi-110061, comprised of ground plus two upper floors, owned/occupied by M/s Gyan Public School, was granted Fire Safety Certificate by this department vide letter No.F6/DFS/MS/School/2014/SZ/23, dated 08.01.2014. The premises was re-inspected by the officer concerned of this department on 07-01-2017 in the presence of Sh. Satish, Manager of the school and found that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of Delhi Fire Service Rules 2010 and that the building is fit for occupancy class-B "Educational" with effect from *13/01/2017* for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of Delhi Fire Service Rules,2010.

Issued on *13/01/2017* at New Delhi by

W
13/1

(Vipin Kental)

Chief Fire Officer

T. No.011- 23412225

OTC
E

Copy to:-1. Director of Education, Old Secretariat, Civil Lines, Delhi-54.

2. Principal, M/s Gyan Public School, located at Bijwasan, New Delhi-110061.

Conditions for the validity of fire safety certificate are as under:-

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. The employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All fire fighting equipments shall be maintained in perfect working condition all time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate, six month prior to its expiry.

INSPECTION REPORT

1	Name & address of the building	M/s Gyan Public School, located at Bijwasan, New Delhi-110061.
2	Type of Occupancy	Educational Building "B"
3	Type of case	Renewal
4	Details of previous NOC	No.F6/DFS/MS/School/2014/SZ/23, Dated 08.01.2014.
5	Fire safety directives letter No	Nil.
6	Date of inspection	07.01.2017.
7	Name of the inspecting Officers	A.D.O. Vedpal.
8	Name and designation of officers from the building side	Sh. Satish Rana, Manager of the School.
9	Building Comprised of	Ground plus two upper floors.
10	Year of construction	1993
11	Applicant's letter No.	Nil, Dated 13.12.2016.

S. NO.	Minimum Standards on fire prevention and fire safety U/R 33	Requirement as per initial NOC (08.01.14)	Provided at site	Remarks MR / NMR
1	Access to building			
	1) Road width	Required	5m	MR(old case)
	2) Gate width	Required	4m	MR(old case)
	3) Width of internal road	N/A	N/A	N/A
2	Number, width Type & arrangement of exits			
	a. Number of staircases			
	1. Upper floors	02nos	02nos	MR
	2. basements	N/A	N/A	N/A
	b. Width of staircase			
	1. Upper floors	Required	1.05m & 90cm	MR(old case)
	2. basements	N/A	N/A	N/A
	c. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	d. No. of continuous staircase to terrace	01no.	01no.	MR
	e. Width of corridor	N/A	N/A	N/A
	f. Door size	1m	1m	MR
3	Compartmentation.			
	1. Fire check door	N/A	N/A	N/A
	2. Sealing of electrical shafts	N/A	N/A	N/A
	3. Fire Rating of shaft door	N/A	N/A	N/A
	4. water curtain	N/A	N/A	N/A
	5. Fire dampers	N/A	N/A	N/A
4	Smoke Management system.			
	basement	N/A	N/A	N/A
	Upper Floors		Natural Ventilation	MR
5	Fire Extinguishers			
	total numbers	06Nos	09nos.	MR
	Types	ABC & WCO2	ABC & Water CO2	MR
	ISI marking	ISI Mark	ISI Mark	MR
6	First-Aid Hose Reels.			
	total numbers on each floor	01no.	01no.	MR
	Length of Hose reel hose	30m	30m	MR
	Nozzle Diameter	5mm	5mm	MR
7	Automatic fire detection and alarming system			
	Type of detectors	N/A	N/A	N/A
	location of Main Panel	N/A	N/A	N/A
	location of Repeater panel	N/A	N/A	N/A
	Alternate source of power	N/A	N/A	N/A
	hooter's location	N/A	N/A	N/A
8	MOEFA	N/A	N/A	N/A
9	Public Address System.	Required	Provided	MR

10	Automatic Sprinkler System.			
	basement	N/A	N/A	N/A
	upper floors	N/A	N/A	N/A
	sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	Size of riser/down-corner	N/A	N/A	N/A
	Number of Hydrants per floor	N/A	N/A	N/A
	hose Box	N/A	N/A	N/A
12	Yard Hydrants.			
	total number of hydrants	N/A	N/A	N/A
	hose box	N/A	N/A	N/A
13	Pumping arrangements			
	1. Ground level	N/A	N/A	N/A
	a. Discharge of main Pump	N/A	N/A	N/A
	b. Head of main pump	N/A	N/A	N/A
	c. Number of main pumps	N/A	N/A	N/A
	d. jockey pump out put	N/A	N/A	N/A
	e. jockey pump head	N/A	N/A	N/A
	f. Standby Pump output	N/A	N/A	N/A
	g. Stanby Pump head	N/A	N/A	N/A
	h. Auto Starting/Manual stopping	N/A	N/A	N/A
	pump house access	N/A	N/A	N/A
	2. Terrace level			
	a. Discharge of pump	450LPM	450LPM	MR
	b. head of the pump	40m	40m	MR
	c. Power supply	Required	Provided	MR
	d. Auto starting of pump	Required	Provided	MR
14	Captive water storage for fire fighting			
	1. Underground tank capacity	N/A	N/A	N/A
	a. Draw-off connection	N/A	N/A	N/A
	b. fire service inlet	N/A	N/A	N/A
	c. Access to tank	N/A	N/A	N/A
	Over head tank Capacity	10000Liters	10000 Liters	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of lifts.			
	a. Pressurization of lift shaft	N/A	N/A	N/A
	b. pressurization of lift lobby	N/A	N/A	N/A
	c. communication in lift car	N/A	N/A	N/A
	d. Fireman's grounding switch	N/A	N/A	N/A
	e. Lift signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.	Not Required		
	total area	N/A	N/A	N/A
	location	N/A	N/A	N/A
19	Fire control room			
	a. detector system Panel	N/A	N/A	N/A
	b. Flow switch Panel	N/A	N/A	N/A
	c. PA system Panel	N/A	N/A	N/A
	d. Batter backup	N/A	N/A	N/A
	e. Building floor plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special risks, if any: N/A			

The fire protection systems provided in the building were test checked at random and found functional at the time of inspection. In view of the deemed compliance of the minimum standards on fire prevention and fire safety required under the rules, the FSC issued vide letter No: F6/DFS/MS/School/2014/SZ/23, dated 08.01.2014, renewal under rule 37 of the Delhi Fire Service Rule 2010 is recommended.

Accordingly DFA is put up for your approval and signature please.

Handwritten signature
Date: 8/1/17

Signature of the inspecting officer

Name: Vedpal



Handwritten signature

Handwritten initials