

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110 001

No. F6/DFS/MS/EH/2017/SZ/58

Dated: 13/01/17

FIRE SAFETY CERTIFICATE

Certified that M/s Lazeez Affaire Restaurant at 6/48, Malcha Marg, Shopping Centre, Diplomatic Enclave, Chankyapuri, New Delhi-21, comprised of Basement, Ground plus one upper floor but Restaurant is at ground and first floor only, owned/occupied by M/s Lazeez Affaire Restaurant was granted FSC by this department vide letter No. F6/DFS/MS/EH/2013/SZ/1142, dated 30-10-2013. The premises was re-inspected by the officer concerned of this department on 07-01-2017 in the presence of Sh. Ashish Bhatia, General Manager and found that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class "D" Restaurant at ground and first floor only with effect from 13/01/2017 for period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 13/01/2017 at New Delhi by.


(Vipin Kental)

Chief Fire Officer

T.No.011-23412225

- Copy to:- 1.D.E.O, Restt. GNCTD, Office of Commissioner of Excise Entt & Tax Dept,
L & J Block, I.P.Estate, New Delhi-110002. o/c
h
2. M/s Lazeez Affaire Restaurant at 6/48, Malcha Marg, Shopping Centre,
Diplomatic Enclave, Chankyapuri, New Delhi-21.

Conditions for the validity of fire safety certificate are as under:-

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. The employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All fire fighting equipments shall be maintained in perfect working condition all time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate, six month prior to its expiry.

INSPECTION REPORT

1. Name & address of the building : M/s Lazeez Affaire Restaurant at 6/48, Malcha Marg, Shopping Centre, Diplomatic Enclave, Chankyapuri, New Delhi-21.
2. Building is comprised of : Basement (storage), Ground plus one upper floor. (Restaurant is at ground and first floor only).
3. Type of Occupancy : Group-D, Assembly Building.
4. Type of Case : Old Case
5. Details of Previous NOC : No.F.6/DFS/MS/EH/2013/SZ/1142, dated-30.10.13.
6. Fire Safety direction letter No : Nil.
7. Date of Inspection : 07.01.2017.
8. Name of the Inspecting Officers : Vedpal (ADO)
9. Name and designation of Officer from the building side : Sh. Ashish Bhatia, General Manager.
10. Year of Construction : Not Known.
11. Applicant's letter No : No. Nil, dated 23.12.16.

S.No	Minimum Standards on fire prevention and fire safety U/R33	Requirements as per Old NOC (23.05.2006)	Provided at Site	Remarks
1	Access to building			
	Road width	Accessible	.5m	MR(old case)
	Gate width	N.A.	N.A.	N.A.
	Width of internal road	N.A.	N.A.	N.A.
2	Number, Width, Type and Arrangement of Exits.			
	a. Number of Staircases			
	Upper Floor	Required	01no.	MR(old case)
	Basement	Required	02nos.	MR(old case)
	B. Width of Staircases			
	Upper Floor	Required	1.20m	MR(old case)
	Basement	N.A.	1.10m & 1.05m	MR(old case)
	c. Protection of exits			
	Fire check door	N.A.	N.A.	N.A.
	Pressurization	N.A.	N.A.	N.A.
	e. No. of continuous staircases to terrace	N.A.	01no.	N.A.
g. Width of Corridor	N.A.	N.A.	N.A.	
h. Door Size	Required 2nos.	Provided at GF only	MR(old case)	
3	Compartmentation			
	Fire check door	N.A.	N.A.	N.A.
	Sealing of electrical shafts	N.A.	N.A.	N.A.
	Fire rating of shaft door	N.A.	N.A.	N.A.
	Water curtain	N.A.	N.A.	N.A.
	Fire Dampers	N.A.	N.A.	N.A.
4	Smoke Management System.			
	Basement	30a/c per hour	Exhaust Fans Provided	MR
	Upper floor	12 a/c per hour	Exhaust fans Provided	MR
5.	Fire Extinguisher			
	Total numbers	08 nos.	12 nos.	MR
	types	CO ₂ & ABC	CO ₂ & ABC	MR
	IS marking	ISI marked	ISI marked	MR
6	First-aid-Hose Reels.			
	Total numbers on each floor	01no.	01no.	MR
	Length of hose reel hose	30m	30m	MR

7	Automatic fire detection and alarming system.			
	Type of detectors	N.A.	Smoke & Heat	N.A.
	Location of main panel	N.A.	Basement	N.A.
	Location of repeater panel	N.A.	N.A.	N.A.
	Alternate source of power	N.A.	Provided	N.A.
	Hooters	N.A.	All Floors	N.A.
8	MOEFA	Required	Provided	MR
9	Public address System.	N.A.	N.A.	N.A.
10	Automatic Sprinkler System.			
	Basement	Required	Provided	MR
	upper floor	Required	Provided	MR
	sprinkler above false ceiling	N.A.	N.A.	N.A.
11	Internal Hydrants			
	size of riser/down-comer	100mm	100mm	MR
	Number of hydrants per floor	01no.	01no.	MR
	Hose Box	01no.	01no.	MR
12	Yard Hydrants.			
	Total number of hydrants	N.A.	N.A.	N.A.
	Hose Box	N.A.	N.A.	N.A.
13	Pumping Arrangements.			
	• Ground Level	N.A.	N.A.	N.A.
	➤ Discharge of main Pump	N.A.	N.A.	N.A.
	➤ Head of Main Pump	N.A.	N.A.	N.A.
	➤ Number of main pumps	N.A.	N.A.	N.A.
	➤ Jockey pump out put	N.A.	N.A.	N.A.
	➤ Jockey pump head	N.A.	N.A.	N.A.
	➤ Standby pump out put	N.A.	N.A.	N.A.
	➤ Standby pump Head	N.A.	N.A.	N.A.
	➤ Auto Starting /Manual stopping	N.A.	N.A.	N.A.
	➤ Pump House Access	N.A.	N.A.	N.A.
	• Terrace Level	Required	Provided	MR
	➤ Discharge of pump	Boosting	450+180LPM	MR
	➤ Head of the Pump	N.A.	35m(each)	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14	Captive Water Storage for Fire Fighting.			
	On ground tank capacity	N.A.	N.A.	N.A.
	Draw-off connection	N.A.	N.A.	N.A.
	Fire service inlet	N.A.	N.A.	N.A.
	Access to tank	N.A.	N.A.	N.A.
	Overhead Tank capacity	5000Ltrs.	5000Litrs	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	Pressurization of Lift Shaft	N.A.	N.A.	N.A.
	Pressurization of Lift lobby	N.A.	N.A.	N.A.
	Communication in lift car	N.A.	N.A.	N.A.
	Firemen's grounding switch	N.A.	N.A.	N.A.
	Lift Signage	N.A.	N.A.	N.A.
17	Standby power supply	Required	Provided 50Kva Generator set	MR
18	Refuge Area.			
	Total area	N.A.	N.A.	N.A.

19	Fire Control Room			
	Detector system panel	N.A.	N.A.	N.A.
	Flow switch panel	N.A.	N.A.	N.A.
	PA system panel	N.A.	N.A.	N.A.
	Batter backup	N.A.	N.A.	N.A.
	Building Floor Plans	N.A.	N.A.	N.A.
20	Special Fire Protection systems for of special Risks, if any:	N.A.	N.A.	N.A.

The fire protection systems provided in the building were test checked at random and found functional at the time of inspection. In view of the deemed compliance of the minimum standards on fire prevention and fire safety required under the rules the FSC issued vide letter No.F.6/DFS/MS/EH/2013/SZ/1142, dated 30.10.2013 renewal under rule 37 of the Delhi Fire Service Rule 2010 is recommended. Shortcomings communicated vide letter dated 06.12.16 have been complied at Sr. Nos. 4,6,8,10,11,13 & 15 please: ✓

Accordingly DFA is put up for your approval and signature please.

[Handwritten Signature]
9/11/17

Signature of the Inspecting Officer

Name : Vedpal

Designation : ADO

~~D.O. (S.D.)~~ *[Handwritten Signature]*
9/11/17

~~Dy. CFO (SZ)~~ *[Handwritten Signature]*
9/11



[Handwritten Signature]

M-Scell

FT M.

[Handwritten Signature]
12/11

519/CFO(SZ)
13.1.17

FT letter is put-up for sign please

CFO (SZ)

M-Scell

[Handwritten Signature]
13/11

[Handwritten Signature]

13/1/17

ADO (SZ)