

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HQ: DELHI FIRE SERVICE, CONNAUGHT PLACE NEW DELHI- 110001

NO. F6/DFS/MS/Cinema/2017/NDZ/70

DATED: 17/01/17

**FIRE SAFETY CERTIFICATE**

Certified that the Cinopolis Cinema earlier known as Fun Cinema (Total no. 03 Auditorium, Audi-I, Audi-II & Audi-III), Located at first & Second floor plot no. 10, V3S Mall Laxmi Nagar, Distt. Centre, Delhi, owned/occupied by Cinopolis India Private Limited was granted NOC vide letter No.F.6/DFS/MS/Cinema/2013/NDZ/1172 dated 06.11.13. The Cinema building was re-inspected by the officers concerned of this department on dated 17.11.16 in the presence of **Sh. Vikas**, Manager (Cinema) and found that the Cinema building have deemed complied with the fire prevention and fire safety requirements in accordance with the Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and that the building is fit for occupancy Group D " Assembly Building" with effect from ..17..01..17.. for a period of three years, subject to conditions printed overleaf.

Issued on ....17/01/17..... at New Delhi by

  
(Vipin Kental)

Chief Fire Officer

o/c (15)

To,

The Manager

The Manager, Cinopolis India Private Limited (Auditorium I to III),

V3S East Centre Mall plot no. 10, Distt. Centre,

Laxmi Nagar Delhi

**Copy to:-**

The SDM (PV), District - East

L.M. Bundh, Shastri Nagar, Delhi-31.

- Conditions -

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
7. Basement Shall be used as per BBL

N/15

1. Name & address of the building : **Cinepolis Cinema** at V3S East Centre Mall at plot no.10, District Centre, Laxmi Nagar, Delhi
2. Building is comprised of : Basement,ground+three upper floors (Cinema on 1st, & 2 nd floor )
3. Type of Occupancy : Mercantile (Mixed Occupancy)
4. Type of Case : Renewal
5. Details of Previous FSC letter : F6/DFS/MS/Cinema/2013/NDZ/1172 dated 06/11/13
6. Fire safety direction letter No. : F6/MS/DFS/BP/2004/863 dated-16/04/04
7. Date of Inspection : 17/11/2016
8. Name of the Inspecting officers : DO S.K. Dua & ADO R.K. Yadav
9. Name and designation of Officer from the building side : Sh.Vikas ( Manager)
10. Year of Construction : 2006
- 11.Applicant's letter No : SDM(PV)/ 2016-17/4353-55 dated 27/10/16

S	Minimum Standards on fire prevention and fire safety U/R33	NBC/BBL Requirement	Provided at Site	Remarks
1	Access to building			
	• Road width	12 M	36 M & 13.8 M	MR
	• Gate width	4.5 M	06 M	MR
	• Width of internal road	06 M	06 M	MR
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	• Upper Floor	02 Nos.	06 Nos.	MR
	• Basement	N/A	N/A	N/A
	B. Width of Staircases			
	• Upper Floor	1.5 M	1.5 M & 1.8 M	MR
	• Basement	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	Required	Provided	MR
	e. No. of continuous staircases to terrace	N/A	N/A	N/A
	g. Width of Corridor	N/A	N/A	N/A
	h. Door Size	1.5 M	1.5 m	MR
3	Compartmentation.			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire rating of shaft door	02 hrs.	02 hrs.	MR
	• Water curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4	Smoke Management System.			
	• Basement	N/A	N/A	N/A
	• Upper floor	Required	Provided	MR
5.	Fire Extinguishers			
	• Total numbers	21 Nos.	24 Nos.	MR
	• types	ABC & Co2	ABC & Co2	MR
	• IS marking	ISI marked	ISI marked	MR

N/16

6	<b>First-aid-Hose Reels. - Common with Mall</b>			
	Total numbers of each floor	02 Nos	Provided	MR
	• Length of hose reel hose	30 M	Provided	MR
	• Nozzle diameter	05 mm	Provided	MR
7	<b>Automatic fire detection and alarming system. - Common with Mall</b>			
	• Type of detectors	Heat & Smoke	Provided	MR
	• Location of main panel	Control room	Basement	MR
	• Location of repeater panel	Security room	Provided	MR
	• Alternate source of power	Battery & DG Set	Provided	MR
	• Hooter's location	Staircase	Provided	MR
8	MOEFA	Required	Provided	MR
9	Public address System.	Required	Provided	MR
10	<b>Automatic Sprinkler System. - Common with Mall</b>			
	• Basement	Required	Provided	MR
	• upper floor	Required	Provided	MR
	• sprinkler above false ceiling	Required	Provided	MR
11	<b>Internal Hydrants. - Common with Mall</b>			
	• size of riser/down-comer	150 mm	Provided	MR
	• Number of hydrants per floor	02 Nos.	Provided	MR
	• Hose Box	02 Nos.	Provided	MR
12	<b>Yard Hydrants. - Common with Mall</b>			
	• Total number of hydrants	05 Nos.	05 Nos.	MR
	• Hose Box	05 Nos.	05 Nos.	MR
13	<b>Pumping Arrangements.- Common with Mall</b>			
	• Ground Level	Required	Provided	MR
	➤ Discharge of main Pump	2850 Lpm	2850 Lpm	MR
	➤ Head of Main Pump	70 M	70 M	MR
	➤ Number of main pumps	1 Nos.	1 Nos.	MR
	➤ Jockey pump out put	180 Lpm	180 Lpm	MR
	➤ Jockey pump head	70 M	70 M	MR
	➤ Standby pump out put	2850 Lpm	2850 Lpm	MR
	➤ Standby pump Head	70 M	70 M	MR
	➤ Auto Starting /Manual stopping	Required	Auto	MR
	➤ Pump House Access	Required	Provided	MR
	• Terrace Level			
	➤ Discharge of pump	N/A	N/A	N/A
	➤ Head of the Pump	N/A	N/A	N/A
	➤ Power supply	N/A	N/A	N/A
	➤ Auto Starting of pump	N/A	N/A	N/A
14	<b>Captive Water Storage for Fire Fighting. - Common with Mall</b>			
	Underground tank capacity	1,00,000 Ltrs	1,00,000 Ltrs	MR
	➤ Draw-off connection	Required	Provided	MR
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	Required	Provided	MR
	• Overhead Tank capacity	20,000Ltrs	40,000Ltrs	MR
15	Exit Signage.	Required	Provided	MR

N/17

16	Provision of Lifts. - Common with Mall			
	• Pressurization of Lift Shaft	Required	Provided	MR
	• Pressurization of Lift lobby	Required	Provided	MR
	• Communication in lift car	Required	Provided	MR
	• Firemen's grounding switch	Required	Provided	MR
	• Lift Signage	Required	Provided	MR
17	Standby power supply	Required	Provided	MR
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room . - Common with Mall			
	• Detector system panel	Required	Provided	MR
	• Flow switch panel	Required	Provided	MR
	• PA system panel	Required	Provided	MR
	• Battery backup	Required	Provided	MR
	• Building Floor Plans	Required	Provided	MR
20	Special Fire Protection systems for protection of special Risks, if any:	Required	Provided in all LT & HT Panels	MR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules. The Fire Safety Certificate issued vide letter no. F6/DFS/MS/Cinema/2013/NDZ/1172 dated 06/11/13 renewal under rule 35 of the Delhi Fire Service Rule 2010 is recommended.

*[Handwritten Signature]*

Signature of the Inspecting Officer  
Name: S. K. Dua  
Designation: DO (East)

*[Handwritten Signature]*

Signature of the Inspecting Officer  
Name: R. K. Yadav  
Designation: ADO (LN)

*[Handwritten Signature]*  
DeFO (NDZ)  
21/12

C.F.P. FT letter 26/11/2

96/CFDNDZ  
25/12/16/10/1/17

Copy FT letter is put up for signature  
*[Handwritten Signature]*  
2/11/2016

*[Handwritten Signature]*  
M.Scell 10/11