

FORM 'H'  
FORM FOR ISSUING FIRE SAFETY CERTIFICATE  
[Refer sub - rule (1) of rule 35]  
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE  
NEW DELHI


No. F6/DFS/MS/EH/2017/WZ/ 68

Dated: 16/01/17

**FIRE SAFETY CERTIFICATE**

Certified that the **Haldiram,s** Located at **Anchor No-03,19,20,Ground Floor, D Mall, Netaji Subhash Place, Pitampura, Delhi – 110034**.in a mall comprised of three Basement + Ground + 12 Upper Floors was issued FSC vide Letter No. F6/DFS/MS/EH/2014/WZ/619 dated 20-05-14 and the mall has issued FSC vide letter no. F6/DFS/MS//2015/WZ/1331 dated 23-07-15. The premises was re inspected by the officers concerned of this department on 02-01-2017 in the presence of Mr. Sunil Agarwal( Manager) and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and that the premises is fit for occupancy class "Assembly Building" Group D with effect from 16/01/17 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 16/01/17 at New Delhi by.

  
(Atul Garg)  
Chief Fire Officer  
Delhi Fire Service

Copy to:

1. Sh. Udit Awasthi (Authorized Signatory) **Anchor No-03,19,20,Ground Floor, D Mall, Netaji Subhash Place, Pitampura, Delhi – 110034**.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used as per building bye laws.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).


1. Name & address of the building: **Haldiram,s, Anchor No-03,19,20,Ground Floor, D Mall, Netaji Subhash Place Pitampura, Delhi- 110034.**
2. Occupancy : Assembly( Restaurant)
3. Type of Case : Renewal ( The Mall has already issued FSC Vide Letter no. F6/DFS/MS/WZ/2015/1331 dated 23-07-2015.
4. Details of previous NOC : Letter No. F6/DFS/MS/EH/2014/WZ/619 dated 20-05-14.
5. Fire Safety directives Letter No. : Issued to the mall
6. Date of inspection : 02-01-2017
7. Name of the Inspecting Officer : Udai vir Singh ADO (WP)
8. Name and designation of Officer  
from the building side : Sh.Sunil Agarwal (Manager )
9. Year of Construction : 2010
10. Applicant's letter No. : Nil Dated 02-12-2016

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	6 m	30m Provided	MR
	• Gate width	5 m	5m Provided	MR
	• Width of internal road	6m	6m Provided	MR
2.	Number, width, Type & Arrangements of exits <b>(Common with Mall)</b>			
	a. Number of staircases			
	• Upper floors	NA	NA	NA
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	NA	NA	NA
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	Required	Provided By Mall	MR
	• Pressurization	Required	Provided By Mall	MR
	d. No of continuous staircase to terrace	Required	Provided By Mall	MR
	e. Width Of Corridor	Required	Provided By Mall	MR
	f. Door Size	1x2m & 1x1m	1x153cm, 1x193cm	MR
3.	Compartmentation			
	• Fire check door	Required	Provided By Mall	MR
	• Sealing of electrical shafts	Required	Provided By Mall	MR
	• Fire Rating of shaft door	Required	Provided By Mall	MR
	• Water Curtain	Required	Provided By Mall	MR
	• Fire Dampers	Required	Provided By Mall	MR
4.	Smoke managements System			
	• Basements	30 a/c per hour	Provided By Mall	MR
	• Upper floors	12 a/c per hour	Provided By Mall	MR
5.	Fire Extinguishers			
	• Total numbers	2 nos.	Provided	MR
	• Types	ABC, CO2 & WCO2	ABC extinguishers	MR
	• IS marking	IS 15650		

6.	First – Aid Hose Reels			
	• Total numbers on each floor	1	Provided	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	Smoke & Heat	Provided By Mall	MR
	• Location of Main Panel	Required	Provided By Mall	MR
	• Location of Repeater Panel	NA	Provided By Mall	MR
	• Alternate source of power	Required	Provided By Mall	MR
	• Hooters' Location	Required	Provided By Mall	MR
8.	MOEFA	Required	Provided By Mall	MR
9.	Public Address System	NA	Provided By Mall	MR
10.	Automatic Sprinkler System			
	• Basements	Not Required	Provided By Mall	MR
	• Upper Floor	Not Required	Provided By Mall	MR
	• Sprinkler above false ceiling	Not Required	Provided By Mall	MR
11.	Internal Hydrants			
	• Size of riser/down- comer	150 mm	Provided By Mall	MR
	• Number of hydrants per floor	2	4 Provided By Mall	MR
	• Hose Box	Required	Provided By Mall	MR
12.	Yard Hydrants			
	• Total number of hydrants	NA	Provided By Mall	MR
	• Hose Box	NA	Provided By Mall	MR
13.	Pumping Arrangements			
	• Ground Level			
	• Discharge of main pump	4500lpm	4500 lpm Provided By Mall	MR
	➤ Head of main pump	65m	65m Provided By Mall	MR
	➤ Number of main pumps	2	2 Provided By Mall	MR
	➤ Jockey pump out put	180lpm	180 lpm Provided By Mall	MR
	➤ Jockey pump head	65m	65m Provided By Mall	MR
	➤ Standby Pump out put	4500lpm	4500lpm Provided By Mall	MR
	➤ Standby Pump Head	Required	65m Provided By Mall	MR
	➤ Auto Staring/Manual stopping	Required	Provided	MR
	➤ Pump House Access	Required	Provided	MR
	• Terrace level	NA	NA	NA
	➤ Discharge of pump	NA	NA	NA
	➤ Head of the pump	NA	NA	NA
	➤ Power supply	NA	NA	NA
	➤ Auto starting of pump	NA	NA	NA
14.	Captive water Storage for fire fighting			
	• Under ground tank capacity	2500000ltr	Common with the mall	MR
	➤ Draw of connection	Required	Common with the mall	MR
	➤ Fire service inlet	Required	Common with the mall	MR
	➤ Access to tank	Required	Common with the mall	MR
	• Overhead Tank capacity	10, 000 litres	50000 ltr Common with the mall	MR
15.	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA

		Required	Provided	MR
17.	Standby power supply			
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection. In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no. F6/DFS/MS/EH/2014/WZ/619 dated 20-05-2014 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Signature of the Inspecting Officer  
  
 Officer

Name Vedat Vir Singh

Designation ADD/WP

Signature of the Inspecting

Name

Designation

DO/CO Inspector 6/1/17 §