

No. F6/DFS/MS/School/2017/SZ/ 64

Dated: ..16/11/17

FIRE SAFETY CERTIFICATE

Certified that the **S.D.M.C. Primary Co-Ed., School, R.K. Puram, Sector-IV, New Delhi**, building comprised of **Ground + 1 Upper floor** was granted Fire Safety Certificate by this department vide letter No. F.6/DFS/MS/School/2013/635 dated 13/02/2013. The premises was re-inspected by officer concerned of this department on 24.12.2016 in the presence of Ms. Sushila Tokas (Principal) of the school and found that said school building have deemed complied with the fire prevention and fire safety arrangements in accordance with Circular No. F.16//Estate/CC/Fire Safety/2011/3298 to 3398 Dated 01.03.2011 issued by Directorate of Education, Govt. of NCT of Delhi and that the building/premises is fit for occupancy class "**Educational Building, Group-B**" with effect from 16/11/2017 for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on ..16/11/17..... at New Delhi by


Vipin Kental
Chief Fire Officer

Copy to: -

1. The Principal, SDMC Primary Co-Ed. School, R.K. Puram, Sector-IV, New Delhi-110022
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi.

Conditions for the validity of Fire Safety Certificate

1. All the fire safety and means of escape facilities shall be maintained in good working condition at all time. Any lapse rendering the fire safety or means of evacuation facilities non-functional shall be the responsibility of the management.
2. Building Sanctioning authority may verify any deviation with regard to construction/occupancy in the building. In case of any deviation, the fire safety certificate stands null & void.
3. The staff shall be trained for operating fire fighting system and mock evacuation drill be conducted at regular interval and record be maintained.
4. The basement shall be used strictly as per the provisions of Building Bye Laws.
5. The Owner/Occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules, 2010. The form is available on www.dfs.delhigovt.nic.in.
6. The Owner/Occupier shall apply for renewal of this Fire Safety Certificate to the Director in the form 'J' [sub rule (1) of rule 37] along with copy of this certificate, six months prior to its expiry. The form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1	Name & Address of the Building	S.D.M.C. PRIMARY CO-ED SCHOOL, R.K. PURAM, SECTOR-IV, NEW DELHI-110022		
2	Type of Occupancy	Educational Building "Group-B" (School)		
3	Building Comprised of	Ground + 01 upper floors		
4	Type of Case	Renewal		
5	Details of Previous NOC	F6/DFS/MS/School/2013/635 Dated 13/02/2013		
6	Fire Safety Directives Letter No	F.16/Estate/CC/Fire Safety/2011/3298 to 3398 Dated 01/03/2011		
7	Date of Inspection	24.12.2016		
8	Name of the Inspecting Officers	ADO R.N. Singh		
9	Name & Designation of Officers from the building side	Ms. Sushila Tokas, Principal		
10	Year of construction	2012		
11	Applicant letter No.	Nil dated 03/12/2016		
S. No	Minimum standards on Fire Prevention and Fire Safety U/R 33	Old NOC Dt. 13/02/2013 Requirements	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	1. Road width	Accessible	6 mtr	MR
	2. Gate width	NA	4 mtr	NA
	3. Width of internal road	NA	NA	NA
2	Number, width, type and arrangements of exits.			
	a. Number of Staircase			
	1. Upper floors	Required	Two	MR
	2. Basement floor	NA	NA	NA
	b. Width of Staircase			
	1. Upper floors	1.50 m /0.75 m	1.25 mtr & 1.17 mtr	MR
	2. Basement floor	NA	NA	NA
	c. Protection of exits			
	1. Fire check door	NA	NA	NA
	2. Pressurization	NA	NA	NA
	d. No. of continuous staircase to terrace	1 No	1 No	MR
	e. Width of corridor	NA	NA	NA
	f. Door size	1.0 mtr	1.0 mtr	MR
3	Compartmentation.			
	1. Fire check door.	NA	NA	NA
	2. Sealing of electrical shafts.	NA	NA	NA
	3. Fire rating of shaft door.	NA	NA	NA
	4. Water curtain	NA	NA	NA
	5. Fire dampers.	NA	NA	NA
4.	Smoke Management system.			
	1. Basement	NA	NA	NA
	2. Upper floors	NA	Open corridor	NA
5.	Fire Extinguishers.			
	1. Total numbers	Portable Fire Extinguisher's ISI marked	07 No's	MR
	2. Types		ABC-04, Co2-03 No	MR
	3. ISI Marking		Yes	MR
6.	First Aid Hose Reels.			
	1. Total numbers on each floor.	NA	NA	NA
	2. Length of hose-reel hose.	NA	NA	NA
	3. Nozzle Diameter	NA	NA	NA

Renewal

SDMC Primary Co-Ed School, R.K. Puram, Sector-IV, ND

P.S.

7	Automatic Fire Detection and Alarming system.			
	1. Type of detectors	NA	NA	NA
	2. Location of Main Panel	NA	NA	NA
	3. Location of Repeater Panel	NA	NA	NA
	4. Alternate source of power	NA	NA	NA
	5. Hooter's location	NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	1. Basement	NA	NA	NA
	2. Upper floors	NA	NA	NA
	3. Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants.			
	1. Size of Riser/Down-comer	NA	NA	NA
	2. Number of Hydrant per floor	NA	NA	NA
	3. Hose box.	NA	NA	NA
12.	Yard Hydrants.			
	1. Total number of hydrants.	NA	NA	NA
	2. Hose box.	NA	NA	NA
13.	Pumping arrangements.			
	a) Ground Level			
	➤ Discharge of main pump.	NA	NA	NA
	➤ Head of main pump.	NA	NA	NA
	➤ Number of main pumps.	NA	NA	NA
	➤ Jockey Pump output.	NA	NA	NA
	➤ Jockey Pump head.	NA	NA	NA
	➤ Standby Pump output.	NA	NA	NA
	➤ Standby pump head.	NA	NA	NA
	➤ Auto Starting/Manual Stopping.	NA	NA	NA
	b) Terrace Level			
	➤ Discharge of pump.	NA	NA	NA
	➤ Head of pump.	NA	NA	NA
	➤ Power supply.	NA	NA	NA
	➤ Auto starting of pump.	NA	NA	NA
14.	Captive water storage for Fire Fighting.			
	1. Underground tank capacity.	NA	NA	NA
	2. Draw-off connection.	NA	NA	NA
	3. Fire Service Inlet.	NA	NA	NA
	4. Access to tank.	NA	NA	NA
	5. Overhead tank capacity.	NA	NA	NA
15.	Exit Signage.	NA	NA	NA
16.	Provisions of Lifts.			
	1. Pressurization of lift shaft.	NA	NA	NA
	2. Pressurization of lift lobby.	NA	NA	NA
	3. Communication in lift car.	NA	NA	NA
	4. Fireman's switch.	NA	NA	NA
	5. Lift signage.	NA	NA	NA
17	Standby Power Supply	NA	NA	NA
18.	Refuge Area			
	1. Total area	NA	NA	NA
	2. Location	NA	NA	NA

19.	Fire Control Room.			
	1. Detector System Panel.	NA	NA	NA
	2. Flow Switch Panel.	NA	NA	NA
	3. PA system Panel.	NA	NA	NA
	4. Battery backup	NA	NA	NA
	5. Building floor plan	NA	NA	NA
20.	Special Fire Protection System for the Protection of special Risk, if any.			NA
<p>The Fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection.</p> <p>In view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the circular of Directorate of Education dated 01/03/2011, FSC issued vide letter No. F6/DFS/MS/School/2013/635 dated 13/02/2013, renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended.</p> <p>Accordingly, DFA is put up for approval and signature please.</p>				
<p style="text-align: right;"><i>R.N. Singh</i> 28/12</p>				
<p style="text-align: right;">Signature of the Inspecting Officer Name: R.N. Singh Designation: ADO</p>				

Renewal

SDMC Primary Co-Ed School, R.K. Puram, Sector-IV, ND

Div. Officer (SD)

[Signature]
30/12/16

[Signature]
dy. (SO) (S2)

[Signature]
2/1



494/cfo s2
4/1/17. /10/1