

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001**

No. *F6/DFS/MS/School/2017/M02/75* Dated: *18/01/17*

FIRE SAFETY CERTIFICATE

Certified that the Delhi International Sec. School at Main Loni Raod, Jawahar Nagar, Johripur, Delhi -110094 comprised of ground plus two upper floor owned/occupied by Delhi International Sec. School was issued NOC vide letter No-F6/DFS/MS/09/2798 dated-15/09/09. The school building was inspected by officer concerned of this department on 26/11/2016 & 16/12/16 in the presence of Mr. Rajeev Kumar, Manager of the school and found that the school building have deemed complied with the fire prevention and fire safety requirements in accordance with Circular No. – 262-362 dated-17/01/2005 issued by Director of Education and found that the school building is fit for occupancy class “B” ‘Educational Building’ with effect from *18/01/17* for a period of **three** years, subject to conditions, printed overleaf.

Issued on *18/01/17* at New Delhi by

W
16/11
(Vipin Kental)
Chief Fire Officer

To,
The Manager,
Delhi International Sec. School,
Loni Raod, Jawahar Nagar,
Johripur, Delhi -110094

Copy:-
The Dy. Director of Education,
B-Block, Yamuna Vihar,
Delhi-110053

o/c
W

CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
7. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry

1. Name & address of the building : Delhi International Sec. School,
Main Road Jawahar Nagar, Johripur, Delhi -94
2. Building is comprised of : **Ground plus two upper floors**
3. Type of Occupancy : Educational
4. Type of Case : **Renewal**
5. Details of Previous NOC letter : F6/DFS/MS/09/2798 dated 15/09/09
6. Fire Safety directive letter No. : Circular No. 262-362 dated 17/01/2005
issued by the Director of Education
7. Date of Inspection * : 26/11/16 & 16/12/16.
8. Name of the Inspecting officers : ADO Vijay Bahadur
9. Name and designation of Officer
from the building side : Mr. Rajeev Kumar (Manager)
10. Year of Construction : 2001
11. Applicant's letter No : Letter No.:- DISS/Gen/445/16, Dated- 24/10/16

Sr. No.	Minimum Standards on Fire Prevention and Fire Safety U/R33	Circular Requirement	Provided at Site	Remarks MR/NMR
01	Access to Building.			
	• Road width	06 mtr.	24 mtr.	MR
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
02	Number, Width, Type and Arrangement of Exits.			
	a. Number of Staircases			
	• Upper floor	1 No. ✓	2 No.	MR
	• Basement	N/A	N/A	N/A
	b. Width of Staircases			
	• Upper floor	1.50 mtr.	1.40 mtrs & 0.75 mtrs (Iron)	MR (Old) Accepted
	• Basement	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No. of Continuous Staircases to Terrace	01 no.	01 no.	MR
	e. Width of Corridor	1.50 mtr.	1.70 mtr.	MR
	f. Door Size	01 mtr.	01 mtr.	MR
03	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire dampers	N/A	N/A	N/A
04	Smoke Management System.			
	• Basement	N/A	N/A	N/A
	• Upper floor	N/A	N/A	N/A
05.	Fire Extinguishers.			
	• Total numbers	08 nos.	08 nos.	MR
	• Types	ABC /CO ₂	Provided	MR
	• IS marking	ISI marked	Provided	MR

* The inspection was carried out by DOR(D) & ADO(TP) on 26/11/16 and again on 16/12/16 by ADO(TP) on request of Management after completion of 2nd (Iron) staircase.

06	First-Aid-Hose Reels			
	• Total numbers on each floor	01 No.	01 no.	MR
	• Length of hose reel hose	30 mtr.	30 mtrs	MR
	• Nozzle diameter	05 mm	05 mm	MR
07	Automatic Fire Detection and Alarming System.			
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's location	N/A	N/A	N/A
08	MOEFA			
09	Public Address System.	N/A	Provided	MR
10	Automatic Sprinkler System.			
	• Basement	N/A	N/A	N/A
	• upper floor	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• size of riser/down-comer	100 mm	100 mm	MR
	• Number of hydrants per floor	01 no.	01 no.	MR
	• Hose box	01 no.	01 no.	MR
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	Pumping Arrangements.			
	➤ Ground Level			
	• Discharge of main pump	N/A	N/A	N/A
	• Head of Main pump	N/A	N/A	N/A
	• Number of main pumps	N/A	N/A	N/A
	• Jockey pump out put	N/A	N/A	N/A
	• Jockey pump head	N/A	N/A	N/A
	• Standby pump out put	N/A	N/A	N/A
	• Standby pump head	N/A	N/A	N/A
	• Auto Starting /Manual stopping	N/A	N/A	N/A
	• Pump house access	N/A	N/A	N/A
	➤ Terrace Level			
	• Discharge of pump	450 lpm	450 lpm	MR
	• Head of the pump	40 M	40 M	MR
	• Power supply	Required	Provided	MR
	• Auto Starting of pump	Required	Provided	MR
14	Captive Water Storage for Fire Fighting.			
	• Underground tank capacity	N/A	N/A	N/A
	• Draw-off connection	N/A	N/A	N/A
	• Fire service inlet	N/A	N/A	N/A
	• Access to tank	N/A	N/A	N/A
	• Overhead tank capacity	5,000 ltrs	5,000 ltrs	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	• Pressurization of lift shaft	N/A	N/A	N/A
	• Pressurization of lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift signage	N/A	N/A	N/A

M15

17	Standby Power Supply	N/A	N/A	N/A
18	Refuge Area			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building floor plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of Special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested/checked at the time of inspection.

Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety required under the Director of Education circular No. 262-362 dated 17/01/2005, it is recommended to grant Fire Safety Certificate.

[Handwritten Signature]
27/12/16

Signature of the Inspecting Officer

Name :- Vijay Bahadur

Designation :- A.D.O (T.Pur)

~~DO(ED)~~ *[Signature]*
02/1/17

~~DUFO(ND2)~~ *[Signature]*
3/1/17

- C.F.P.
1. The cutting at S.No. 2 to be initiated.
 2. Why so much delay.
 3. Put up FT M.

~~DCFO S2/ND2~~

[Signature]
6/1

~~DO E.D.~~ *[Signature]*
9/1
Sep
11/1

~~ADP(TP)~~