

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No F 6 / DFS / MS / EH / 2017 / 78

Dated: 18/1/17

FIRE SAFETY CERTIFICATE

Certified that the **Amitabh Restaurant, located at Ground Floor, E-23, Bunglow Road, Kamla Nagar, Delhi-110007** comprised of basement+ ground and two upper floors owned/ occupied by Amitabh Guest House has already been issue fire safety certificate vide letter no. **F6/DFS/MS/GH/2013/WZ/1169 dated 04/11/2013**. The premises was re-inspected by the officer concerned of Fire Service on 16/12/2016 in the presence of **Sh. Mehra (Manager)** and observed that all the fire prevention & fire safety arrangements as provided in the premises found in good working condition The premises have therefore, deemed complied with the requirement under rule 33 of Delhi Fire Service Rules, 2010 and the building is fit for occupancy **Class – D(Assembly) at ground floor only** with effect from ~~18/1/17~~----- for a period of **03 (Three) years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in
8. All the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.
9. This NOC is valid only Ground Floor.

Issued on 18/1/17..... at New Delhi by


(Atul Garg)

Chief Fire Officer
Ph:-011-23414250

Copy to :-

1. The Additional Commissioner of Police (Lic), 1st floor, Police Station, Defence Colony, New Delhi.
2. The Manager, Amitabh Restaurant, Kamla Nagar, Delhi-110007.

M/10

INSPECTION REPORT

1. Name & address of the building : :Amitabh Restaurant, E-23, Bunglow Road, Kamla Nagar, Delhi-110007.
2. Type of Occupancy : :Assembly (B+G+02 upper floors), Restaurant on Ground Floor
3. Type of Case : :Renewal
4. Details of previous NOC : :F6/DFS/MS/GH/2016/WZ/1169 Dated: 04/11/2013
5. Fire Safety directives letter No : :old case
6. Date of inspection : :16/12/2016
7. Name of the Inspecting Officers : :ADO (RN)
8. Name and designation of officers
from the building side : :Mr. Mehra (Manager)
9. Year of Construction : :--
10. Applicant's letter No. : :Nil Dated 21/10/2016

| | Minimum Standards on fire prevention and fire safety U/R 33 | NBC/ BBL Requirement | Provided at site | Remarks MR/NMR |
|---------------------|--|------------------------|------------------|----------------|
| 1 | Access to building | | | |
| | <ul style="list-style-type: none"> • Road width • Gate width • Width of internal road | 09m | 15m | MR |
| | | 4.5m | 4.5m | MR |
| | | NA | NA | NA |
| 2 | Number, Width, Type & Arrangement of Exits | | | |
| | a. Number of staircases | | | |
| | <ul style="list-style-type: none"> • Upper Floors • Basements | 01 | 02 | MR |
| | | 02 | 02 | MR |
| | b. Width of staircases | | | |
| | <ul style="list-style-type: none"> • Upper Floors • Basements | 1.50m | 1.50m & 1.16m | MR(old case) |
| | | 1.50m | 1.50m & 2.00m | MR(old case) |
| | c. Protection of exits | | | |
| | <ul style="list-style-type: none"> • Fire check door • Pressurization | NA | NA | NA |
| | | NA | NA | NA |
| | d. No. of continuous staircases to terrace | | | |
| | e. Width of Corridor | | | |
| f. Door Size | | | | |
| | 04 exits | 2.0m, 1.50x 02 & 1.16m | MR | |

25/11

| | | | | |
|----|--|---------------------|--------------------|----|
| 3 | Compartmentation. | | | |
| | • Fire check door | NA | NA | NA |
| | • Sealing of electrical shafts | NA | NA | NA |
| | • Fire Rating of shaft door | NA | NA | NA |
| | • Water Curtain | NA | NA | NA |
| | • Fire Dampers | NA | NA | NA |
| 4 | Smoke Management System. | | | |
| | • Basements | 30 a/c per hour | Provided | MR |
| | • Upper floors | 12 a/c per hour | Natural Ventilated | MR |
| 5 | Fire Extinguishers | | | |
| | • Total numbers | 04nos | 06 | MR |
| | • Types | ABC, W.Co2 & Co2 | ABC - 06, | MR |
| | • ISI marking | Yes | Yes | MR |
| 6 | First-Aid Hose Reels. | | | |
| | • Total numbers on each floor | 01 | 01 | MR |
| | • Length of hose reel hose | 30m | 30m | MR |
| | • Nozzle diameter | 5mm | 5mm | MR |
| 7 | Automatic fire detection and alarming system. | | | |
| | • Type of detectors | NA | NA | NA |
| | • Location of Main Panel | NA | NA | NA |
| | • Location of Repeater Panel | NA | NA | NA |
| | • Alternate source of power | NA | NA | NA |
| | • Hooters' Location | NA | NA | NA |
| 8 | MOEFA | Required | Provided | MR |
| 9 | Public Address System. | NA | NA | NA |
| 10 | Automatic Sprinkler System. | | | |
| | • Basement | Required | Provided | MR |
| | • Upper Floor | NA | Provided | NA |
| | • Sprinkler above false ceiling | NA | NA | NA |


M/12

| | | | | | |
|------------|---|----------|--|----|----|
| 11 | Internal Hydrants | | | | |
| | <ul style="list-style-type: none"> • Size of riser/down-comer • Number of hydrants per floor • Hose Box | 100mm | 100mm | MR | |
| | | 01Nos. | 01 Nos | MR | |
| | | 01 Nos. | 01 Nos | MR | |
| 12 | Yard Hydrants. | | | | |
| | <ul style="list-style-type: none"> • Total number of hydrants • Hose Box | NA | NA | NA | |
| | | NA | NA | NA | |
| 13 | Pumping Arrangements. | | | | |
| | <ul style="list-style-type: none"> • Ground Level <ul style="list-style-type: none"> ➤ Discharge of main Pump ➤ Head of Main pump ➤ Number of main pumps ➤ Jockey Pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/ Manual stopping ➤ Pump House Access • Terrace level <ul style="list-style-type: none"> ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump | NA | NA | NA | |
| | | NA | NA | NA | |
| | | NA | NA | NA | |
| | | NA | NA | NA | |
| | | NA | NA | NA | |
| | | NA | NA | NA | |
| | | NA | NA | NA | |
| | | NA | NA | NA | |
| | | NA | NA | NA | |
| | | 450 LPM | 450 lpm | MR | |
| | | 180 m | 180 m | MR | |
| | | Required | Provided | MR | |
| | | Required | Provided | MR | |
| | | 14 | Captive Water Storage for fire fighting. | | |
| | | | <ul style="list-style-type: none"> • Underground tank capacity <ul style="list-style-type: none"> ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity | NA | NA |
| NA | NA | | | NA | |
| NA | NA | | | NA | |
| NA | NA | | | NA | |
| 20,000 ltr | 20,000 ltr. | | | MR | |
| Required | Provided | MR | | | |
| 15 | Exit Signage. | | | | |
| | Required | Provided | MR | | |

| | | | | |
|----|--|----------|--|-----|
| 16 | Provision of Lifts. | | | |
| | • Pressurization of Lift Shaft | N/A | N/A | N/A |
| | • Pressurization of Lift lobby | N/A | N/A | N/A |
| | • Communication In lift Car | NA | NA | NA |
| | • Fireman's Grounding Switch | NA | NA | NA |
| | • Lift Signage | NA | NA | NA |
| 17 | Standby power supply | Required | Provided | MR |
| 18 | Refuge Area. | | | |
| | ➤ Total Area | N/A | N/A | N/A |
| | ➤ Location | N/A | N/A | N/A |
| 19 | Fire Control Room | | | |
| | • Detector System Panel | Required | Provided | MR |
| | • Flow Switch Panel | N/A | N/A | N/A |
| | • PA System Panel | N/A | N/A | N/A |
| | • Batter backup | N/A | N/A | N/A |
| | • Building Floor Plans | N/A | N/A | N/A |
| 20 | Special Fire Protection Systems for Protection of special Risks, if any: | - | No special risk seen at the time of inspection | - |

The fire protection systems provided in the building were tested/ checked and found some in working order at the time of inspection.

Keeping in view of the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to renew Fire Safety Certificate issued vide this department letter of even no. 1169 dated 04.11.2013 under rule 35 of the Delhi Fire Service Rules 2010.


 Signature of the Inspecting Officer
 Name: - Rajesh Kumar
 Designation:- ADO/RN

Do/No/By


Singh

29.12.16

As CEO (WZ)

CFB- work

16/11/17


16/11/17

HT P/S

As approved, f.t. letter is for copy for your signature pl.

16/11/17