

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

Fax No. 011-23412593, Ph. 011-23412225

No. F6/DFS/MS/School/2017/SZ/ 102

Dated: 23/1/17.....

FIRE SAFETY CERTIFICATE

Certified that the **Barry Public School, K Block- 19/1216, Sangam Vihar, New Delhi- 110062**, comprised of **Ground floor only** Owned/Occupied by Maharani Kalyani Education Society was inspected by officer concerned of this department on 13.01.2017 in the presence of Mrs. Meena (Peon) of the school and found that said school building have complied with the fire prevention and fire safety arrangements in accordance with Directorate of Education Circular No. F.16/Estate/CC/Fire/Safety/2011/3298-3398 date 01-03-2011 issued by Director of Education, GNCT of Delhi and that the building/premises is fit for occupancy class "**Educational Building, Group-B**" as above with effect from 23/1/ 2017 for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 23/1/17..... at New Delhi by

W
20/1
Vipin Kental
Chief Fire Officer

Copy to: -

1. The Principal, Barry Public School, K Block- 19/1216, Sangam Vihar, New Delhi-110062
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi.

Conditions for the validity of Fire Safety Certificate

1. All the fire safety and means of escape facilities shall be maintained in good working condition at all time. Any lapse rendering the fire safety or means of evacuation facilities non-functional shall be the responsibility of the management.
2. Building Sanctioning authority may verify any deviation with regard to construction/occupancy in the building. In case of any deviation, the fire safety certificate stands null & void.
3. The staff shall be trained for operating fire fighting system and mock evacuation drill be conducted at regular interval and record be maintained.
4. This Certificate cannot be treated as regularization of unauthorized construction, if any.
5. The Owner/Occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules, 2010. The form is available on www.dfs.delhigovt.nic.in.
6. The Owner/Occupier shall apply for renewal of this Fire Safety Certificate to the Director in the form 'J' [sub rule (1) of rule 37] along with copy of this certificate, six months prior to its expiry. The form is available on www.dfs.delhigovt.nic.in.

N/

INSPECTION REPORT				
1	Name & Address of the Building	Barry Public School, K Block- 19/1216, Sangam Vihar, New Delhi-110062		
2	Type of Occupancy	Educational Building "Group-B" (School)		
3	Building Comprised of	Ground floor only		
4	Type of Case	New		
5	Details of Previous NOC	Nil		
6	Fire Safety Directives Letter No	DOE Circular dated 01/03/2011		
7	Date of Inspection	13.01.2017		
8	Name of the Inspecting Officers	ADO R.N. Singh		
9	Name & Designation of Officers from the building side	Mrs. Meena (Peon)		
10	Year of construction	2002		
11	Applicant letter No.	DFOCP/Fire/061216/002 dated 06/12/2016		
S. No	Minimum standards on Fire Prevention and Fire Safety U/R 33	DOE Circular Dt. 01/03/2011 Requirements	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	1. Road width	Accessible	6 Mtr.	MR
	2. Gate width	NA	3.5 Mtr	NA
	3. Width of internal road	NA	NA	NA
2	Number, width, type & arrangement of exits.			
	a. Number of Staircase			
	1. Upper floors.	NA	NA	NA
	2. Basement floor.	NA	NA	NA
	b. Width of Staircase			
	1. Upper floors	NA	NA	NA
	2. Basement floor	NA	NA	NA
	c. Protection of exits			
	1. Fire check door	NA	NA	NA
	2. Pressurization	NA	NA	NA
	d. No. of continuous staircase to terrace	NA	NA	NA
	e. Width of corridor	NA	NA	NA
	f. Door size	1 mtr	1 mtr	MR
3	Compartmentation.			
	1. Fire check door.	NA	NA	NA
	2. Sealing of electrical shafts.	NA	NA	NA
	3. Fire rating of shaft door.	NA	NA	NA
	4. Water curtain	NA	NA	NA
	5. Fire dampers.	NA	NA	NA
4.	Smoke Management system.			
	1. Basement	NA	NA	NA
	2. Upper floors	NA	NA	NA
5.	Fire Extinguishers.			
	1. Total numbers	One / 300 m ²	02 No's	MR
	2. Types	ABC / Co2	ABC- 2 No's	MR
	3. ISI Marking	ISI Marking	Provided	MR
6.	First Aid Hose Reels.			
	1. Total numbers on each floor.	NA	NA	NA
	2. Length of hose-reel hose.	NA	NA	NA
	3. Nozzle Diameter	NA	NA	NA

New

Barry Public School, K Block- 19/1216, Sangam Vihar, ND-62

R.

7	Automatic fire detection & alarming system.			
	1. Type of detectors	NA	NA	NA
	2. Location of Main Panel	NA	NA	NA
	3. Location of Repeater Panel	NA	NA	NA
	4. Alternate source of power	NA	NA	NA
	5. Hooter's location	NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	1. Basement	NA	NA	NA
	2. Upper floors	NA	NA	NA
	3. Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants.			
	1. Size of Riser/Down-comer	NA	NA	NA
	2. Number of Hydrant per floor	NA	NA	NA
	3. Hose box.	NA	NA	NA
12.	Yard Hydrants.			
	1. Total number of hydrants.	NA	NA	NA
	2. Hose box.	NA	NA	NA
13.	Pumping arrangements.			
	A. Ground Level			
	➤ Discharge of main pump.	NA	NA	NA
	➤ Head of main pump.	NA	NA	NA
	➤ Number of main pumps.	NA	NA	NA
	➤ Jockey Pump output.	NA	NA	NA
	➤ Jockey Pump head.	NA	NA	NA
	➤ Standby Pump output.	NA	NA	NA
	➤ Standby Pump head.	NA	NA	NA
	➤ Auto Starting / Manual Stopping.	NA	NA	NA
	➤ Pump house access.	NA	NA	NA
	B. Terrace Level			
	➤ Discharge of pump.	NA	NA	NA
	➤ Head of pump.	NA	NA	NA
	➤ Power supply.	NA	NA	NA
	➤ Auto starting of pump.	NA	NA	NA
14.	Captive water storage for Fire Fighting.			
	1. Underground tank capacity.	NA	NA	NA
	2. Draw-off connection.	NA	NA	NA
	3. Fire Service Inlet.	NA	NA	NA
	4. Access to tank.	NA	NA	NA
	5. Overhead tank capacity.	NA	NA	NA
15.	Exit Signage.	NA	Provided	NA
16.	Provision of Lifts.			
	1. Pressurization of lift shaft.	NA	NA	NA
	2. Pressurization of lift lobby.	NA	NA	NA
	3. Communication in lift car.	NA	NA	NA
	4. Fireman's switch.	NA	NA	NA
	5. Lift signage.	NA	NA	NA
17.	Standby Power Supply	NA	NA	NA
18.	Refuge Area			
	1. Total area	NA	NA	NA
	2. Location	NA	NA	NA

New

Barry Public School, K Block- 19/1216, Sangam Vihar, ND-62

Pr.

INSPECTION REPORT				
1	Name & Address of the Building	Barry Public School, K Block- 19/1216, Sangam Vihar, New Delhi-110062		
2	Type of Occupancy	Educational Building "Group-B" (School)		
3	Building Comprised of	Ground floor only		
4	Type of Case	New		
5	Details of Previous NOC	Nil		
6	Fire Safety Directives Letter No	DOE Circular dated 01/03/2011		
7	Date of Inspection	13.01.2017		
8	Name of the Inspecting Officers	ADO R.N. Singh		
9	Name & Designation of Officers from the building side	Mrs. Meena (Peon)		
10	Year of construction	2002		
11	Applicant letter No.	DFOCP/Fire/061216/002 dated 06/12/2016		
S. No	Minimum standards on Fire Prevention and Fire Safety U/R 33	DOE Circular Dt. 01/03/2011 Requirements	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	1. Road width	Accessible	6 Mtr.	MR
	2. Gate width	NA	3.5 Mtr	NA
	3. Width of internal road	NA	NA	NA
2	Number, width, type & arrangement of exits.			
	a. Number of Staircase			
	1. Upper floors.	NA	NA	NA
	2. Basement floor.	NA	NA	NA
	b. Width of Staircase			
	1. Upper floors	NA	NA	NA
	2. Basement floor	NA	NA	NA
	c. Protection of exits			
	1. Fire check door	NA	NA	NA
	2. Pressurization	NA	NA	NA
	d. No. of continuous staircase to terrace	NA	NA	NA
	e. Width of corridor	NA	NA	NA
	f. Door size	1 mtr	1 mtr	MR
3	Compartmentation.			
	1. Fire check door.	NA	NA	NA
	2. Sealing of electrical shafts.	NA	NA	NA
	3. Fire rating of shaft door.	NA	NA	NA
	4. Water curtain	NA	NA	NA
	5. Fire dampers.	NA	NA	NA
4.	Smoke Management system.			
	1. Basement	NA	NA	NA
	2. Upper floors	NA	NA	NA
5.	Fire Extinguishers.			
	1. Total numbers	One / 300 m ²	02 No's	MR
	2. Types	ABC / Co2	ABC- 2 No's	MR
	3. ISI Marking	ISI Marking	Provided	MR
6.	First Aid Hose Reels.			
	1. Total numbers on each floor.	NA	NA	NA
	2. Length of hose-reel hose.	NA	NA	NA
	3. Nozzle Diameter	NA	NA	NA

New

Barry Public School, K Block- 19/1216, Sangam Vihar, ND-62


h.

19.	Fire Control Room.			
	1. Detector system panel.	NA	NA	NA
	2. Flow switch panel.	NA	NA	NA
	3. PA system panel.	NA	NA	NA
	4. Battery backup.	NA	NA	NA
	5. Building floor plan.	NA	NA	NA
20.	Special Fire Protection System for the Protection of special Risk, if any.	NA	NA	NA

The Fire protection systems provided in the building were randomly checked/ tested and found functional at the time of inspection. The shortcomings communicated vide letter dated 18/06/2014 have been complied

In view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, it is recommended to issue Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules, 2010.

Accordingly DFA is put up for approval and signature please.


 Signature of the Inspecting Officer
 Name : R.N. Singh
 Designation: ADO

New

Barry Public School, K Block- 19/1216, Sangam Vihar, ND-62

Div. Officer (SD)



17/11/17



543/CB S2
19/1/2011



CFO (S2)



F.T.M.

M. S. Cell 18/11

F.T letter is put up for signature file

CFO/S2

M. S. Cell

18/11


20/11