

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI- 110001

NO. F6/DFS/MS/School/2017/SZ /85

Dated: 19/01/2017

FIRE SAFETY CERTIFICATE

Certified that the CANDYFLOSS Nursery School located at Sector-9, Dwarka, New Delhi-110045, comprised of ground plus two upper floors with basement owned / occupied by South Delhi Educational Society was granted NOC by this department vide letter no. F6/DFS/MS/School/2013/SZ/1319 dated 18.12.2013 in the name & style of ITL CANDYFLOSS Nursery School. The premises was re-inspected by the officer concerned of this department on 09.1.2017 in presence of Sh. Rajan (Estate Officer) and found that the premises have deemed complied with fire prevention and fire safety requirements in accordance Circular no. F.16/Estate/CC/Fire safety/2011/3298 to 3398 dated 01.03.2011 issued by Directorate of education Govt. of NCT of Delhi, and that the premises/ building is fit for occupancy class B "Educational building" effect from...19/01/2017... for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules 2010, printed overleaf.

Issued on ...19/01/2017... at New Delhi by


(VipinKental)
Chief Fire Officer


Copy to:-

1. The Deputy Director (Education), Govt. of NCT of Delhi, Old Secretariat, New Delhi-54.
2. Director, CANDYFLOSS Nursery School, Sector-9, Dwarka, New Delhi-110077.

CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner /occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner / occupier shall apply for renewal of this **Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37)** along with copy of the certificate, six months prior to its expiry.

INSPECTION REPORT

1	Name & address of the building	CANDYFLOSS Nursery School, Located at Sector-9, Dwarka, New Delhi.		
2	Type of Occupancy	Educational Building "B" (Basement,Ground +Two upper floors)		
3	Type of case	Renewal		
4	Details of previous NOC	F6/DFS/MS/School/2013/SZ/1319 dated 18.12.2013		
5	Fire safety directives letter No	D.O.E letter dated 01.03.2011		
6	Date of inspection	09.01.2017		
7	Name of the inspecting Officers :	ADO S.P. Bhardwaj		
8	Name and designation of officers from the building side	Sh. Rajan (Estate Officer)		
9	Year of construction	2008		
10	Applicant's letter No.	Nil dated 15.12.2016	Basement, Ground plus two upper floors	

S. NO.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement/ DOE letter 01.3.2011	Fire safety arrangement as per letter dated 18.12.2013	Remarks MR / NMR
--------	---	---------------------------------------	--	------------------

1	Access to building			
	1) Road width	6 Mtrs.	9 Mtrs.	MR
	2) Gate width	4.5 Mtrs.	4.25 Mtrs.	MR being old case
	3) Width of internal road	N/A	N/A	N/A

2	Number, width Type & arrangement of exits			
	a. Number of staircases			
	1. Upper floors	2 Nos.	2 Nos.	MR
	2. basements	2 Nos.	1 No. + 1 Ramp	MR being old case
	b. Width of staircase			
	1. Upper floors	1.5 Mtrs.	1.5 Mtrs.	MR
	2. basements	1.5 Mtrs.	1.42 Mtrs., Ramp (5 Mtrs.)	MR being old case
	c. Protection of exits			
	1. Fire check door	Required	Provided	MR
	2. Pressurization	N/A	N/A	N/A
	d. No. of continuous staircase to terrace	One	One	MR
	e. Width of corridor	N/A	1.5 Mtrs.	N/A
	f. Door size	1 Mtr.	1 Mtr.	MR

3	Compartmentation.			
	1. Fire check door	Required	Provided	MR
	2. Sealing of electrical shafts	N/A	N/A	N/A
	3. Fire Rating of shaft door	N/A	N/A	N/A
	4. water curtain	N/A	N/A	N/A
	5. Fire dampers	N/A	N/A	N/A

4	Smoke Management system.			
	basement	30 A/C per hour	Exhaust fan Provided	MR
	upper floors		N/A	N/A

5	Fire Extinguishers			
	total numbers	8 Nos. Co2 & ABC ISI Marked	8 Nos.	MR
	Types		Co2 & ABC	MR

6	First-Aid Hose Reels.			
	total numbers on each floor	One	One	MR
	Length of Hose reel hose	30 m	30 Mtrs.	MR
	Nozzle Diameter	5 mm	5 mm	MR
7	Automatic fire detection and alarming system			
	Type of detectors	N/A	N/A	N/A
	location of Main Panel	N/A	N/A	N/A
	location of Repeater panel	N/A	N/A	N/A
	Alternate source of power	N/A	N/A	N/A
	hooter's location	N/A	N/A	N/A
8	MOEFA	N/A	N/A	N/A
9	Public Address System.	N/A	Provided	N/A
10	Automatic Sprinkler System.			
	basement	Required	Provided	MR
	upper floors	N/A	N/A	N/A
	sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	Size of riser/down-corner	N/A	100 MM	N/A
	Number of Hydrants per floor	N/A	One	N/A
	hose Box	N/A	Provided	N/A
12	Yard Hydrants.			
	total number of hydrants	N/A	N/A	N/A
	hose box	N/A	N/A	N/A
13	Pumping arrangements			
	1. Ground level			
	a. Discharge of main Pump	N/A	N/A	N/A
	b. Head of main pump	N/A	N/A	N/A
	c. Number of main pumps	N/A	N/A	N/A
	d. jockey pump out put	N/A	N/A	N/A
	e. jockey pump head	N/A	N/A	N/A
	f. Standby Pump output	N/A	N/A	N/A
	g. Stanby Pump head	N/A	N/A	N/A
	h. Auto Starting/Manual stopping	N/A	N/A	N/A
	pump house access	N/A	N/A	N/A
	2. Terrace level			
	a. Discharge of pump	450, 180 LPM.	450, 180 LPM	MR
	b. head of the pump	40 Mtrs.	40 Mtrs.	MR
	c. Power supply	Required	Provided	MR
	d. Auto starting of pump	Required	Provided	MR
14	Captive water storage for fire fighting			
	1. Underground tank capacity	N/A	N/A	N/A
	a. Draw-off connection	N/A	N/A	N/A
	b. fire service inlet	N/A	N/A	MR
	c. Access to tank	N/A	N/A	N/A
	Over head tank Capacity	Old case	5000 Ltrs.	MR being old case
15	Exit Signage.	Required	Provided	MR
16	Provision of lifts.			
	a. Pressurization of lift shaft	N/A	N/A	N/A
	b. pressurization of lift lobby	N/A	N/A	N/A
	c. communication in lift car	N/A	N/A	N/A
	d. Fireman's grounding switch	N/A	N/A	N/A
	e. Lift signage	N/A	N/A	N/A

N/9

17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.	Not Required		
	total area			
	location			
19	Fire control room			
	a. detector system Panel	N/A	N/A	N/A
	b. Flow switch Panel	N/A	N/A	N/A
	c. PA system Panel	N/A	N/A	N/A
	d. Batter backup	N/A	N/A	N/A
	e. Building floor plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special risks, if any: Co2 fire extinguisher provided near electric panel			MR

The fire protection systems provided in the building were checked and found functional at the time of inspection.

Keeping in view deemed compliance of the minimum standards on fire prevention and fire safety required under the rules , renewal of FSC issued vided letter no.F6/DFS/MS/School/2013/SZ/1319 dated 18.12.2013 for ground plus two upper floor is recommended under rules 37of the Delhi Fire Service Act 2007 & Rules 2010.

Accordingly DFA is put up for approval and signature please.

S.P. Bhardwaj
10/11/17

Signature of the Inspecting Officer

Name S.P. Bhardwaj

Designation ADO (Dwarka)

~~DO/DO~~

dkg
11/1/17

532/cf/s2
13/1/17/19/1

DCFO (S2)

dkp
12/1



cf/s2

m-s cell

FT/101
13/1