

FORM H:  
FORM FOR ISSUING FIRE SAFETY CERTIFICATE  
[SEE SUB RULE (1) OF RULE 35]  
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE  
NEW DELHI

No. F-6/DFS/MS/Banquet/2017/ 100

Dated 20/01/2017

**FIRE SAFETY CERTIFICATE**

Certified that the **Celebration Banquet Hall** Located at **Basement + Ground Floor+1<sup>ST</sup> Floor only**, A-16/3, Wazirpur Industrial Area, New Delhi – 110052 in a building comprised of Basement + Ground +2 upper Floor only was issued FSC vide Letter No. F-6/DFS/MS/Banquet/2012/582 Dated 21/02/2012 The premises was re inspected by the officers concerned of this department on 11-01-2017 in the presence of Sh. Sanjeev Verma (Owner) and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and that the premises is fit for occupancy class “ Assembly” Group D (**Basement + Ground Floor+1<sup>ST</sup> Floor only**) with effect from 20/01/17 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on .....20/01/17..... at New Delhi by.

(Atul Garg)

Chief Fire Officer,  
Delhi Fire Service

Copy to:

Sh.Sanjeev Verma, Celebration Banquet Hall,  
A-16/3, Wazirpur Industrial Area, New Delhi – 110052.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used as per building bye laws.
7. The owner/occupier shall submit a declaration every year in the form ‘K’ provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
8. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form ‘J’ [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
9. 2<sup>nd</sup> floor shall be used for kitchen purpose only.

## INSPECTION REPORT

1. Name & address of the building: Celebration Banquet Hall Located at, Basement Ground and 1<sup>st</sup> floor at A-16/3, Wazirpur Industrial Area, New Delhi – 110052.
2. Type of Occupancy : Assembly (**Basement+ Ground+1<sup>nd</sup> floor only in a building comprised of Basement+ Ground+2 Upper floors**)
3. Type of Case :Renewal
4. Details of previous NOC : F-6/DFS/MS/Banquet/2012/582 Dated 21/02/2012
5. Fire Safety directives Letter No. : F-6/DFS/MS/BP/2011/43 Dated 06/01/2012
6. Date of inspection : 11-01-2017
7. Name of the Inspecting Officer : ADO (WP)
8. Name and designation of Officer  
from the building side : Sh. Sanjeev Verma (Owner)
9. Year of Construction : 1975
10. Applicant's letter No. : Nil Dated-07/12/16

S No	Minimum standards on fire prevention and fire safety U/R 33	As Per Directive	Provided at site	Remarks MR/NMR
1.	Access of building			
	<ul style="list-style-type: none"> <li>• Road width</li> <li>• Gate width</li> <li>• Width of internal road</li> </ul>	<ul style="list-style-type: none"> <li>6m</li> <li>5m</li> <li>NA</li> </ul>	<ul style="list-style-type: none"> <li>9m</li> <li>5m</li> <li>NA</li> </ul>	<ul style="list-style-type: none"> <li>MR</li> <li>MR</li> <li>NA</li> </ul>
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	3	Provided	MR
	• Basements	2	Provided	MR
	b. Width of staircases			
	• Upper floors	2x1.5 m, 1x100cm	1x175cm,1x100cm 1x150 cm provided	MR( Old Case)
	• Basements	1x1.65 m ,1x100cm	1x165cm & 1x90cm Provided	MR
	c. Protection of exits			
	• Fire check door	Required (In Basement)	Provided	MR
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	02	Provided	MR
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	2 mtr	GF=2m,1x100cm FF=185cm,90cm & 100cm	MR
3.	Compartmentation			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Sealing of electrical shafts</li> <li>• Fire Rating of shaft door</li> <li>• Water Curtain</li> <li>• Fire Dampers</li> </ul>	<ul style="list-style-type: none"> <li>Required</li> <li>NA</li> <li>NA</li> <li>NA</li> <li>NA</li> </ul>	<ul style="list-style-type: none"> <li>Provided</li> <li>NA</li> <li>NA</li> <li>NA</li> <li>NA</li> </ul>	<ul style="list-style-type: none"> <li>MR</li> <li>NA</li> <li>NA</li> <li>NA</li> <li>NA</li> </ul>
4.	Smoke managements System			
	• Basements	Required	Provided	MR
	• Upper floors	Required	Provided	MR
5.	Fire Extinguishers			
	• Total numbers	10 nos.	Provided	MR
	• Types	ABC & CO2	Provided	MR

6.	<ul style="list-style-type: none"> <li>Total numbers on each floor</li> <li>Length of hose reel hose</li> <li>Nozzle diameter</li> </ul>	2	Provided	MR
		30 m	30 mtr	MR
		5 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	Smoke & Heat	Provided	MR
	• Location of Main Panel	Ground floor	Provided	MR
	• Location of Repeater Panel	Ground floor	Provided	MR
	• Alternate source of power	Required	Provided	MR
	• Hooters' Location	Required	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	• Basements	Required	Provided	MR
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants			
	• Size of riser/down-comer	4 inch	Provided	MR
	• Number of hydrants per floor	2	Provided	MR
	• Hose Box	2	Provided	MR
12.	Yard Hydrants			
	• Total number of Hyd	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements			
	• Ground Level			
	• Discharge of main pump	NA	NA	NA
	➤ Head of main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Starting/Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	900 lpm	Provided	MR
	➤ Head of the pump	40 m	Provided	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14.	Captive water Storage for fire fighting			
	• Under ground tank capacity	NA	NA	NA
	➤ Draw of connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	20,000 ltrs	Provided	MR
15.	Exit Signs	Provided	Provided	MR

Provision of Lifts( Lift run from Ground to 2 <sup>rd</sup> Floor)			
➤ Pressurization of Lift Shaft	NA	NA	NA
➤ Pressurization of lift lobby	NA	NA	NA
➤ Communication in lift Car	Required	Provided	MR
➤ Fireman's Grounding Switch	Required	Provided	MR
➤ Lift Signage	Required	Provided	MR
17. Standby power supply	Required	Provided	MR
18. Refuge Area	NA	NA	
➤ Total area	NA	NA	NA
➤ Location	NA	NA	NA
19. Fire control room			
➤ Detector system panel	NA	NA	NA
➤ Flow Switch Panel	NA	NA	NA
➤ PA System Panel	NA	NA	NA
➤ Battery backup	NA	NA	NA
➤ Building Floor Plans	NA	NA	NA
20. Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the FSC issued vide letter no F-6/DFS/MS/Banquet/2012/582 Dated 21/02/2012 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

**Note** Earlier FSC issued vide letter no. F-6/DFS/MS/Banquet/2012/582 Dated 21/02/2012 was issued for B+G+2UFs now FSC is recommended to run the Banquet at Ground and 1<sup>st</sup> floor.

The basement is being used as storage and 2<sup>nd</sup> floor for kitchen and staff room.

Signature of the Inspecting Officer

Signature of the Inspecting Officer

Name

Name

Designation

Designation

*Handwritten signature and date 13/1/17*

*Handwritten signature and date 16/1/17*