

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/SCHOOL/2017/ 98

Dated: 20/01/17

FIRE SAFETY CERTIFICATE

Certified that the S.D. Memorial Public School at Nilothi Extn, Village Nilothi, Nangloi, New Delhi- 41, comprised of ground floor + one upper floor owned/occupied by Saroj Devi Educational Welfare Society, has already been issued NOC / FSC by this department vide letter No. F.6/DFS/MS/School/2013/WZ/622 dated 25.07.2013. The premises was re-inspected by the officer concerned of this department on 27.12.2016 in the presence of Sh. Raj Pal (Owner), and observed that Fire prevention and fire safety arrangements provided in the premises, found in good working condition. The premises have therefore, deemed complied with the fire prevention and fire safety requirements in accordance with the circular issued by Circular No. F6/Estate/CC/Fire/Safety/2011/3298-3398 dated 01/03/2011 and that the building / premises is fit for occupancy class Educational (Group B) with effect from ... 20/01/17 ... for a period of 3 (three) years subject to conditions printed below.

Issued on 20/01/17 at New Delhi by.

(ATUL GARG)

CHIEF FIRE OFFICER.

Copy to :-

1. Sh. Rajpal (Manager), S.D. Memorial Public School, Nilothi Extn, Village Nilothi, Nangloi, New Delhi- 41.

Following fire safety directives must be adhered to:-

1. All the means of escape shall be kept free of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working conditions all the time and any lapse rendering non functional of fire safety measures, management shall be responsible.
4. Any deviation with regards to construction, electrical installation etc. may be got verified from the concerned authorities.
5. This NOC may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner/occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt..nic.in.

INSPECTION REPORT

1. Name & address of the building: S.D. Memorial Public School, Nilothi Extn,
Village Nilothi, Nangloi, New Delhi- 41
2. Type of Occupancy : Educational (Ground+1st Floor only)
3. Type of Case : Renewal (Plot Area-4840 Yard²)
(Total Covered Area-800 yard²)
4. Details of previous NOC : F.6/DFS/MS/School/2013/WZ/622 dated 25.07.2013
5. Fire Safety directives Letter No. : DOE Circular dated 1.03.2011
6. Date of inspection : 27/12/2016
7. Name of the Inspecting Officer : A. K. Jaiswal
8. Name and designation of Officer
from the building side : Sh. Raj Pal (Owner)
9. Year of Construction : ---2011
10. Applicant's letter No. : SDMPS/09/016 dated 28/11/2016

S No	Minimum standards on fire prevention and fire safety U/R 33	DOE Circ. Dated 1/03/11 Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	6 mtr	6 mtr	MR
	• Gate width	5 mtr	5 mtr	MR
	• Width of internal road	N/A	N/A	N/A
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	1	2	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	1.50 mtr	1.30 x 2	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No of continuous staircase to terrace	1	2	MR
	e. Width Of Corridor	1.50 mtr	1.50 mtr	MR
	f. Door Size	1.00 mtr	1.00 mtr	MR
3.	Compartmentation			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	Open to sky	Open to sky	MR
5.	Fire Extinguishers			
	• Total numbers	4	8	MR
	• Types	ISI marked ABC/CO ₂	Provided	M/R

	Total numbers on each floor	N/A	N/A	N/A
	• Length of hose reel hose	N/A	N/A	N/A
	• Nozzle diameter	N/A	N/A	N/A
7.	Automatic fire detection and alarming system			
	• Type of detector	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooters' Location	N/A	N/A	N/A
8.	MOEFA	N/A	N/A	N/A
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	• Basements	N/A	N/A	N/A
	• Upper Floor	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	• Size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
12.	Yard Hydrants			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13.	Pumping Arrangements			
	• Ground Level	N/A		
	• Discharge of main pump	N/A	N/A	
	➤ Head of main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Starting/Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace level			
	➤ Discharge of pump	N/A	N/A	N/A
	➤ Head of the pump	N/A	N/A	N/A
	➤ Power supply	N/A	N/A	N/A
	➤ Auto starting of pump	N/A	N/A	N/A
14.	Captive water Storage for fire fighting			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw of connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A

N/8

15	Exit Signage	N/A	N/A	N/A
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	N/A	N/A	N/A
	➤ Pressurization of lift lobby	N/A	N/A	N/A
	➤ Communication in lift Car	N/A	N/A	N/A
	➤ Fireman's Grounding Switch	N/A	N/A	N/A
	➤ Lift Signage	N/A	N/A	N/A
17.	Standby power supply	N/A	N/A	N/A
18.	Refuge Area	N/A	N/A	
	➤ Total area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19.	Fire control room			
	➤ Detector system panel	N/A	N/A	N/A
	➤ Flow Switch Panel	N/A	N/A	N/A
	➤ PA System Panel	N/A	N/A	N/A
	➤ Battery backup	N/A	N/A	N/A
	➤ Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection Systems for Protection of special Risks, if any;	N/A	N/A	N/A

Note:- General requirements for schools as per Director of Education circular dated 1/03/2011.

1. Escape routeClear.....
2. LPG cylinders in laboratoriesNil.....
3. Electric wiring ...Conduit Wiring..... MCB and ELCB Provided.....
Electric circuit
4. Electric meter boardNot under the staircase.....
5. Basement use as per BBL 1983NA.....
6. Emergency telephone no. boardDisplayed.....
7. Generator setNil.....

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter No. F.6/DFS/MS/School/2013/WZ/622 dated 25.07.2013 renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

D.O. (W)

[Signature]
6/1/17

[Signature]
27/12/16

Signature of the Inspecting Officer

Name : Ashok Kumar Jaiswal

Designation : A.D.O. (Jwala Puri)

~~D.O. (W)~~

~~CFO - West~~
16/1/17

[Signature]
12/1/17